

MSME chemical unit invests Rs 30 lakhs in energy efficiency measures—and saves Rs 20 lakhs every year!

Background

Ankleshwar is a chemical cluster in Gujarat. It has over 700 MSMEs manufacturing various kinds of chemicals (dyes and pigments—67%; pharma and pharma intermediates—27%; and pesticides and chlor-alkalis—6%). The production capacity of these units varies from 50 tonnes to over 10,000 tonnes per annum (tpa).

Unit profile


M/s **A19** is an MSME unit that manufactures iron oxide (red and yellow), producing about 600 tpa. The annual energy bill of the unit was INR 108 lakhs, which was around 86% of total turnover. The annual energy consumption was around 756 tonnes of oil equivalent (toe), of which firewood accounted for 676 toe (89%), natural gas (NG) 58 toe (8%) and grid electricity 22 toe (3%).

Process description

The manufacturing process involves reaction of the raw materials at a particular temperature, which is maintained through indirect heating by steam from a wood-fired boiler. The products of reaction are filtered, dried using an NG-based rotary dryer, pulverized and ground to give the final products.


The major energy consuming equipments used were a wood-fired 2pass IBR boiler of capacity 1000 kg/hour, an NG-based single pass rotary dryer, electrical motors associated with various utilities, and lighting.

Overall Impact: post-implementation



Overall Impact 18% reduction in total energy bill (i.e. annual savings of INR 21 lakhs) with a simple payback of 1.5 years

This case study has been prepared under WB GEF Project titled "Financing Energy Efficiency at MSMEs in India". The project aims to identify, design & implement Energy Efficiency (EE) solutions in 500 MSMEs in 5 clusters with potential of EE investment of more than Rs. 100 crore and reduction in GHG emissions equivalent to 1.2 million tonne CO_2 . This project is being co-implemented by Small Industries Development Bank of India (SIDBI) and Bureau of Energy Efficiency (BEE).





Replacement of existing 2-pass boiler with 3-pass boiler of larger capacity

Baseline Scenario

The existing wood-fired 2-pass IBR boiler of 1000 kg/hour capacity had an efficiency of only about 46% due to energy losses through dry flue gas and high flue gas temperature.

Recommendation

The unit was advised to replace the existing boiler with an energy efficient 3-pass IBR boiler of 2000 kg/hour capacity.

Installation of waste heat recovery system in the rotary dryer

The exhaust temperature of the hot air from the rotary dryer was very high (694 °C), indicating energy loss. As advised, the unit installed a shell and tube type 'economizer' (waste heat recovery device) to recover heat from exhaust air and use it to the pre-heat the boiler feed water. This investment of INR 1.6 lakhs is saving around 17.5 tonnes of firewood annually, equivalent to INR 0.6 lakh. The simple payback period is 2.9 years.

Implemented Scenario

As advised, the unit replaced the existing boiler with an energy efficient 3-pass IBR boiler of 2000 kg/hour capacity.





This investment of INR 26.7 lakhs is saving 476 tonnes of wood annually, equivalent to INR 15.5 lakhs. The simple payback period is 1.7 years.

Installation of energy efficient burner system in rotary dryer

The efficiency of the rotary dryer was very low, at about 19%, because the existing burner system did not have a temperature-based system to regulate NG flow. As advised, the unit installed an energy efficient burner system in the rotary dryer and also applied proper insulation to the outer surface of the dryer. This investment of INR 1.6 lakhs is saving about 9800 SCM of NG annually, equivalent to INR 4.1 lakhs. The simple payback period is 0.4 years.

Replacement of existing lighting with energy efficient lighting system

The unit was using about 16 fluorescent tube lights (FTLs) of T-12 and T-8 type. As advised, the unit replaced these with energy efficient FTLs of T-5 type. This investment of INR 0.2 lakh is saving 1014 kWh of electricity annually, equivalent to INR 0.1 lakh. The simple payback period is 2.7 years.



Disclaimer: This case study has been compiled by TERI on behalf of SIDBI under WB–GEF Project. While every effort has been made to avoid any mistakes or omissions, these agencies will not be in any way liable for any inadvertent mistakes/omissions in the publication.

For further information please contact:

Energy Efficiency Centre, Small Industries Development Bank of India (SIDBI), Ground Floor, E-1, Videocon Tower, Jhandewalan Extension, Rani Jhansi Road, New Delhi-110055, India, Ph. 011 23682473-77, www.sidbi.in



