

# Reactive Power Management Through Capacitor & APFC



# Context

## Presentation Covers

- Rajasthan Bill Tariff
- Existing Bill Pattern
- What is Power Factor ?
- Why to Maintain ?
- How to Maintain
- Case Study

# Rajasthan State

## Rajasthan State having 3 Discoms

- Ajmer Vidyut Vitran Nigam Ltd
- Jaipur Vidyut Vitran Nigam Ltd.
- Jodhpur Vidyut Vitran Nigam Ltd.

Following table is the contract demand and corresponding voltage for all 3 Discoms

<b>Contract demand</b>	<b>Voltage of Supply kV</b>
For Low and Medium	0.433
Upto 1500 KVA	11
Above 1500 KVA up to 5000 KVA	33
Above 5000 KVA	132 or 220

# Rajasthan State

For the 3 Discoms (Vidyut Vitran Nigam of Rajasthan)

Billing is in kWh

Existing Tariff of Electricity		
Category	02.11.2017 onwards	
	Energy Charges per Unit (Rs.)	Fixed Charges (per connection per month) (Rs.)
<b>INDUSTRIAL</b>		
<b>SIP (SP/LT-5) upto 18.65 kW (25HP)</b>		
Upto consumption 500 units/ month	6.00	Rs. 65/- per HP per month
Consumption above 500 units/ month	6.45	Rs. 65/- per HP per month
<b>MP/LT-6</b>		
Connected load more than 18.65 kW (25HP) upto 112 kW (150 HP) or Max. demand upto 50kVA	7.00	Rs. 75/- per HP per month or Rs. 165 per KVA of billing demand per month

# Rajasthan State

## **Power factor Clause for all 3 Discoms of Rajasthan**

- Consumer should have to maintain Power factor not less than 0.90.
- A surcharge at 0.1% of energy charges for energy 0.001 fall in average power below 0.900 shall be charged.
- An Incentive of 1% of Energy Charges shall be provided if the power factor is above 0.95 (95%) for each 0.01 (1%) improvement above 0.95 (95%).

# Bill Structure

उपखण्ड कोड, नाम व प. 1103310  
 AEN(O&M, Nagaur)  
 AVVNL

अजमेर विद्युत वितरण निगम लिमिटेड  
 विद्युत उपभाग विपन्न ( उपभोक्ता प्रति. )  
 फोन नं. AACC-A8562E

पता शिकायत केन्द्र :  
 बिल नं. 1033101690246  
 टोल फ्री शिकायत नं. 18001806565

ईमेल: [REDACTED] नं. 01582-240876

नाम	पता	क्र.सं.	विवरण	बिल राशि ( रु. )
		1.	विद्युत खर्च	18340.00
		2.	स्थाई शुल्क	4350.00
		3.	डिमांड सरचार्ज	
		4.	पावर फैक्टर सरचार्ज (+) प्रोत्साहन (-) /शंट कंपेसिटर सरचार्ज (3%)	
		5.	अनाधिकृत उपभोग राशि	
		6.	सी.टी./पी.टी./मीटर किराया	100.00
		7.	ट्रांसफार्मर किराया	
		8.	अन्य	1222.15
		9.	रिबेट्स (-) (i) वोल्टेज (ii) सोलर/स्प्रिंकलर/ग्रामीण रियायत	
		10.	निगम राशि ( क्रम सं. 1 से 9 तक का योग )	24012.15
		11.	विद्युत शुल्क वर्तमान उपभोग पर	1048.00
		12.	जल संरक्षण उपकर	262.00
		13.	नगरीय उपकर	393.00
		14.	अन्य देय/जमा कोड निगम राशि	
		15.	अन्य देय/जमा कोड विद्युत शुल्क	
		16.	अन्य देय/जमा कोड जल संरक्षण उपकर	
		17.	अन्य देय/जमा कोड नगरीय उपकर	

क. नंबर: 110331012729  
 RSN: 20  
 सेवा क्रमांक अमानत राशि 15080.00  
 वर्तमान खाता संख्या 0591/0145  
 बिल माह Mar/2018 कुल माह बिल 1.0000  
 फीडर कोड 11F1038107 टैरिफ कोड 6000XA  
 स्वी. श्रेणी MIP  
 स्वी. लोड (कि.वा./हा.पं.) 58.00 HF कनेक्टेड लोड (कि.वा./हा.पं.) 58.00 HF  
 कांटेक्ट डिमांड (क.वि.ए.) शहरी/ग्रामीण URBAN  
 सप्लाय वोल्टेज 400 V मीटरिंग वोल्टेज 400 V  
 मीटर स्वामित्व मीटरिंग टाइप TUM  
 पावर फैक्टर 0.903 बिलिंग डिमांड  
 औसत मासिक उपभोग (घ.वि.व.) 2244 मीटर सुरक्षा राशि



# Bill Structure

एड कोड: 1103310 नाम व पता: AEN (O&M, Nagaur)  
 पता शिकायत केंद्र: पता शिकायत केंद्र :  
 अजमेर विद्युत वितरण निगम लिमिटेड  
 विद्युत उपभोग विपत्र ( उपभोक्ता प्रति. )  
 पेन नं. AACC-AB562E  
 बिल नं. 11033101621468  
 टोल फ्री शिकायत नं. 18001806565.  
 फोन नं. 01582-240876

क्र.सं.	विवरण	विल राशि ( रु. )
1.	विद्युत खर्च	17640.00
2.	स्थाई शुल्क	4350.00
3.	डिमांड सरचार्ज	
4.	पावर फैक्टर सरचार्ज (+) प्रोत्साहन (-) / शंट कैपेसिटर सरचार्ज (3%)	2081.52
5.	अनाधिकृत उपभोग राशि	
6.	सी.टी./पी.टी./मीटर किराया	100.00
7.	ट्रांसफार्मर किराया	
8.	अन्य	
9.	रिबेट्स (-) (i) चोल्टेज	
	(ii) सोलर/सिप्रंक्लर/ग्रामीण रियायत	
10.	निगम राशि ( क्रम सं. 1 से 9 तक का योग )	24171.52
11.	विद्युत शुल्क वर्तमान उपभोग पर	1008.00
12.	जल संरक्षण उपकर	252.00
13.	नगरीय उपकर	
14.	अन्य देय/जमा कोड निगम राशि	
15.	अन्य देय/जमा कोड विद्युत शुल्क	
16.	अन्य देय/जमा कोड जल संरक्षण उपकर	
17.	अन्य देय/जमा कोड नगरीय उपकर	
18.	अन्य देय/जमा कोड/एल.ई.डी./डिफेंड ग्रॉजुना भुगतान	
19.	समायोजित राशि ( कोड )	

अमानत राशि 15080.00  
 कुल माह विल 1.0000  
 नो. नंबर: 110331012729  
 RSN: 20  
 तैरिफ कोड 6000XA  
 वोल्टेज 400 V  
 मीटरिंग टाइप TVM  
 मीटर सुरक्षा राशि  
 उपभोक्ता की स्थिति R

Office of the AEN (O&M)  
 A.V.V.N.L., NAGAUUR  
 S.D. CODE NO. 1886  
 CASH COUNTER No.-2  
 21 NOV 2017









# Power Factor

# Introduction

## Power Factor Basics

### Two Types of Power In System

1. Active Power
2. Reactive Power

# Power Factor

## Active Power


- **This involves transfer of Real Power from system to end user**
- **When Voltage and Current are in Phase with each other**

# Power Factor

## Reactive Power

- **This involves establishment of Magnetic field or Electric Field**
- **No transfer of Real Power is involved**
- **When Voltage and Current are out of phase by  $90^\circ$**


# Power Triangle



$$\text{Power Factor} = \frac{\text{kW (productive power)}}{\text{kVA (total power)}}$$

# Analogy

Power factor =  $\frac{kW}{kVA} = \frac{kW}{kW + kVAr} = \frac{\text{Beer}}{\text{Beer} + \text{Foam}}$



# Power Factor

## How Poor operating power factor cost money?

- **Maximum demand increases for the same load**
- **Draws more current for the same load**
- **More distribution voltage drop i.e loss in the distribution cable increase**
- **Copper loss in the transformer increase**



# Automatic Power Factor Controller (APFC)



# Selection of APFC

**The category of APFC is generally 3 types.**


- **Current - Sensing based APFC**
- **Power Factor Sensing based APFC**
- **kVAr Sensing based APFC**

# Types of APFC Panels

- **Contactor based APFC < 10 Sec**
- **Thyristors Based APFC < 1 Sec**
- **Microcontroller Based APFC < 5 milisec**

# Power Factor Compensation

## Centralized compensation



# Power Factor Compensation

## Centralized Compensation

### Advantages

- **Easy P.F maintenance**
- **Capacitor maintenance easy**


### Disadvantages

- **More voltage drop in distribution**
- **Over heating of cable resulting in failure**

**Common in engineering industry**


# Power Factor Compensation

## Distributed Compensation




# Power Factor Compensation

## Voltage and Current Harmonics Trend



# Power Factor Compensation

## Mixed Compensation





# Power Factor Compensation

## Mixed Compensation

### Advantages

- **Good P.F control**
- **Easy maintenance**
- **Low distribution losses**

**Common in cement industry**

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

- **Electrical Distribution system studied**
- **Over all power factor 0.94-0.95**
- **Possibility to improve to unity**

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Power factor for last 11 months in Plant -1

<b>Month &amp; Year</b>	<b>Power Factor</b>	<b>Opportunity PF = 0.99</b>	<b>Opportunity PF = 1.0</b>
Apr-12	0.937	69776	77529
May-12	0.946	68279	75865
Jun-12	0.95	56257	62508
Jul-12	0.95	61542	68380
Aug-12	0.944	70029	77810
Sep-12	0.964	49614	55127
Oct-12	0.968	53986	59984
Nov-12	0.944	104064	115626
Dec-12	0.933	123211	136901
Jan-13	0.963	69454	77171
Feb-13	0.951	87105	96784
<b>Total</b>		<b>813317</b>	<b>903685</b>

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Power factor for last 10 months in Plant -2

<b>Month &amp; Year</b>	<b>Power Factor</b>	<b>Opportunity PF = 0.99</b>	<b>Opportunity PF = 1.0</b>
May-12	0.921	83601	92889
Jun-12	0.904	92388	102654
Jul-12	0.955	50955	56617
Aug-12	0.95	59487	66096
Sep-12	0.929	102704	114116
Oct-12	0.923	137813	153125
Nov-12	0.932	201558	223953
Dec-12	0.966	59678	66309
Jan-13	0.963	134807	149786
Feb-13	0.944	134160	149067
Total		1057151	1174612

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

## Bill Analysis

Plant	Avg. Power Factor	Total Bill Last FY 2012-13	Opportunity			
			PF = 0.99	% age	PF = 1.0	%age
Plant-1	0.950	2.32 Crores	8.87 Lakhs	3.83 %	9.86 Lakhs	4.26 %
Plant-2	0.939	2.33 Crores	12.69 Lakhs	5.44 %	14.10 Lakhs	6.04 %

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

## Action Plan

- **Maintenance of existing system**
- **Installation of APFC Panels at different areas**

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Capacitor Health Checkup 1250 KVA Transformer

Capacitor Detail	Rating	Ideal Current	Current in Phases (Ampere)		
	KVAR		Ampere	R	Y
Capacitor No 1	25	28-30	15.5	8.8	8.8
Capacitor No 2	25	28-30	0	0	0
Capacitor No 3	25	28-30	20.1	20.8	20.2
Capacitor No 4	25	28-30	20.8	20.6	20.2
Capacitor No 5	25	28-30	0	0	0
Capacitor No 6	25	28-30	17.8	8.6	23.2
Capacitor No 7	25	28-30	0	0	0
Capacitor No 8	25	28-30	25.3	25.4	0
Capacitor No 9	25	28-30	19.3	20.3	21.8
Capacitor No 10	25	28-30	23.8	23.2	30.8
Capacitor No 11	25	28-30	28.3	28.9	29.7
Capacitor No 12	25	28-30	0	0	0
Capacitor No 13	25	28-30	29.6	29.3	29.7
Capacitor No 14	50	58-60	45	50.2	50.8
Capacitor No 15	50	58-60	53	61.4	53.1
Capacitor No 16	50	58-60	0	0	0
Capacitor No 17	50	58-60	34.2	37.4	28.5
Capacitor No 18	50	58-60	60.7	51.1	52.6
Capacitor No 19	50	58-60	53.1	52.8	61.2

# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Capacitor Health Checkup 800 KVA Transformer

Capacitor Detail	Rating	Ideal Current	Current in Phases (Ampere)		
	KVAR		Ampere	R	Y
Capacitor No 1	25	28-30	24.9	32	24.5
Capacitor No 2	25	28-30	28	28.6	27.4
Capacitor No 3	25	28-30	28.5	28.7	0
Capacitor No 4	25	28-30	27.4	57.6	66.7
Capacitor No 5	25	28-30	24.8	26.2	25
Capacitor No 6	50	58-60	54	52.4	32.3
Capacitor No 7	25	28-30	21.1	22.5	20.8
Capacitor No 8	50	58-60	55.7	0	55.8
Capacitor No 9	25	28-30	27.3	27.3	26.7
Capacitor No 10	25	28-30	32.7	32.4	32
Capacitor No 11	50	58-60	65.7	64.9	64.4
Capacitor No 12	25	28-30	32.6	32.2	32.4
Capacitor No 13	25	28-30	32.2	35	35.4
Capacitor No 14	25	28-30	32.5	32.4	32.1




# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Sr. No.	Section Description	Voltage Volts	Currents Amperes	Power kW	Power Factor
1	Bonding and Tool Room	395	224	117	0.74
2	DTA Moulding 1	397	49	34	0.72
3	Accounts and Ship Compressor	397	47.7	29.7	0.9
4	Moulding Heavy line	395	47.8	28	0.83
5	DTA Moulding 2	392	316	177	0.85
6	DTA Finishing and Redeam	395	176	73	0.65
7	Compressor 500 CFM	397	137	82	0.87
8	EOU New Moulding	397	22.4	10.9	0.35
9	Press Shop	397	112	55	0.76
10	Clutch facing	397	316	202	0.93
11	Power House, Store DTA	426	22.6	16.75	0.72
12	OCV Finishing	427	117	68.5	0.79
13	OCV Basement DB1	427	97	68	0.95
14	OCV Basement Moulding DB2	427	125	78	0.82
15	OCV Lighting	427	11.7	7.2	0.89
16	Main Gate and Boundary Light	427	8.7	4.8	0.75
17	Moulding EOU	429	184	180	0.74
18	Dy 1 & 2	430	27.9	10	0.47
19	Moulding 3	431	120	78	0.86
20	4 Wheeler	434	41	22	0.68
21	Moulding 1	434	115	82	0.93

# Power Factor Compensation

## Mixed Compensation



# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Sr. No.	Section Description	Power Factor	Power kW	KVAR Required
1	Transformer 1250 KVA			250
2	Transformer 800 KVA			250
3	Bonding and Tool Room	0.74	117	125
4	DTA Moulding 2	0.85	177	125
5	DTA Finishing and Redeam	0.65	97	125
6	Clutch facing	0.93	202	100
7	OCV Finishing	0.79	68.5	100
8	OCV Basement Moulding DB2	0.82	78	100
9	Moulding EOU	0.74	180	150


# Power Capacitors

- Capacitor banks install to improve power factor


## *Reasons for failure*

- Ageing
- Input voltage and frequency fluctuation
- Harmonics present in the system
- Temperature around the bank
- Poor quality capacitors use in the construction

# Power Capacitors



# Power Capacitors



# IMPROVE OVERALL POWER FACTOR OF PLANT TO 0.99

Savings = Rs. 8.87 Lakhs + Rs. 12.69 = Rs. 21.56 Lakhs

<b>Annual Saving</b>	<b>- Rs 21.56 Lakhs</b>
<b>Investment</b>	<b>- Rs 12.00 Lakhs</b>
<b>Pay Back</b>	<b>- 7 Months</b>

# Capacitor Selection

v **Chart Method**

v **Formula Method**

➤ **Capacitor required (KVAr)**

$$= \text{kW} \times \{ \text{Tan } \cos^{-1}\Phi_1 - \text{Tan } \cos^{-1}\Phi_2 \}$$

➤ **Cos  $\Phi_1$  – Present power factor**

➤ **Cos  $\Phi_2$  – Desired power factor**



**TABLE 1.2 MULTIPLIERS TO DETERMINE CAPACITOR kVAR REQUIREMENTS FOR POWER FACTOR CORRECTION**


Original Power Factor	Desired Power Factor																				
	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.89	0.90	0.91	0.92	0.93	0.94	0.95	0.96	0.97	0.98	0.99	1.0
0.50	0.982	1.008	1.034	1.060	1.086	1.112	1.139	1.165	1.192	1.220	1.248	1.276	1.306	1.337	1.369	1.403	1.440	1.481	1.529	1.589	1.732
0.51	0.937	0.962	0.989	1.015	1.041	1.067	1.094	1.120	1.147	1.175	1.203	1.231	1.261	1.292	1.324	1.358	1.395	1.436	1.484	1.544	1.687
0.52	0.893	0.919	0.945	0.971	0.997	1.023	1.050	1.076	1.103	1.131	1.159	1.187	1.217	1.248	1.280	1.314	1.351	1.392	1.440	1.500	1.643
0.53	0.850	0.876	0.902	0.928	0.954	0.980	1.007	1.033	1.060	1.088	1.116	1.144	1.174	1.205	1.237	1.271	1.308	1.349	1.397	1.457	1.600
0.54	0.809	0.835	0.861	0.887	0.913	0.939	0.966	0.992	1.019	1.047	1.075	1.103	1.133	1.164	1.196	1.230	1.267	1.308	1.356	1.416	1.559
0.55	0.769	0.795	0.821	0.847	0.873	0.899	0.926	0.952	0.979	1.007	1.035	1.063	1.093	1.124	1.156	1.190	1.227	1.268	1.316	1.376	1.519
0.56	0.730	0.756	0.782	0.808	0.834	0.860	0.887	0.913	0.940	0.968	0.996	1.024	1.054	1.085	1.117	1.151	1.188	1.229	1.277	1.337	1.480
0.57	0.692	0.718	0.744	0.770	0.796	0.822	0.849	0.875	0.902	0.930	0.958	0.986	1.016	1.047	1.079	1.113	1.150	1.191	1.239	1.299	1.442
0.58	0.655	0.681	0.707	0.733	0.759	0.785	0.812	0.838	0.865	0.893	0.921	0.949	0.979	1.010	1.042	1.076	1.113	1.154	1.202	1.262	1.405
0.59	0.619	0.645	0.671	0.697	0.723	0.749	0.776	0.802	0.829	0.857	0.885	0.913	0.943	0.974	1.006	1.040	1.077	1.118	1.166	1.226	1.369
0.60	0.583	0.609	0.635	0.661	0.687	0.713	0.740	0.766	0.793	0.821	0.849	0.877	0.907	0.938	0.970	1.004	1.041	1.082	1.130	1.190	1.333
0.61	0.549	0.575	0.601	0.627	0.653	0.679	0.706	0.732	0.759	0.787	0.815	0.843	0.873	0.904	0.936	0.970	1.007	1.048	1.096	1.156	1.299
0.62	0.516	0.542	0.568	0.594	0.620	0.646	0.673	0.699	0.726	0.754	0.782	0.810	0.840	0.871	0.903	0.937	0.974	1.015	1.063	1.123	1.266
0.63	0.483	0.509	0.535	0.561	0.587	0.613	0.640	0.666	0.693	0.721	0.749	0.777	0.807	0.838	0.870	0.904	0.941	0.982	1.030	1.090	1.233
0.64	0.451	0.474	0.503	0.529	0.555	0.581	0.608	0.634	0.661	0.689	0.717	0.745	0.775	0.806	0.838	0.872	0.909	0.950	0.998	1.068	1.201
0.65	0.419	0.445	0.471	0.497	0.523	0.549	0.576	0.602	0.629	0.657	0.685	0.713	0.743	0.774	0.806	0.840	0.877	0.918	0.966	1.026	1.169
0.66	0.388	0.414	0.440	0.466	0.492	0.518	0.545	0.571	0.598	0.626	0.654	0.682	0.712	0.743	0.775	0.809	0.846	0.887	0.935	0.995	1.138
0.67	0.358	0.384	0.410	0.436	0.462	0.488	0.515	0.541	0.568	0.596	0.624	0.652	0.682	0.713	0.745	0.779	0.816	0.857	0.905	0.965	1.108
0.68	0.328	0.354	0.380	0.406	0.432	0.458	0.485	0.511	0.538	0.566	0.594	0.622	0.652	0.683	0.715	0.749	0.786	0.827	0.875	0.935	1.078
0.69	0.299	0.325	0.351	0.377	0.403	0.429	0.456	0.482	0.509	0.537	0.565	0.593	0.623	0.654	0.686	0.720	0.757	0.798	0.846	0.906	1.049
0.70	0.270	0.296	0.322	0.348	0.374	0.400	0.427	0.453	0.480	0.508	0.536	0.564	0.594	0.625	0.657	0.691	0.728	0.769	0.817	0.877	1.020
0.71	0.242	0.268	0.294	0.320	0.346	0.372	0.399	0.425	0.452	0.480	0.508	0.536	0.566	0.597	0.629	0.663	0.700	0.741	0.789	0.849	0.992
0.72	0.214	0.240	0.266	0.292	0.318	0.344	0.371	0.397	0.424	0.452	0.480	0.508	0.538	0.569	0.601	0.635	0.672	0.713	0.761	0.821	0.964
0.73	0.186	0.212	0.238	0.264	0.290	0.316	0.343	0.369	0.396	0.424	0.452	0.480	0.510	0.541	0.573	0.607	0.644	0.685	0.733	0.793	0.936
0.74	0.159	0.185	0.211	0.237	0.263	0.289	0.316	0.342	0.369	0.397	0.425	0.453	0.483	0.514	0.546	0.580	0.617	0.658	0.706	0.766	0.909
0.75	0.132	0.158	0.184	0.210	0.236	0.262	0.289	0.315	0.342	0.370	0.398	0.426	0.456	0.487	0.519	0.553	0.590	0.631	0.679	0.739	0.882
0.76	0.105	0.131	0.157	0.183	0.209	0.235	0.262	0.288	0.315	0.343	0.371	0.399	0.429	0.460	0.492	0.526	0.563	0.604	0.652	0.712	0.855
0.77	0.079	0.105	0.131	0.157	0.183	0.209	0.236	0.262	0.289	0.317	0.345	0.373	0.403	0.434	0.466	0.500	0.537	0.578	0.626	0.685	0.829
0.78	0.052	0.078	0.104	0.130	0.156	0.182	0.209	0.235	0.262	0.290	0.318	0.346	0.376	0.407	0.439	0.473	0.510	0.551	0.599	0.659	0.802
0.79	0.026	0.052	0.078	0.104	0.130	0.156	0.183	0.209	0.236	0.264	0.292	0.320	0.350	0.381	0.413	0.447	0.484	0.525	0.573	0.633	0.776
0.80	0.000	0.026	0.052	0.078	0.104	0.130	0.157	0.183	0.210	0.238	0.266	0.294	0.324	0.355	0.387	0.421	0.458	0.499	0.547	0.609	0.750
0.81		0.000	0.026	0.052	0.078	0.104	0.131	0.157	0.184	0.212	0.240	0.268	0.298	0.329	0.361	0.395	0.432	0.473	0.521	0.581	0.724
0.82			0.000	0.026	0.052	0.078	0.105	0.131	0.158	0.186	0.214	0.242	0.272	0.303	0.335	0.369	0.406	0.447	0.495	0.555	0.698
0.83				0.000	0.026	0.052	0.079	0.105	0.132	0.160	0.188	0.216	0.246	0.277	0.309	0.343	0.380	0.421	0.469	0.529	0.672
0.84					0.000	0.026	0.053	0.079	0.106	0.134	0.162	0.190	0.220	0.251	0.283	0.317	0.354	0.395	0.443	0.503	0.646
0.85						0.000	0.027	0.053	0.080	0.108	0.136	0.164	0.194	0.225	0.257	0.291	0.328	0.369	0.417	0.477	0.620
0.86							0.000	0.026	0.053	0.081	0.109	0.137	0.167	0.198	0.230	0.264	0.301	0.342	0.390	0.450	0.593
0.87								0.000	0.027	0.055	0.083	0.111	0.141	0.172	0.204	0.238	0.275	0.316	0.364	0.424	0.567
0.88									0.000	0.028	0.056	0.084	0.114	0.145	0.177	0.211	0.248	0.289	0.337	0.397	0.540
0.89										0.000	0.028	0.056	0.086	0.117	0.149	0.183	0.220	0.261	0.309	0.369	0.512
0.90											0.000	0.028	0.058	0.089	0.121	0.155	0.192	0.233	0.281	0.341	0.484
0.91												0.000	0.030	0.061	0.093	0.127	0.164	0.205	0.253	0.313	0.456
0.92													0.000	0.031	0.063	0.097	0.134	0.175	0.223	0.283	0.426
0.93														0.000	0.032	0.066	0.103	0.144	0.192	0.252	0.395
0.94															0.000	0.034	0.071	0.112	0.160	0.220	0.363
0.95																0.000	0.037	0.079	0.126	0.186	0.329
0.96																	0.000	0.041	0.089	0.149	0.292
0.97																		0.000	0.048	0.108	0.251
0.98																			0.000	0.060	0.203
0.99																				0.000	0.143
																					0.000



# Power Factor Study of Plant


- **Electrical Distribution system studied –**
- **Billing analysis done for last 1 Year**
- **Average power factor - 0.998**

# Transformer loading




# Transformer loading

## Power VS Power Factor Trend Transformer -3




# Transformer loading

## Power VS Power Factor Trend Transformer-5




# Transformer loading

## Power VS Power Factor Trend Transformer-8



# Transformer loading

## Power VS Power Factor Trend Transformer-11




# Thank you

**pankaj.dhote@cii.in**

**9685613238**



# Electrical System



# Agenda


- **Introduction – Electrical System**
- **Major Components**
- **Electrical System Audit**
- **Preventive Maintenance benefits**
- **Role of LSPs**

# Major Activities

## Major activities

- Bill Analysis
- Motor Loading Analysis
- Voltage Drop Study
- Power Factor Analysis
- Thermal Imaging
  - Power Quality / Harmonics Analysis
  - Capacitor Health Check up
  - Earthing / Lux Level
  - Idle Operation

# Load Distribution of Plant



# Transformer

## ❖ **Transformer**

➤ **Heart of Electrical Distribution**

## ❖ **Category**

➤ **Power Transformers**

➤ **Distribution Transformers**

# Loss in Transformer

- ❖ **Efficient Transformer – 1% loss**
  - **Substantial at higher ratings**
- ❖ **Losses contributed by**
  - **Core – No load loss**
  - **Copper Loss – Depends on load**

# How to Calculate Running Losses

**Total losses = No load losses + full load losses  
x (%age of transformer loading)<sup>2</sup>**

<b>Rating</b>	<b>= 2000 kVA</b>
<b>Loading</b>	<b>= 1400 kVA</b>
<b>Loading in %age</b>	<b>= 70 %</b>
<b>No Load Losses</b>	<b>= 3.4 kW</b>
<b>Full Load Losses</b>	<b>= 24 kW</b>
<b>Total Losses</b>	<b>= 3.4 + 24 (0.7 x 0.7)</b> <b>= 15.36 kW</b>

# Estimation of Losses

**Efficiency >>> 98-99 %**


- **Loss in 1 Transformer = 15.36 kW**
- **Operational Hours = 8500 Hrs/Yr.**
- **Power Cost = Rs. 7.0/ Unit**
- **Cost of Losses = 15.36 x 8500 x 7**  
**= Rs. 9.15 Lakhs/Yr.**



# **LATEST STANDARD DISTRIBUTION TRANSFORMERS 1180-1 (2014)**

# Transformer efficiency

## TRANSFORMER EFFICIENCY



# MAXIMUM TOTAL LOSSES & IMPEDANCE VALUES UPTO 11 kV CLASS TRANSFORMERS

Clauses (7.8.1.1)								
S.No	Rating	Impedance	Max. Total Loss (W)					
	(kVA)	(percent)	Energy Efficiency		Energy Efficiency		Energy Efficiency	
			Level 1		Level 2		Level 3	
			50 % Load	100 % Load	50 % Load	100 % Load	50 % Load	100 % Load
i	250	4.5	1050	3150	980	2930	920	2700
ii	315	4.5	1100	3275	1025	3100	955	2750
iii	400	4.5	1300	3875	1225	3450	1150	3330
iv	500	4.5	1600	4750	1510	4300	1430	4100
v	630	4.5	2000	5855	1860	5300	1745	4850
vi	1000	5	3000	9000	2790	7700	2620	7000
vii	1250	5	3600	10750	3300	9200	3220	8400
viii	1600	6.25	4500	13500	4200	11800	3970	11300
ix	2000	6.25	5400	17000	5050	15000	4790	14100
x	2500	6.25	6500	20000	6150	18500	5900	17500

# MAXIMUM TOTAL LOSSES & IMPEDANCE VALUES UPTO 11 kV CLASS TRANSFORMERS

S.No	Rating (kVA)	Energy Efficiency		Energy Efficiency		Energy Efficiency	
		Level 1		Level 2		Level 3	
		50 % Load	100 % Load	50 % Load	100 % Load	50 % Load	100 % Load
i	250	99.58 %	98.74 %	99.61 %	98.83 %	99.63 %	98.92 %
ii	315	99.65 %	98.96 %	99.67 %	99.02 %	99.70 %	99.13 %
iii	400	99.68 %	99.03 %	99.69 %	99.14 %	99.71 %	99.17 %
iv	500	99.68 %	99.05 %	99.70 %	99.14 %	99.71 %	99.18 %
v	630	99.68 %	99.07 %	99.70 %	99.16 %	99.72 %	99.23 %
vi	1000	99.70 %	99.10 %	99.72 %	99.23 %	99.74 %	99.30 %
vii	1250	99.71 %	99.14 %	99.74 %	99.26 %	99.74 %	99.33 %
viii	1600	99.72 %	99.16 %	99.74 %	99.26 %	99.75 %	99.29 %
ix	2000	99.73 %	99.15 %	99.75 %	99.25 %	99.76 %	99.30 %
x	2500	99.74 %	99.20 %	99.75 %	99.26 %	99.76 %	99.30 %

# Name Plate

## DISTRIBUTION TRANSFORMER

**CROMPTON GREAVES LIMITED**

3 PHASE TRANSFORMER

STANDARD

IS 1180 (PART 1)

KVA

2500

VOLTS AT  
NO LOAD

HV

11000

LV

433

BIL

HV

75 kVp / 28 kVrms

LV

- kVp / 3 kVrms

ENERGY EFFICIENCY LEVEL

1

MAX. TOTAL LOSSES  
AT 50% RATED LOAD

W

6500

MAX. TOTAL LOSSES  
AT 100% RATED LOAD

W

20000

TYPE OF COOLING

ONAN

TEMP RISE

OIL °C

40

WDG °C

45

# Case study (New Installation)

**Distribution transformer 2500 kVA**

**% Age impedance 6.25%**

## **Case 1**

**No load losses 3.8 kW**

**Load losses 28.0 kW**

## **Case 2 ( Level 1 : IS 1180)**

**No load losses 2.0 kW**

**Load losses 18.0 kW**

# Case study

**Consider Loading on transformer is 80 %**

**Total losses= No load losses + full load losses x  
(%age of transformer loading)<sup>2</sup>**

## **Case 1**

**Total Losses = 3.8 + 28 (0.8 x 0.8) = 21.72 kW**

## **Case 2**

**Total Losses = 2.0 + 18 (0.8 x 0.8) = 13.53 kW**

# Case study

**Total Savings = 21.71 – 13.52 = 8.2 kW**

**Operational Hours = 8500 hours**

**Total Energy saving = 8500 x 8.2 = 69700 Units**

**Unit Rate = Rs. 7.5 Per Unit**

**Savings = 69700 x 7.5 = Rs. 5.22 Lacs Per Annum**



# Case study

<b>Cost of Transformer with High Loss</b>	<b>= 16 lacs (Approx)</b>
<b>Cost of Transformer with Low Loss</b>	<b>= 26 lacs (Approx)</b>
<b>Extra Capital Amount</b>	<b>= 10 lacs</b>
<b>Savings</b>	<b>= 5.2 lacs/annum</b>
<b>Simple Payback Period</b>	<b>= 2 Years</b>
<b>Life of Distribution Transformer</b>	<b>= 25 Years</b>
<b>Total savings for Life</b>	<b>= 120 Lacs</b>

# Maintenance of Transformer

## Maintenance Schedule (Hourly)

- Ambient Temperature
- Winding Temperature
- Oil Temperature
- Loading in kVA, Amperes
- Voltage Level ( HV /LV)

# Maintenance of Transformer



# Maintenance of Transformer

## Maintenance Schedule (Daily)

- Oil Level in Transformer
  - ✓ Bushings
  - ✓ OLTC
  - ✓ Conservator
- Condition of Breather
- Diaphragm of Explosion Vent
- Cooling fan status

# Maintenance of Transformer

## Maintenance Schedule (Quarterly)

- Oil Dielectric Strength (>40 kV)
  - ✓ BDV
  - ✓ Water Content
- Condition of Bushings
- Dehydration of Oil if required

# Maintenance of Transformer

## Maintenance Schedule (Half Yearly)

- Oil Dielectric Strength (>40 kV)
  - ✓ BDV
  - ✓ Water Content
- DGA Test (Dissolved Gas Analysis)
- OLTC Operation checking
- Dehydration of Oil if required

# Maintenance of Transformer

## Maintenance Schedule (Yearly)

- Oil Dielectric Strength (>40 kV)
  - ✓ BDV
  - ✓ Water Content
  - ✓ DGA Test (Dissolved Gas Analysis)
- OLTC Operation checking
- Condition of Bushings
- Dehydration of Oil

# Maintenance of Transformer


## Maintenance Schedule (Yearly)

- Checking of all Nut & Bolts
- Gasket Joints
- Cable/Bus bar Boxes
- Relay/alarm Circuits
- Painting
- Sludge Checking
- Wash Core with Oil if sludge is more




# Analogy

Power factor =  $\frac{\text{kW}}{\text{kVA}} = \frac{\text{kW}}{\text{kW} + \text{kVAr}} = \frac{\text{Beer}}{\text{Beer} + \text{Foam}}$




# PF COMPENSATION

## Centralized compensation




# PF COMPENSATION

## Distributed Compensation



# PF COMPENSATION

## Mixed Compensation



# Electricity Tariff Details

# Punjab State Revised

## Punjab State is having Single Discom

- Punjab State Power Corporation Limited  
**Billing is in kVAh**

<b>Billing Structure</b>		<b>Fixed Charges (₹)</b>	<b>Energy Charges (₹)</b>
<b>General Industry</b>	Above 100 kVA & upto 1000 kVA	140/kVA	5.70/kVAh
	Above 100 kVA & upto 2500 kVA	195/kVA	5.74/kVAh
	Above 2500 KVA	230/kVA	5.78/kVAh
<b>PIU / ARC Furnace</b>	Above 100 kVA & upto 1000 kVA	160/kVA	5.74/kVAh
	Above 1000 KVA	295/kVA	5.98/kVAh
<b>Bulk Supply</b>	LT	155/kVA	6.25/kVAh
	HT	195/kVA	5.85/kVAh

# Punjab State Revised

## Voltage Rebate

- Rebate of 30 paise/kVAh to all consumers getting supply at 400/220/132 kV, 25 paise/kVAh to all consumers getting supply at 66/33 kV, 20 paise/kVAh to DS, NRS & MS consumers getting supply at 11 kV

# Bill Analysis

## Present System

- Bill analysis done in detail
- Power factor, MDI, Energy consumption, studied in detail
- Present Billing is in kVAh
- Present CD – 400 kVA



# Bill Analysis Power Factor

Month	Energy Consumption kVAh	Energy Consumption kWh	Power Factor	Energy charges in Rs.	Monthly E Bill Rs.	P.F Unit Cost Rs.
Jan-17	123268	116184	0.943	706746	846760	5.7
Feb-17	110308	104639	0.949	635074	760890	5.8
Mar-17	118743	111194	0.936	678301	812730	5.7
Apr-17	141689	131209	0.926	812238	939330	5.7
May-17	145736	134312	0.922	834454	1011619	5.7
Jun-17	166454	152546	0.916	956093	1162370	5.7
Jul-17	145121	133649	0.921	922256	1116900	6.4
Aug-17	158618	143177	0.903	1004051	1206280	6.3
Sep-17	173950	154323	0.887	1099847	1349100	6.3
Oct-17	183444	158524	0.864	1165479	1436280	6.4
Nov-17	185735	163825	0.882	1069120	1310929	5.8
Dec-17	160515	146277	0.911	990189	1199910	6.2
	1813581	1649859	0.913	10873848	13153098	6.0


# Bill Analysis

Month	Contract Demand in kVA	Actual Demand in kVA	Fine Demand charges in RS	Rs/kVA	Monthly Bill	unit Cost
Jan-17	400	321		0	846760	6.87
Feb-17	400	351		0	760890	6.90
Mar-17	400	364		0	812730	6.84
Apr-17	400	394		0	939330	6.63
May-17	400	405.36	4020	750	1011619	6.94
Jun-17	400	422.76	17070	750	1162370	6.98
Jul-17	400	418.2	13650	750	1116900	7.70
Aug-17	400	428.04	21030	750	1206280	7.60
Sep-17	400	467.76	50820	750	1349100	7.76
Oct-17	400	480.73	60540	750	1436280	7.83
Nov-17	400	465.1	48840	750	1310929	7.06
Dec-17	400	441.36	31020	750	1199910	7.48
			246990		13153098	7.22

# Analysis of Electrical Parameters on Main Incoming

Active, Reactive Power & Power Factor Trend at Main Incoming

Active Power    Reactive Power    Power Factor



# Capacitor Bank

Capacitor Bank Health Check-up						
Name	Rated kVAR	Actual kVAr	Measured Current in Amperes			Measured kVAr
	440 Volts	396 kVAr	R	Y	B	
1	25	21.7	31.1	30.5	31.4	21.51
2	25	21.7	30.7	31.5	31.3	21.62
3	10	8.7	0.8	4.5	0.0	1.23
4	20	17.4	24.1	25.2	24.7	17.11
5	20	17.4	24.5	25.4	24.2	17.13
6	25	21.7	31.3	31.3	30.3	21.48
7	10	8.7	0.0	0.0	0.0	0.00
8	25	21.7	31.7	24.1	23.6	18.36
9	25	21.7	54.5	23.1	30.7	-

# Improve Overall Power factor of Plant

## Concern Point

- No APFC panel is Installed
- Capacitors are manually connected
- No Control on reactive power supply
- Connected Capacitors are not sufficient to maintain unity power factor

# Improve Overall Power factor of Plant

## Action Plan

- Install new APFC of 400 kVAr
- isolate Manual Capacitors
- Maintain Unity Power Factor at SEB Meter
- Install MDI Controller and maintain MDI at 395 kVA
- Shut of Non critical load if MDI crosses 395 kVA

# Saving Potential

Month	Energy Consumption kVAh	Energy Consumption kWh	Power Factor	Energy charges	Monthly Bill	P.F Unit Cost	Saving Potential
Jan-17	123268	116184	0.943	706746	846760	5.7	40615
Feb-17	110308	104639	0.949	635074	760890	5.8	32638
Mar-17	118743	111194	0.936	678301	812730	5.7	43122
Apr-17	141689	131209	0.926	812238	939330	5.7	60077
May-17	145736	134312	0.922	834454	1011619	5.7	65411
Jun-17	166454	152546	0.916	956093	1162370	5.7	79886
Jul-17	145121	133649	0.921	922256	1116900	6.4	72906
Aug-17	158618	143177	0.903	1004051	1206280	6.3	97741
Sep-17	173950	154323	0.887	1099847	1349100	6.3	124097
Oct-17	183444	158524	0.864	1165479	1436280	6.4	158325
Nov-17	185735	163825	0.882	1069120	1310929	5.8	126117
Dec-17	160515	146277	0.911	990189	1199910	6.2	87832
	1813581	1649859	0.9133	10873848	13153098	6.0	9.89

# Improve Overall Power factor of Plant

<b>Annual Savings</b>	<b>- Rs 12.35 Lakhs</b>
<b>Investment</b>	<b>- Rs 4.0 Lakhs</b>
<b>Payback</b>	<b>- 4 Months</b>



# Capacitor Selection

- ❑ **Chart Method**

- ❑ **Formula Method**

- **Capacitor required (KVAR)**

$$= \text{kW} \times \{ \text{Tan } \cos^{-1}\Phi_1 - \text{Tan } \cos^{-1}\Phi_2 \}$$

- **Cos  $\Phi_1$  – Present power factor**

- **Cos  $\Phi_2$  – Desired power factor**

**TABLE 1.2 MULTIPLIERS TO DETERMINE CAPACITOR kVAR REQUIREMENTS FOR POWER FACTOR CORRECTION**

Original Power Factor	Desired Power Factor																				
	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.89	0.90	0.91	0.92	0.93	0.94	0.95	0.96	0.97	0.98	0.99	1.0
0.50	0.982	1.008	1.034	1.060	1.086	1.112	1.139	1.165	1.192	1.220	1.248	1.276	1.306	1.337	1.369	1.403	1.440	1.481	1.529	1.589	1.732
0.51	0.937	0.962	0.989	1.015	1.041	1.067	1.094	1.120	1.147	1.175	1.203	1.231	1.261	1.292	1.324	1.358	1.395	1.436	1.484	1.544	1.687
0.52	0.893	0.919	0.945	0.971	0.997	1.023	1.050	1.076	1.103	1.131	1.159	1.187	1.217	1.248	1.280	1.314	1.351	1.392	1.440	1.500	1.643
0.53	0.850	0.876	0.902	0.928	0.954	0.980	1.007	1.033	1.060	1.088	1.116	1.144	1.174	1.205	1.237	1.271	1.308	1.349	1.397	1.457	1.600
0.54	0.809	0.835	0.861	0.887	0.913	0.939	0.966	0.992	1.019	1.047	1.075	1.103	1.133	1.164	1.196	1.230	1.267	1.308	1.356	1.416	1.559
0.55	0.769	0.795	0.821	0.847	0.873	0.899	0.926	0.952	0.979	1.007	1.035	1.063	1.093	1.124	1.156	1.190	1.227	1.268	1.316	1.376	1.519
0.56	0.730	0.756	0.782	0.808	0.834	0.860	0.887	0.913	0.940	0.968	0.996	1.024	1.054	1.085	1.117	1.151	1.188	1.229	1.277	1.337	1.480
0.57	0.692	0.718	0.744	0.770	0.796	0.822	0.849	0.875	0.902	0.930	0.958	0.986	1.016	1.047	1.079	1.113	1.150	1.191	1.239	1.299	1.442
0.58	0.655	0.681	0.707	0.733	0.759	0.785	0.812	0.838	0.865	0.893	0.921	0.949	0.979	1.010	1.042	1.076	1.113	1.154	1.202	1.262	1.405
0.59	0.619	0.645	0.671	0.697	0.723	0.749	0.776	0.802	0.829	0.857	0.885	0.913	0.943	0.974	1.006	1.040	1.077	1.118	1.166	1.226	1.369
0.60	0.583	0.609	0.635	0.661	0.687	0.713	0.740	0.766	0.793	0.821	0.849	0.877	0.907	0.938	0.970	1.004	1.041	1.082	1.130	1.190	1.333
0.61	0.549	0.575	0.601	0.627	0.653	0.679	0.706	0.732	0.759	0.787	0.815	0.843	0.873	0.904	0.936	0.970	1.007	1.048	1.096	1.156	1.299
0.62	0.516	0.542	0.568	0.594	0.620	0.646	0.673	0.699	0.726	0.754	0.782	0.810	0.840	0.871	0.903	0.937	0.974	1.015	1.063	1.123	1.266
0.63	0.483	0.509	0.535	0.561	0.587	0.613	0.640	0.666	0.693	0.721	0.749	0.777	0.807	0.838	0.870	0.904	0.941	0.982	1.030	1.090	1.233
0.64	0.451	0.474	0.503	0.529	0.555	0.581	0.608	0.634	0.661	0.689	0.717	0.745	0.775	0.806	0.838	0.872	0.909	0.950	0.998	1.068	1.201
0.65	0.419	0.445	0.471	0.497	0.523	0.549	0.576	0.602	0.629	0.657	0.685	0.713	0.743	0.774	0.806	0.840	0.877	0.918	0.966	1.026	1.169
0.66	0.388	0.414	0.440	0.466	0.492	0.518	0.545	0.571	0.598	0.626	0.654	0.682	0.712	0.743	0.775	0.809	0.846	0.887	0.935	0.995	1.138
0.67	0.358	0.384	0.410	0.436	0.462	0.488	0.515	0.541	0.568	0.596	0.624	0.652	0.682	0.713	0.745	0.779	0.816	0.857	0.905	0.965	1.108
0.68	0.328	0.354	0.380	0.406	0.432	0.458	0.485	0.511	0.538	0.566	0.594	0.622	0.652	0.683	0.715	0.749	0.786	0.827	0.875	0.935	1.078
0.69	0.299	0.325	0.351	0.377	0.403	0.429	0.456	0.482	0.509	0.537	0.565	0.593	0.623	0.654	0.686	0.720	0.757	0.798	0.846	0.906	1.049
0.70	0.270	0.296	0.322	0.348	0.374	0.400	0.427	0.453	0.480	0.508	0.536	0.564	0.594	0.625	0.657	0.691	0.728	0.769	0.817	0.877	1.020
0.71	0.242	0.268	0.294	0.320	0.346	0.372	0.399	0.425	0.452	0.480	0.508	0.536	0.566	0.597	0.629	0.663	0.700	0.741	0.789	0.849	0.992
0.72	0.214	0.240	0.266	0.292	0.318	0.344	0.371	0.397	0.424	0.452	0.480	0.508	0.538	0.569	0.601	0.635	0.672	0.713	0.761	0.821	0.964
0.73	0.186	0.212	0.238	0.264	0.290	0.316	0.343	0.369	0.396	0.424	0.452	0.480	0.510	0.541	0.573	0.607	0.644	0.685	0.733	0.793	0.936
0.74	0.159	0.185	0.211	0.237	0.263	0.289	0.316	0.342	0.369	0.397	0.425	0.453	0.483	0.514	0.546	0.580	0.617	0.658	0.706	0.766	0.909
0.75	0.132	0.158	0.184	0.210	0.236	0.262	0.289	0.315	0.342	0.370	0.398	0.426	0.456	0.487	0.519	0.553	0.590	0.631	0.679	0.739	0.882
0.76	0.105	0.131	0.157	0.183	0.209	0.235	0.262	0.288	0.315	0.343	0.371	0.399	0.429	0.460	0.492	0.526	0.563	0.604	0.652	0.712	0.855
0.77	0.079	0.105	0.131	0.157	0.183	0.209	0.236	0.262	0.289	0.317	0.345	0.373	0.403	0.434	0.466	0.500	0.537	0.578	0.626	0.685	0.829
0.78	0.052	0.078	0.104	0.130	0.156	0.182	0.209	0.235	0.262	0.290	0.318	0.346	0.376	0.407	0.439	0.473	0.510	0.551	0.599	0.659	0.802
0.79	0.026	0.052	0.078	0.104	0.130	0.156	0.183	0.209	0.236	0.264	0.292	0.320	0.350	0.381	0.413	0.447	0.484	0.525	0.573	0.633	0.776
0.80	0.000	0.026	0.052	0.078	0.104	0.130	0.157	0.183	0.210	0.238	0.266	0.294	0.324	0.355	0.387	0.421	0.458	0.499	0.547	0.609	0.750
0.81		0.000	0.026	0.052	0.078	0.104	0.131	0.157	0.184	0.212	0.240	0.268	0.298	0.329	0.361	0.395	0.432	0.473	0.521	0.581	0.724
0.82			0.000	0.026	0.052	0.078	0.105	0.131	0.158	0.186	0.214	0.242	0.272	0.303	0.335	0.369	0.406	0.447	0.495	0.555	0.698
0.83				0.000	0.026	0.052	0.079	0.105	0.132	0.160	0.188	0.216	0.246	0.277	0.309	0.343	0.380	0.421	0.469	0.529	0.672
0.84					0.000	0.026	0.053	0.079	0.106	0.134	0.162	0.190	0.220	0.251	0.283	0.317	0.354	0.395	0.443	0.503	0.646
0.85						0.000	0.027	0.053	0.080	0.108	0.136	0.164	0.194	0.225	0.257	0.291	0.328	0.369	0.417	0.477	0.620
0.86							0.000	0.026	0.053	0.081	0.109	0.137	0.167	0.198	0.230	0.264	0.301	0.342	0.390	0.450	0.593
0.87								0.000	0.027	0.055	0.083	0.111	0.141	0.172	0.204	0.238	0.275	0.316	0.364	0.424	0.567
0.88									0.000	0.028	0.056	0.084	0.114	0.145	0.177	0.211	0.248	0.289	0.337	0.397	0.540
0.89										0.000	0.028	0.056	0.086	0.117	0.149	0.183	0.220	0.261	0.309	0.369	0.512
0.90											0.000	0.028	0.058	0.089	0.121	0.155	0.192	0.233	0.281	0.341	0.484
0.91												0.000	0.030	0.061	0.093	0.127	0.164	0.205	0.253	0.313	0.456
0.92													0.000	0.031	0.063	0.097	0.134	0.175	0.223	0.283	0.426
0.93														0.000	0.032	0.066	0.103	0.144	0.192	0.252	0.395
0.94															0.000	0.034	0.071	0.112	0.160	0.220	0.363
0.95																0.000	0.037	0.079	0.126	0.186	0.329
0.96																	0.000	0.041	0.089	0.149	0.292
0.97																		0.000	0.048	0.108	0.251
0.98																			0.000	0.060	0.203
0.99																				0.000	0.143
																					0.000




# Power Capacitors

- **Capacitor banks install to improve power factor**


## ***Reasons for failure***

- **Ageing**
- **Input voltage and frequency fluctuation**
- **Harmonics present in the system**
- **Temperature around the bank**
- **Poor quality capacitors use in the construction**

# Power Capacitors



# Power Capacitors




# OPTIMIZE PLANT VOLTAGE AT 415 V

- Transformer 1250 kVA and 800 kVA, with Off Load Tap Changer
- Both Transformers are installed with Servo - Stabilizers
- Voltage pattern analyzed
  - Data Logger installed on plant transformer and servo stabilizers– recordings done


# OPTIMIZE PLANT VOLTAGE AT 415 V

## Voltage Variation from SEB, Transformer 1250 kVA



# OPTIMIZE PLANT VOLTAGE AT 415 V


## Voltage Variation after Servo Stabliser 1250 kVA






# OPTIMIZE PLANT VOLTAGE AT 415 V

## Voltage Variation from SEB, Transformer 800 kVA



# OPTIMIZE PLANT VOLTAGE AT 415 V

## Voltage Variation after Servo Stabiliser 800 kVA



# OPTIMIZE PLANT VOLTAGE AT 415 V

- All motors are rated for 415 V, with a  $\pm 10\%$  tolerance
- Voltage fluctuations very high – threat to the operation / life of the plant equipments -
- Plant motors also loaded between 40 – 70 %
- Except Dust Collectors, Compressors

# OPTIMIZE PLANT VOLTAGE AT 415 V

- 1250 kVA Servo Stabiliser is not working, giving same output as input
- 800 kVA voltage setting at very high 430 volts
- Some Cable sizes and bus bars sizes are under sized
- Voltage drop 5-6 volts from transformer to panel

# OPTIMIZE PLANT VOLTAGE AT 415 V


- Annual Bill – 4.5 crores
- Present Voltage level – 390 - 450 V
- Recommend to optimize the voltage to 410 V.
- Annual Savings : @ 1% : 4.5 lakhs

**Already implemented during the audit in EOU section**

# OPTIMIZE PLANT VOLTAGE AT 415 V

<b>Annual Saving</b>	<b>- Rs 4.50 Lakhs</b>
<b>Investment</b>	<b>- Nil</b>

# MOTOR LOSSES



# WHY MOTORS ARE BECOMING LESS EFFICIENT

1

- **Over Sized / Under loaded Motors**

2

- **Improper Supply Voltage**

3

- **Use of Less Efficient Motors**

4


- **Poor Power Factor**

5


- **Rewinding of Motors**



# STAR AND DELTA CONNECTION





Delta connection




Star connection

# MOTOR LOSSES



# MOTOR EFFICIENCY CLASS




# MOTOR REWINDING

- Bearing failure
  - Rotor scratches stator
  - Air gap becomes uneven
    - Net torque developed is low
    - Causes drop in efficiency
  - Maximum 5 times motor can undergo rewinding – normal failure




# PERMANENT MAGNET SYNCHRONOUS MOTOR




# PERMANENT MAGNET SYNCHRONOUS MOTOR

S.No.	Permanent Magnet Synchronous Motors (self starting)					Savings using IE4 PMSM over IE2	
	Frame	kW	Pole	BBL IE4 PMSM Eff %	BBL IE2 Eff %	Energy (kWh) saving/year based on 6000 Hrs running	Rs. Saving/year based on power rate Rs.9 per kWh
1	112M	2.2	4	89.5	84.3	910	8188
2	112M	3.0	4	90.4	85.5	1141	10270
3	112M	3.7	4	90.9	86.3	1302	11716
4	132S	3.7	4	90.9	86.3	1302	11716
5	132S	5.5	4	91.9	87.7	1720	15477
6	132M	7.5	4	92.6	88.7	2137	19230
7	160M	11.0	4	93.3	89.8	2757	24814
8	160L	15.0	4	93.9	90.6	3491	31420
9	180M	18.5	4	94.2	91.2	3876	34885
10	180L	22.0	4	94.5	91.6	4422	39800

# Replace Belt driven Fume Extractor with Direct Driven System



# Replace Belt driven Fume Extractor with Direct Driven System





# Replace Belt driven Fume Extractor with Direct Driven System

## Belt driven mechanism

- Inefficient method
- loss of 7-8% of total operational power
- Motor can be directly coupled to fan to avoid transmission losses

## Action Plan

- Couple motor directly with blower
- Save the transmission losses

# Replace Belt driven Fume Extractor with Direct Driven System



**Direct Driven System**

# Replace Belt driven Fume Extractor with Direct Driven System



# Replace Belt driven Fume Extractor with Direct Driven System

	Name	Measured kW
CPPR Chrome	Fume Extractor Blower Parkerising	3
	ACP-2 Fume Extractor	9.7
	ACP-3 Fume Extractor	8.9
	ACP-4 Fume Extractor	13.09
	ACP-1 Fume Extractor	3.9
	ID Plant Blower	9.2
	Flue Extractor-EV Plating	6.68
C2D1	Fume Extractor C2D1-1	3.6
	Fume Extractor C2D1 -2	2.9
Total		60.97 kW

# Replace Belt driven Fume Extractor with Direct Driven System

Saving = 5 % x 60.97 kW x 24 hrs/day x 305 Days x 8.14 Rs/kWh

<b>Annual Saving</b>	<b>- Rs 1.87 Lakhs</b>
<b>Investment</b>	<b>- Rs 1.00 Lakhs</b>
<b>Simple Payback</b>	<b>- 7 Months</b>

# Cables



# Types of Cables

## Types

- **High Voltage (Voltage > 1.1 kV)**
- **Low Voltage (Voltage < 1.1 kV)**
  - ✓ **Control**
  - ✓ **Instrumentation (Shielded)**
  - ✓ **Data Cable ( Profibus /Lan /Modbus /Fiber/Optics)**

# Losses in Cables

## Un-avoidable Losses

- **Copper Losses**  
 **$I^2R$  (Load losses)**
- **Voltage Drop**
- **Induction Losses**
- **Capacitance Losses**

## Avoidable Losses

- **Jointing Losses (Heating/Thimble Burning)**
- **Bus Bar Connection**
- **Thimble losses**
- **Material change (Copper to Aluminum)**



# De rating factors

Derating factors for ambient air temperatures other than 30°C.

°C	Ambient Temperature Derating Factor	
	PVC	EPR / XLPE
10	1.22	1.15
15	1.17	1.12
20	1.12	1.08
25	1.06	1.04
30	1	1
35	0.94	0.96
40	0.87	0.91
45	0.79	0.87
50	0.71	0.82
55	0.61	0.76
60	0.5	0.71
65	-	0.65

Derating factors for soil temperatures other than 20°C.

°C	Soil Temperature Derating Factor	
	PVC	EPR / XLPE
10	1.1	1.07
15	1.05	1.04
20	1	1
25	0.95	0.96
30	0.89	0.93
35	0.84	0.89
40	0.77	0.85
45	0.71	0.8
50	0.63	0.76
55	0.55	0.71
60	0.45	0.65
65	-	0.6


# Losses in Cables due to over heating




Ken Brinkman

- **Proper tightening of cable is very significant**

# Losses in Cables due to over heating



# Losses due to Wrong Cable Termination



➤ **Use Right type of thimble at Right place**

# Losses in Cables

## Case Study - 1

- **Cable Type** - **3.5 Core 185 mm<sup>2</sup> Al.**
- **Resistance** - **0.164 ohm/kM**
- **Current Capacity** - **280 Amperes**
- **Losses I<sup>2</sup>R** - **280 x 280 x 0.164/1000**  
**kW/kM**
- **Losses / kM** - **12.86 kW**
- **Cost / Meter** - **Rs. 470/-**

# Losses in Cables

## Case Study - 1

- **Cable Type** - **3.5 Core 240 mm<sup>2</sup> Al.**
- **Resistance** - **0.125 ohm/kM**
- **Current Capacity** - **330 Amperes**
- **Losses I<sup>2</sup>R** - **330 x 330 x 0.125/1000**  
**kW/kM**
- **Losses / kM** - **13.61 kW**
- **Cost / Meter** - **Rs. 600/-**

# Losses in Cables

## Case Study - 1

- **Cable Type** - **3.5 Core 240 mm<sup>2</sup> Al.**
- **Resistance** - **0.125 ohm/kM**
- **Current Capacity** - **330 Amperes**
- **Actual Load** - **280 Amperes**
- **Losses I<sup>2</sup>R** - **280 x 280 x 0.125 / 1000**  
**kW/kM**
- **Losses / kM** - **9.8 kW**

# Losses in Cables

## Case Study - 1

- **Difference** - **3.8 kW**
- **Running hours** - **8000 /Annum**
- **Cost** - **Rs. 8/Unit**
- **Saving** - **2.43 Lakhs/Annum**
- **Additional Investment** - **1.3 Lakhs**



# Losses in Cables

- **Selection of Cable is very important**
- **Right selection can cost you more in project stage but cheaper in longer run**
- **Periodic health check is very important**
- **Thermal Imaging , loading on cables etc. needs to be checked regularly**

# Stop idle operation of equipment's during lunch/Dinner and tea breaks

## Presently

- Idle operation of equipment's during lunch hours
- Fans, tube lights, CFL, exhaust fans, conveyor and some machines were operational
- Idle operation is pure wastage of energy

# Stop idle operation of equipment's during lunch/Dinner and tea breaks



# Stop idle operation of equipment's during lunch/Dinner and tea breaks



# Stop idle operation of equipment's during lunch/Dinner and tea breaks



# Electrical Panels



# Electrical Panels

## Major Components of Electrical Panels

- Air Circuit Breakers (ACB)
- Moulded Case Circuit Breaker (MCCB)
- Switch Fuse Unit (SFU)
- Miniature Circuit Breaker (MCB)
- Bus Bars, Wiring & accessories

# Electrical Panels


## LOSSES IN THE PANELS

- Losses in Switch gears
- Losses in Wiring
- Losses in Bus Bars
- Losses in Indicators
- Losses in meters, Instrument Transformers
- Losses in Capacitors




# Electrical System

## Main MCCB incomer





# Electrical System

## L.T ROOM RO Plant Main MCCB



# Thermal Imaging



Air Circuit Breaker


© Confederation of Indian Industry




# Losses due to overheating in Bus Bars




# Losses due to overheating in Bus Bars




# Losses due to overheating in Bus Bars



# Losses due to overheating in Bus Bars



# EARTHING / GROUNDING







# Introduction


## Earthing – Definition

- In electrical engineering, ground or earth is the reference point in an electrical circuit from which other voltages are measured, or is a common return path for electric current, or a direct physical connection to the Earth.

# Electrical Hazards




# Example



# Wrong Practices in Plant

## Earthing Wire Connected to Wrong Place





# Wrong Practices in Plant

## Lot of Joints in Earthing Strips



# Good Practices in Plant



# General Observations

- Earthing Plays Very important role in Plant Performance
- Schedule Testing of All earth Pits
- Earth pit should be isolate before testing
- Schedule maintenance of Earthing Pits
- Earth grids are not connected to each other
- All earth Pits should be connected to common grid
- GI/SS nut bolts should be used for connections
- Use Chemical earth pits

# Observations Safety Mats

- Safety Mats should be as per new standard
- Rubber Mats old IS : 5424 /69
- New IS standard for Safety Mats  
IS:15652:2006
- New International Standard IEC 61111



# To Sum up...

- Maintenance plays major role in keeping up the electrical system 24 x 7
- We can save lot of losses by maintaining the system well
- Electrical system failure create a lot of production and profitability loss

# Thank you

[Manpreet.singh@cii.in](mailto:Manpreet.singh@cii.in)

**09876724003**



Confederation of Indian Industry

# Welcome to

## 1<sup>st</sup> WORKSHOP

### CAPACITY BUILDING OF LSPs UNDER

### GEF-UNIDO-BEE PROJECT

# "PROMOTING ENERGY EFFICIENCY AND RENEWABLE ENERGY IN SELECTED MSME CLUSTERS IN INDIA"

**11 May 2018**

**Nagaur**



## **CII Energy Management Services**



**Khalid Khan**  
**Associate Counsellor – Energy Services**  
**Accredited Energy Auditor**  
**Confederation of Indian Industry**

**CII – Centre of Excellence for Competitiveness for SMEs**

# CII Energy Audit & Management

## ❖ CII Energy Services:

- ➔ **CII – Godrej Green Business Centre, Hyderabad**
- ➔ **CII – Centre of Excellence for Competitiveness, Chandigarh for SMEs**
- ➔ **CII – EMC, Chennai**
- ➔ **CII – EMC, Ahmadabad**
- ➔ **More than 100 experts involved in energy services**
- ➔ **Team of Accredited & Certified Energy Auditors**

# CI I Energy Audit & Management

## ❖ Energy Services

- ➔ Detailed Energy Audit
- ➔ Training Programs on Energy
- ➔ Developing road map/benchmarking on Energy Consumption
- ➔ Missions/workshops/seminars on energy
- ➔ Audited more than 1500 units

# CI I Energy Audit & Management

## ❖ Major Initiatives & Projects

- ➔ **World Class Energy Efficiency in Power Plant**
- ➔ **World Class Energy Efficiency in Sugar, Paper & Cement Sectors**
- ➔ **IREDA Project for Energy Efficiency in Textile sector**
- ➔ **Energy Audit of major DCs sector under PAT Scheme**
- ➔ **BEE – SME program for Energy Efficiency in SME sectors**
- ➔ **BEE – GEF – WB Faridabad Cluster**
- ➔ **Developed Manual on Energy Efficiency at Design Stage**

# Energy Audit

## ❖ An energy audit –

➔ is an inspection, measurement survey and analysis of energy flows for energy conservation in an industry, building, process or system

➔ to reduce the amount of energy input into the system without negatively affecting the output








# List of Instruments used during Audit

- Ultrasonic Flow Meter
- Power Analysers 3 Phase & 1 Phase
- Digital Pressure Gauges
- Thermal Imager
- Vane type anemometer
- IR Temperature Gun
- Lux meter
- Hygrometer


# Installation of Power Meter



# Equipment load pattern




# Installation of Flow Meter



# Installation of Flue gas analyser



# Process Flow Diagram




# Energy Audit - Benefits

## ❖ Tangible Benefits

- Reduction in energy consumption
- Better control over quality
- Savings in raw material consumption
- Better equipment life
- Reduced GHG emissions


## ❖ Intangible Benefits

- Plant expansion – designing of parameters
- Energy Efficient equipment purchase
- Alternate fuel/energy sources options
- Identification & feasible recommendation for critical issues



# Energy Conservation at Macro Level

Measure of  
encon activities




Reduction in specific  
energy and Water  
consumption



# Energy Conservation at Macro Level ...

**Capacity utilisation**

**Three-  
pronged  
approach**




**Fine-tuning**

**Technology  
upgradation**

# Macro Level - Methodology

Any process/unit operation


Unavoidable losses



# Losses – Avoidable Vs Unavoidable

- Pumps - Valve throttling control or Re-circulation
- Air Compressor leakage
- Compressed air generation pressure
- Furnace – Radiation losses
- Boiler – Flue gas losses
- Over designed equipments – Air Compressors, Fans & Blowers etc
- Condenser cooling water losses in Chillers etc

# Macro Level - Methodology ...



**Focus  
should be**

- **To concentrate on avoidable losses**
- **Quantify the losses**
- **Identify ways and means for reduction**
- **Implementation**

# Macro Level - Methodology

## Losses – Two ways of representing

- **There is compressed air leakage from 6 mm pipe in the plant**
- **Pump is operating at 40% valve throttling**
- **ID/FD fan being controlled by closing the damper**
- **Motor is under loaded**
- **Boiler flue gas temperature is 40 deg higher than recommended**
- **Specific Energy Consumption of Chiller is 0.15 kW/TR higher**

# Macro Level - Methodology


## Losses – Two ways of representing

- There is compressed air leakage from 6 mm pipe in the plant which is costing Rs. 6.0 Lakhs/annum
- Pump is operating at 40% valve throttling – Consuming 40% extra power
- Blower flow is being controlled by closing the damper – consuming 5 kW more than requirement
- Motor is under loaded – potential to save Rs. 1.0 Lakhs/annum
- Boiler flue gas temperature is 40 deg higher than recommended - Costing around 2% extra fuel
- Specific Energy Consumption of Chiller is 0.70 kW /TR which is 0.15 kW/TR higher than the rated and costs Rs. 30 Lakhs/Annum for 300 TR Chiller

# Macro Level - Methodology

**Identify ways and means for reduction -**

- **There can be 3 – 4 means of reduction**
- **Over designed pump -**
  - **Replacing with correct size**
  - **Impeller trimming**
  - **Speed control**
  - **Two pump system**
- **Decision depends on many factor – like cost, reliability, process etc**



# Coverage

## Thermal/Mechanical/Electrical

**Boiler and Steam System**

**Ovens**

**HVAC System**

**Air compressors System**

**Leakage and Capacity Test**

**Cooling Towers**

**Major Motors**

**Thermal Imaging**

**Mixers and Grinders**

**Process Equipments**

**Electrical distribution System**

**Bill Analysis**

**Harmonics Study**

**Power Factor Improvement**

**Capacitors Health Checkup**

**Electrical Safety & Cables**

**Lighting**

**Fans & Blowers (AWU & AHU)**

**All Major Pumps**


**Dust Collectors**



# Three Pronged Approach

**Simple Projects  
( < 6 months payback )**

**Detailed  
Energy  
Audit**



**Medium term  
(6-18 months payback)**

**Long term  
(18-30 months payback)**

# Why energy saving?


There have always been good reasons for energy saving

- CO2 reductions
- Environmental pollution
- Reduced operation costs

Two reasons force the market to act

- Legislation – worldwide and local
- Increasing energy costs

# Commercial Energy Consumption Pattern in India



# Energy conservation potential from various industries

	<b>% Share of Energy Cost</b>	<b>Conservation Potential (%)</b>
<b>Iron and Steel</b>	<b>15.8</b>	<b>8-10</b>
<b>Fertilisers &amp; Pesticides</b>	<b>18.3</b>	<b>10-15</b>
<b>Textile</b>	<b>10.9</b>	<b>20-25</b>
<b>Cement</b>	<b>34.9</b>	<b>10-15</b>
<b>Chlor-alkali</b>	<b>15.0</b>	<b>10-15</b>
<b>Pulp and Paper</b>	<b>22.8</b>	<b>20-25</b>
<b>Aluminium</b>	<b>34.2</b>	<b>8-10</b>
<b>Ferrous Foundry</b>	<b>10.5</b>	<b>15-20</b>
<b>Petrochemical</b>	<b>12.7</b>	<b>10-15</b>
<b>Ceramics</b>	<b>33.7</b>	<b>15-20</b>
<b>Glass</b>	<b>32.5</b>	<b>15-20</b>
<b>Refineries</b>	<b>1.0</b>	<b>8-10</b>
<b>Ferro-Alloys</b>	<b>36.5</b>	<b>8-10</b>
<b>Sugar</b>	<b>3.4</b>	<b>25-30</b>



# Energy Saving Opportunities

- ❖ **Industrial sector consumes about half of the total energy generation**
- ❖ **Energy can be saved up to 5 – 30 %**
  - **5 – 10 % of energy saving by following best operating practices**
  - **10 – 30 % of energy saving achieved by using energy efficient systems**

# Summary of Audits-2016

S. No	Project name	Total Energy Bill (Rs. Lakhs)	Total Savings (Rs. Lakhs)	Average Cost Saving
1	Shri Ram Pistons & Rings Ltd Ghaziabad	9946	1465	15%
2	Rockman Industries Ltd, Ludhiana	1284	196	15%
3	Indeutsch Industries Pvt,Ltd Brush Division	168	46	27%
4	Orient Bell Limited	1857	384	21%
5	Virola Agra	135	40	30%
6	Honda Cars Ltd Tapukara	1868	247	13%
7	Sun Pharma Toansa	2207	464	21%
8	Dileep Industries	27	6	21%
9	Indeutsch Industries Pvt Ltd	141	28	20%
10	SRF Ltd	114	41	36%
11	Anmol Bakers	1117	217	19%
12	DSM	1103	231	21%

# Summary of Audits-2016

S. No.	Project name	Total Energy Bill (Rs. Lakhs)	Total Savings (Rs. Lakhs)	Average Cost Saving
13	Samsonite	325	83	25%
14	Snam Alloys (Unit I) & (Unit II)	2428	205	8%
15	Snam Alloys, Pakala Mandal	5848	275	5%
16	Hotel Vibe by Lalit	117	15	13%
17	Star Mall	563	42	7%
18	Federal Mogul	6000	627	10%
19	Tasty Dairy	346	52	15%
20	Oswal Castings	686	82	12%
21	Lumax DK Auto Industries	367	115	31%
22	Somany Ceramics Pvt Ltd	6145	430	7%
23	Abhishri Packaging	365	105	29%
24	FMI Limited	405	96	24%
25	Godrej & Boyce Manufacturing Company Ltd	103	23	22%
	Total	43664	5514	13%
	Average			19%

# Summary of Audits-2017


S. No	Project name	Total Energy Bill (Rs. Lakhs)	Total Savings (Rs. Lakhs)	Average Cost Saving
1	Tiwana Oil Mills, Sirhind	313	85	27%
2	Mayur Leather Jaipur Plant-1	25	7	28%
3	Mayur Leather Jaipur Plant-2	29	7.25	25%
4	Federal Mogul Bhiwadi	353	139.32	39%
5	Hindustan Zinc Rampura Agucha	22326	679	3%
6	Uniproducts Rewari	1015	190.4	19%
7	Colgate Palmolive Sricity	643	196.21	31%
8	Cadbury Malanpur	1909	261.94	14%
9	IGEA Chandigarh	7027	1749.12	25%
10	TDI Kundli	796	110.24	14%
11	Piramal Glass, Gujarat	19810	390.9	2%
12	Baba Farid Institutions Bathinda	63	11.76	19%
13	Automat Industries	104	17.3	17%
14	Federal Mogul Parwanoo	604	243.6	40%



# Summary of Audits-2017

S. No	Project name	Total Energy Bill (Rs. Lakhs)	Total Savings (Rs. Lakhs)	Average Cost Saving
15	IGEA Hoshiarpur	272	108.4	40%
16	Frick India Pvt Ltd Faridabad	357	53.1	15%
17	DEA Quardlife Sciences	208	42.59	20%
18	Mayur Uniquoters Jaipur-1	765	73.1	10%
19	Mayur Uniquoters Jaipur-2	919	88.12	10%
20	Anmol Steel, Kolkata	346	61.2	18%
21	NBC Newai	582	82.92	14%
22	NBC Manesar	347	94.5	27%
23	NBC Jaipur	8449	361.5	4%
24	NBC Vadodra	1060	130.63	12%
25	Minda Security Pune	155	24.9	16%
26	Lumax, Dharuhera	1455	296	20%
	Total	69932	5506	8%
	Average			20%

# ✓ 3 Major Factors



# Equipment & Cost of Operation

## Air Compressor

- ❖ **90 kW & 45 kW compressors in operation**
- ❖ **Present power consumption – 87 kW & 54 kW on loading**
- ❖ **Total power = 141 kW**
- ❖ **Running hrs = 24 hrs, 320 days/yr = 7680 hrs/yr, power cost Rs. 7.7/unit**

# Equipment & Cost of Operation

## Cost Air Compressor Operation

- ❖ **Cost of operation**
- ❖ **Energy Cost in 1 yr** - **Rs. 83.38 Lakhs**
- ❖ **Energy Cost in 10 yrs** - **Rs. 833.8 Lakhs**
- ❖ **Initial cost** - **Rs. 15.0 + 5.0 Lakhs**
- ❖ **Life of Comp** - **10 yrs**
- ❖ **Maintenance cost** - **Rs. 1.0 Lakh/yr**

# Equipment & Cost of Operation

## Life cycle cost of Dust collector blower

- ❖ **Total blower power** - **40 kW**
- ❖ **Initial cost** - **Rs. 3.5 Lakhs**
- ❖ **Life of Blower** - **10 yrs**
- ❖ **Maintenance cost** - **Rs. 0.5 Lakh/yr**
- ❖ **Energy Cost in 1 yr** - **Rs. 23.0 Lakhs**
- ❖ **Energy Cost in 10 yr** - **Rs. 230.0 Lakhs**


# Equipment & Cost of Operation

## Life cycle cost of Induction Furnace 1 T

- ❖ **Total power** - @ 600 units/T
- ❖ **Initial cost** - 60 Lakhs
- ❖ **Life of Furnace** - 10 yrs
- ❖ **Maintenance cost** - Rs. 5.0 Lakhs/yr
- ❖ **Energy Cost in 1 yr** - Rs. 280.0 Lakhs
- ❖ **Energy Cost in 10 yr** - Rs. 2800.0 Lakhs

# I. Energy & Life cycle cost of an equipment

- ❖ **Energy Cost in 10 yrs- Rs. 833.8 Lakhs**
- ❖ **Initial cost - Rs. 30.0 Lakhs**
- ❖ **Life of Comp - 10 yrs**
- ❖ **Maintenance cost - Rs. 10 Lakh/yr**



## II. Equipment Efficiency & System Efficiency

Energy efficient system is the combination of best and most efficient components –

- system efficiency can be defined at different system levels



# Energy Efficiency of Compressed Air System:

$$\eta_{\text{air compressor system}} = \eta_{\text{generation}} \times \eta_{\text{distribution}} \times \eta_{\text{user}}$$

$$\eta_{\text{induction furnace}} = \eta_{\text{furnace type}} \times \eta_{\text{control}} \times \eta_{\text{electrical}} \times \eta_{\text{Automation}}$$

# **System efficiency – energy efficient equipment**

***may not work efficiently in a system  
!!!!***

***Example –***

***Furnace***

***Pump***

***Compressor***

***blower***

# III. Energy Monitoring & Targeting



➔ **Measure to manage better!**

# Energy Monitoring and Targeting



## Monitoring

To account for your energy use

## Targeting

Assessing, setting & aiming for a particular consumption

- Help to eliminate waste & reduce energy use
- Provide the information required to make informed decisions
- Improve motivation
- Typical cost savings from a M&T programme are between 5-10%

# Energy Monitoring

- Application of EMT
  - Predictive maintenance
    - Monitors major variation in operating parameters of equipment / Power consumption
  - Root cause analysis
    - Helps understanding energy wastage / idle operation of equipment
  - Measurement & Verification
    - Enables to access trends in energy usage in a facility
    - Verification of benefits achieved by implementation of energy conservation measures

**Thank You**


# Furnaces

# Thermal Systems

- **Furnaces**
- **Boilers**
- **Hot Water Generators**
- **Hot Air Generators**
- **Thermic fluid System**
- **Ovens**



# Energy Audit Approach



# Parameters affecting the performance

## Operating Temperature

- Close to operational requirement
- Higher the temp. lower the efficiency & higher scale / metal loss
- For 12°C rise in temp. efficiency drops by 1% for furnace
- Every 4.8 kg/cm<sup>2</sup> drop  $\Rightarrow$  1% increase in efficiency

# Parameters affecting the performance

## Air/ Fuel Ratio

- Highly critical parameter
- Should be optimum

# **Air quantity for combustion -**


## **An important parameter for energy efficiency**

### **Exact air quantity**

 **Theoretical air requirement**

**can be estimated from  
combustion theory**

 **Excess air required**

 **Quantity of excess air  
depends on mixing capability  
of fuel**

 **Mixing capability**


**- Solid < Liquid < Gas**

 **Lesser the mixing capability**

**- more the quantity of  
excess air**

# Basic principles of combustion

**Fuel ingredients : C, H & S**



**Excess air %**

**Efficiency %**

**10**

**84.8**

**100**


**78.5**

**140**

**75.0**

**Keeping stack temperature constant**


# Effect of air quantity on efficiency



# Effect of air quantity on efficiency



# Effect of air quantity on efficiency





# Parameters affecting the performance

## Advance Energy Efficient Burners



# Typical excess air requirements and resultant level of oxygen in flue gases

<b>Coal</b>	<b>Oxygen %</b>	<b>Excess Air</b>
<b>Pulverised firing</b>	<b>4.0-5.0</b>	<b>20-30</b>
<b>Stoker firing</b>	<b>4.5-6.5</b>	<b>25-40</b>
<b>Fluidised bed combustion</b>	<b>4.0-4.5</b>	<b>20-25</b>
<b>Oil</b>	<b>1.0-3.0</b>	<b>5-15</b>
<b>Natural gas</b>	<b>1.0-2.0</b>	<b>5-10</b>
<b>Black liquor</b>	<b>1.0-2.0</b>	<b>5-10</b>

**Reduce excess air to optimal level**

# Instruments

## Portable combustion analyser

- Merits & Demerits
- Small size, multiple boilers

## On-line O<sub>2</sub> analyser

- Large boilers (say, 70 TPH)
- Location
- Whether automatic?

## On-line CO/O<sub>2</sub> analyser with O<sub>2</sub> trim control

- High capacity boiler



# Flue gas temperature

## High temperature

- Excess fuel firing
- Fouled tubes (scaling inside/outside tubes)


## Reasons for fouling

- Combustion particles deposition
- Water treatment inadequate

**Every 22°C drop ⇒ 1% efficiency increase**

# Flue gas temperature

 **Better to reduce exhaust temperature**


 **Lowest permissible exhaust temperature depends on Sulphur content in fuel**

 **For 1% Sulphur content in fuel**

- **Recommended lowest exhaust flue gas temp. is about 150°C**
- **For FO, LSHS and Coal**

**Reduce exhaust flue gas temperature to optimum levels**

# %SULFUR Vs. DEW POINT OF FLUE GAS



# Parameters affecting the performance


## Waste Heat Recovery

### When do we recover waste heat?

- when exit temperature high
- when furnace runs on a continuous basis

### Advantages of WHR

- reduction in fuel loss
- reduction in furnace heating time



# Parameters affecting the performance

## Surface Insulation- How important

✓ Adequate insulation-a must

What is the optimum surface temperature?

60 °C for thermal system

✓ Radiation Loss – Varies as fourth power of Temp

Radiation loss at 150 °C : 1500 Kcal/m<sup>2</sup>/hr

Radiation loss at 70 °C : 450 Kcal/m<sup>2</sup>/hr

Avoid the openings of furnaces to reduce radiation losses and leakages of combustion gas through openings



# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Present system

- Three fuel fired furnaces installed for melting
  - 2 Skelner Furnaces
    - 1 Ton & 1.5 Ton
  - 2 Tower Furnaces
- Furnaces are fired with Furnace Oil

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Present system

- Operating Temperature
  - No monitoring system
- Air/ Fuel Ratio
  - No FO meters for individual furnaces
  - No proper control for air/ fuel ratio
  - Damper of combustion air controlled manually
  - Poor Burner Efficiency-Fuel Burning with orange flame
- Waste Heat Recovery –
  - Recuperator of Skelner furnaces not working properly
  - Temperature of combustion air is in range of 45-50 °C of all furnaces

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Present system

### ➤ Opening losses

- Gates of furnaces have high opening, leading to high radiation losses
- High positive pressure inside the furnaces
- Hot combustion gas coming out of openings leading to energy and production loss

### ➤ Surface Insulation


- Combustion Air line and recuperator of Skelner un-insulated
- Combustion Air line of Tower Furnace is un-insulated
- Surface Temperature of Tower furnace and Skelner Furnace is in range of 90-300 °C

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces




Opening Loss and Combustion gas loss  
Skelner Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces




Skelner Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces




Skelner Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces



Recuperator Skelner Furnace


# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces



Recuperator Skelner Furnace




# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces




Recuperator Skelner Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces



Combustion Air Line-Skelner  
Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces




Tower Furnace Front

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces



Tower Furnace

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces



Tower Furnace Side

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Specific Fuel Consumption in Furnace

Theoretical Value of Heat required –  $M \times C_p \times \Delta T$

Mass	- 1000 kG
Specific Heat $C_p$ of Al	- 0.22 kcal/kg Deg C
Temp Rise	- 730-30 = 700 Deg C
Heat Reqd.	- 154000 kcal/tonne

Efficiency of Furnace	- 25-35 %
Heat Reqd. @ 25% Eff	- 616000 kcal/tonne
Fuel required @ GCV 10000 kCal/kg	= 61.6 kG/Tonne

Heat Reqd. @ 35% Eff	- 440000 kcal/tonne
Fuel required @ GCV 10000 kCal/kg	= 44 kG/Tonne

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

<b>On Tower Furnace (DEC 15)</b>			
<b>Material Molted (Ton)</b>	<b>FO Used (Kg)</b>	<b>SEC (kg/Ton)</b>	<b>Efficiency % age</b>
782.926	57844	73.88	21 % approx.

<b>On Skelner Furnace (DEC 15)</b>			
<b>Material Molted (Ton)</b>	<b>FO Used (Kg)</b>	<b>SEC (kg/Ton)</b>	<b>Efficiency % age</b>
285.953	27300	95.47	16 % Approx.

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Action Plan

- Install temperature sensors on all Furnace & avoid overshooting of temp.
- Replace existing burners with Modulation burners for maintaining A/F ratio
- Use VFD on combustion Air blower in place of damper
- Proper Utilize Recuperator of Skelner furnaces
- Reduce openings to minimum



# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

## Action Plan

- Install recuperator on tower furnace to Preheat combustion air
- Pre Heat FO day tank for efficient combustion and control its temperature up to 100 Deg. C
- Improve surface insulation
  - Insulate FO line and combustion air flow line
  - Use insulation paints on Furnaces
- Install weighing balance close to furnace to avoid temperature drop of molten metal

# Optimize the Specific Energy Consumption of Tower and Skelner Furnaces

Potential Saving > 25 - 30 %

Saving Calculation = 15% of Total Annual FO bill

<b>Annual Savings</b>	-	<b>Rs. 19.50 Lakhs</b>
<b>Investment</b>	-	<b>Rs. 10.00 Lakhs</b>
<b>Payback</b>	-	<b>6 Months</b>

# Furnaces Operating Costs

## Present Analysis –

Unit I			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	80
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	250
6	Average Production	Pieces/Day	1500
7	<b>Specific Energy Consumption</b>	<b>Liters/Ton</b>	<b>187</b>

# Furnaces Operating Costs

## Present Analysis –

Unit II			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	70
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	250
6	Average Production	Pieces/Day	1500
7	<b>Specific Energy Consumption</b>	<b>Liters/Ton</b>	<b>186</b>

# Furnaces Operating Costs

## Present Analysis –

Unit III			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	80
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	290
6	Average Production	Pieces/Day	1700
7	Specific Energy Consumption	Liters/Ton	162
8	Specific Energy Consumption (Recommended)	Liters/Ton	72
9	Saving Potential	Rs./Year	5,00,000

# Furnaces Operating Costs

**Annual Savings - Rs. 5.00 Lakhs**

# Thank You

**Khalid Khan**

**khalid.khan@cii.in**

# Motors





# TYPES OF MOTORS

## ❖ AC MOTORS

- Very common in Industries



## ❖ DC Motors


- Generally installed for variable speed applications



# Motor Efficiency

Effectiveness with which a motor converts *Electrical* energy to *Mechanical* Energy


Output



Input

$$\text{Efficiency} = \frac{\text{Out put Power}}{\text{Input Power}} \times 100$$


# AC Induction Motor



**STATOR**

**Primary winding connected to  
"POWER SOURCE"**

**Secondary winding carries  
"INDUCED CURRENT"**



**ROTOR**

# Watts Losses

- **Stator & Rotor losses -  $I^2 R$**
- **Iron loss – Voltage Dependent**
- **Friction & windage losses - Independent**
- **Stray load loss – over hang, air gap etc**

# Motor Losses

- **Current dependent - Copper losses**

**Stator**

**Rotor**

- **Voltage dependent - Iron losses**

**Magnetization**


**Eddy Current**

- **Friction and Windage losses**

# Range of Losses in AC Induction Motor

Range ( H.P )	% of Loss	At FL Efficiency %
1 - 10	14 - 35	65 - 86
10 - 50	09 - 15	85 - 91
50 - 200	06 - 12	88 - 94
200 - 1500	04 - 07	93 - 96
1500 & above	4	95 - 96

# Basic Formulas



$$\text{Power} = \sqrt{3} V I \cos \phi$$

$\cos \phi$  is power factor

Capacity  $\propto$  Torque

$\propto$  Voltage<sup>2</sup>


# Energy Waste - Causes

- **Use of less efficient motors**
- **Oversized /under loaded motors**
- **Improper supply voltage**
- **Voltage fluctuations**
- **Poor power factor**
- **Idle running**



# Motor Efficiency - Improvement

**Capacity  $\propto$  Voltage  $^2$**



# Voltage Optimization

**Capacity  $\propto$  Voltage <sup>2</sup>**

## **Impact on motor operating parameters**

- **Capacity reduces**
- **Reduction in voltage dependent losses - Drop in Magnetization current**
- **PF improves**
- **Load current drops**
- **Load factor improves**
- **Efficiency Improves**


# Voltage Optimization

## What are the effects of voltage optimization?

**(Voltage 415 V --> 400 V)**

- **100 HP Motor - 100 % Loading**  
**Increase in Load Current**
- **100 HP Motor - 80% Loading**  
**Decrease in Load Current – Optimum Level**
- **100 HP Motor - 50% Loading**  
**Decrease in load current – Still Potential**


# Effect of Voltage on Motor Losses



# Optimize The Plant Operating Voltage - Overall

- **Plant operating voltage plays a critical role in energy conservation**
- **On line voltage optimising devices to regulate the operating voltage**
- **Magnetization losses vary exponentially with the voltage**

# Motor Magnetization Losses Vs Motor Voltage



# Optimise The Plant Operating Voltage- Overall

- **Voltage optimisation Potential will vary with over all Loading pattern of all motors**
- **To be implemented after analysing the loading pattern of all motors**
- **Reduce Voltage from rated value – *In steps***
- **Monitor Energy Consumption**
- **Arrive at Optimum Voltage**

# Voltage Optimisation-Overall

- **Distribution Transformers**
- **2000 kVA, 433 Volts Supply Voltage**
- **LT Motors Loading : 20 – 80%**
- **Transformer tap position reduced from normal tap**
- **Voltage before optimization = 420 Volts**
- **Average Load = 850-900 KW**
- **Optimized voltage = 400-405 Volts**

**Annual Savings : Rs.1.3 Lakhs**



# Energy Efficient Motor

# WHY MOTORS ARE BECOMING LESS EFFICIENT

1

- **Over Sized / Under loaded Motors**

2

- **Improper Supply Voltage**

3

- **Use of Less Efficient Motors**

4


- **Poor Power Factor**

5

- **Rewinding of Motors**

# Energy Efficient Motor

- **Use of lower loss silicon steel**
- **Longer core**
- **Thicker wires**
- **Thinner laminations**
- **20% more copper compared to standard motors to reduce the stator losses**
- **Rotor losses are reduced by increasing the mass of rotor conductors and / or increasing their conductivity**
- **Precision air gaps to reduce current requirements**
- **Improved winding and lamination designs to minimize energy consumption**



# Energy Efficient Motor

- **lesser slip**
- **Improved fan design**
  - ❑ **Cooler operation & Increases motor insulation life**
- **1.15 service factor**
  - ❑ **Greater flexibility in handling voltage variations and imbalances**
- **High power factor**
  - ❑ **Eliminate need for PF correction**

# Energy Efficient Motors

## New efficiency classes defined by IEC

Super premium efficiency *	IE4	Super premium efficiency
Premium efficiency	IE3	Premium
High efficiency	IE2	Comparable to EFF1
Standard efficiency	IE1	Comparable to EFF2

***IEC standard indicated a Super Premium class with 15% lower losses than the IE3***




# Comparison of efficiencies of Standard & Energy Efficient Motors

Output 4 Pole	IS 8789	eff 2 as per IS 12615	eff 1 as per IS 12615
0.75 kW	71.0%	73.0%	82.5%
1.5 kW	76.0%	78.5%	85.0%
3.7 kW	83.0%	84.0%	88.3%
11 kW	85.5%	88.4%	91.0%
18.5kW	87.0%	90.0%	92.2%
37 kW	88.5%	92.0%	93.6%
75 kW	Not specified	93.6%	94.7%
110 kW	Not specified	94.4%	95.2%
160 kW	Not specified	95.0%	95.8%

Efficiency values are subject to tolerance as per IS325

# IE efficiency classes for 50 Hz 4-pole motors




# Loading vs Efficiency

- **Motors are generally loaded between 40-60%**
  - ❑ **Due to Higher starting Torque**
  - ❑ **Varying process requirements**
- **Efficiency of Energy Efficient Motors is higher than conventional motors and flat between 50-100% loading**



# Energy Efficient Motor – Part load Operation



# Advantages

- **Optimum efficiency**
- **Longer life**
- **Lower operating cost**
- **Better tolerance to thermal and electrical stresses**
- **Ability to operate at higher ambient temperature**
- **Can withstand abnormal operating conditions**

# When to Install EE Motors?

## New Projects

- EE Motors ideally suited

## Rewinding of Old motors

- In case of Normal Failure
- Fit case for Replacement after rewind 5 times

## Applications where EE motors cannot be installed ?

EE Motors are not to be Installed for Intermittent duty applications like crane, Hoist etc

# Rewound Motors

## Motor Burning

- **Quality of insulation between stampings deteriorates**
- **Eddy current losses increases**
- **Magnetic property deteriorates**
  - ❑ **Magnetic losses increases**
- **Causes drop in efficiency**

# Rewound Motors

## Bearing failure

- Rotor scratches stator
- Air gap becomes uneven
- Torque induced not uniform
- Net torque developed is low
- Causes drop in efficiency
- Motors replacement should be analysed case to case basis
- Maximum 5 times motor can undergo rewinding – normal failure



# Replace Conventional Old Motors With Energy Efficient Motors

- **It has been implemented in many industries**
- **Case study is from one of the textiles industry**
- **Ring frames are vital and continuous operating equipment in textile industry**
- **Total number of RF machines - 30 Nos.**

# Replace Conventional Old Motors With Energy Efficient Motors

**Continuous operation**

**Results:**

<b>Motors</b>	<b>Rated kW</b>	<b>No load kW</b>	<b>Load kW</b>
<b>Old motor</b>	<b>15.0</b>	<b>2.32</b>	<b>9.92</b>
<b>Energy efficient motor</b>	<b>15.0</b>	<b>1.56</b>	<b>7.36</b>
<b>Difference in consumption</b>		<b>0.76</b>	<b>2.56</b>

**Savings** : **Rs. 6.7 lakhs**  
**Investment** : **Rs.10.2 lakhs**  
**Pay back** : **19 month**


# Comparison with Energy Efficient Motor

- There are two same size motor is operating for one part, punching Application
- Following table shows the details of Grinder Machine


Area	Rating of Motor	Running Power of Motor	
	HP	kW	
Punching-1	15	14.0	5 Times Rewind
Punching-2	15	7.0	New



# Comparison with Energy Efficient Motor



# Comparison with Energy Efficient Motor



# Install New Energy Efficient Motor

## Proposed System

- **Install EE Motor**
- **Lower Power consumption**
- **More than 25% of energy saving at present power consumption**

# Install New Energy Efficient Motor

Saving = 14 kW x 25% x 6 hrs x 300 Days x Rs 7.50

<b>Annual Savings</b>	<b>: Rs. 0.47 Lakhs</b>
<b>Investment</b>	<b>: Rs. 1.48 Lakhs</b>
<b>Payback</b>	<b>: 38 Months</b>

# Summary – EE Motors

- **National standard IS 12615: 2004 for energy efficient three phase induction motors from 0.37kW to 160 kW**
- **Energy savings are more at partial loads because Energy Efficient motors have a Flat Efficiency Vs. Load Characteristic**
- **Payback period of eff2 motor over IS-8789 motor is approx. 1500 to 2000 working hrs.**
- **Payback period of eff1 motor over eff2 motor is approx. 2500 - 3000 working hrs.**

# Sum-up

## Sizing of the motor is critical and important

- **Oversizing will result in**
  - ❑ More losses
  - ❑ Lower efficiency
- **Under-sizing will result in**
  - ❑ Overloading
  - ❑ Overheating & failures
- **Optimal sizing will result in**
  - ❑ Minimum losses
  - ❑ Maximum efficiency

# Sum-up

- **History Card**
  - ❑ **Regular Updation**
- **Joint Ownership with the process team**
- **Energy Efficient Motor**
  - ❑ **Replacement – Rewound Motors**

# Thank you



# Furnaces

# Furnaces Operating Costs

## Present Analysis –

Unit I			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	80
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	250
6	Average Production	Pieces/Day	1500
7	<b>Specific Energy Consumption</b>	<b>Liters/Ton</b>	<b>187</b>

# Furnaces Operating Costs

## Present Analysis –

Unit II			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	70
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	250
6	Average Production	Pieces/Day	1500
7	<b>Specific Energy Consumption</b>	<b>Liters/Ton</b>	<b>186</b>

# Furnaces Operating Costs

## Present Analysis –

Unit III			
S N	Parameters	Units	Figures
1	Fo Consumption	Litres/Day	80
1	FO Cost	Rs./Kg	33
3	Plant Running hours	Hours/Day	6
4	Plant Running days	Days/Annum	300
5	Weight of Product	gm	290
6	Average Production	Pieces/Day	1700
7	Specific Energy Consumption	Liters/Ton	162
8	Specific Energy Consumption (Recommended)	Liters/Ton	72
9	Saving Potential	Rs./Year	5,00,000



# Furnaces Operating Costs

**Annual Savings - Rs. 5.00 Lakhs**