

COMPREHENSIVE ENERGY AUDIT REPORT
“PROMOTING ENERGY EFFICIENCY AND RENEWABLE ENERGY IN SELECTED MSME
CLUSTERS IN INDIA”

Juneja Forgings

5th-Milestone, Kapurthala Road, Jalandhar, Punjab – 144013

16-05-2015

Submitted to



BUREAU OF ENERGY EFFICIENCY

4th Floor, Sewa Bhawan, R K Puram, Sector-I, New Delhi -110066

Submitted by



DEVELOPMENT ENVIRONERGY SERVICES LTD

819, Antriksh Bhawan, 22 Kasturba Gandhi Marg, New Delhi -110001
Tel.: +91 11 4079 1100 Fax : +91 11 4079 1101; www.deslenergy.com

DISCLAIMER

This report (including any enclosures and attachments) has been prepared for the exclusive use and benefit of the addressee(s) and solely for the purpose for which it is provided. Unless we provide express prior written consent, no part of this report should be reproduced, distributed or communicated to any third party. We do not accept any liability if this report is used for an alternative purpose from which it is intended, nor to any third party in respect of this report.

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 2 of 71 | |

ACKNOWLEDGEMENT

DESL places on record its sincere thanks to Global Environment Facility (GEF), United Nations Industrial Development Organization (UNIDO) and Bureau of Energy Efficiency (BEE) for vesting confidence in DESL to carry out the assignment “Conducting energy audit and dissemination programs in MSME clusters” under their national project “*promoting energy efficiency and renewable energy in selected MSME clusters in India*”.

As a part of this assignment, work in Jalandhar Hand-tools cluster was awarded to DESL and DESL is grateful to GEF-UNIDO-BEE PMU for their full-fledged coordination and support throughout the study

The study team is indebted to Mr. Sarabjit Singh, Director for showing keen interest in the energy audit and also thankful to the management of M/s Juneja Forgings for their wholehearted support and cooperation for the preparation of this comprehensive energy audit report, without which the study would not have steered to its successful completion. Special thanks to other members of the unit for their diligent involvement and cooperation.

It is well worthy to mention that the efforts being taken and the enthusiasm shown by all the plant personnel towards energy conservation and sustainable growth are really admirable.

Last but not the least, the interaction and deliberation with Mr. Sukh Dev Raj, President, Hand tool manufacturers association, Jalandhar, technology providers and all those who were directly or indirectly involved throughout the study were exemplary. The entire exercise was thoroughly a rewarding experience for DESL.

DESL Team

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 3 of 71 | |

DESL Team

| | |
|---------------------------------------|---|
| Project Head | Mr. R. Rajmohan Chief Executive Officer |
| Team leader and co-coordinator | Mr. Suparno R Majumdar Consultant |
| Team member(s) | Mr. Mithlesh Priya Analyst |
| | Mr. Tanmay Varshney Project Analyst |
| | Mr. Prabhat Sharma Project Analyst |
| | Mr. Vishnu P Project Associate |
| | Mr. Oisik Mishra Project Associate |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 4 of 71 | |

CONTENTS

| | |
|--|----|
| EXECUTIVE SUMMARY | 11 |
| 1 INTRODUCTION | 14 |
| 1.1 Background and Project objective | 14 |
| 1.2 Scope of work for Comprehensive Energy Audit | 14 |
| 1.3 Methodology | 15 |
| 1.3.1 Boundary parameters | 15 |
| 1.3.2 General methodology | 15 |
| 1.3.3 Comprehensive energy audit – field assessment | 16 |
| 1.3.4 Comprehensive energy audit – desk work..... | 18 |
| 2 ABOUT THE MSME UNIT..... | 19 |
| 2.1 Particulars of the unit..... | 19 |
| 3 DETAILED TECHNICAL FEASIBILITY ASSESSMENT OF THE UNIT | 20 |
| 3.1 Description of manufacturing process | 20 |
| 3.1.1 Process & Energy flow diagram | 20 |
| 3.1.2 Process description | 21 |
| 3.2 Inventory of process machines / equipments and utilities | 22 |
| 3.2.1 Types of energy used and description of usage pattern..... | 22 |
| 3.3 Analysis of electricity consumption by the unit | 24 |
| 3.3.1 Baseline parameters | 24 |
| Electricity load profile..... | 25 |
| 3.3.2 Sourcing of electricity | 25 |
| 3.3.3 Supply from utility | 26 |
| 3.3.4 Self – generation..... | 26 |
| 3.3.5 Month wise electricity consumption | 27 |
| 3.4 Analysis of thermal consumption by the unit | 29 |
| 3.5 Specific energy consumption | 30 |
| 3.6 Identified energy conservation measures in the plant | 31 |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 5 of 71 | |

| | | |
|-------|---|----|
| 3.6.1 | Electricity Supply from Grid | 31 |
| 3.6.2 | DG Performance | 33 |
| 3.6.3 | Electrical consumption areas | 36 |
| 3.6.4 | Thermal consumption areas | 37 |
| 4 | EE TECHNOLOGY OPTIONS AND TECHNO – ECONOMIC FEASIBILITY | 39 |
| 4.1 | EPIA 1, 2 & 3: Excess air control using PID | 39 |
| 4.2 | EPIA 4: Reduction in radiation and convection losses from surfaces of forging furnace 4 and 5 | 41 |
| 4.3 | EPIA 5: Installation of VFD on broaching machine | 43 |
| 4.4 | EPIA 6: Replacing old conventional ceiling fans with EE fans..... | 44 |
| 4.5 | EPIA 7 & 8: Replacing present conventional lights with Energy Efficient light fixtures | 45 |
| 4.6 | EPIA 9: Leakage arrest in compressor 1 | 46 |
| 4.7 | EPIA 10: Replacement of reciprocating compressor No. 2 with screw compressor | 47 |
| 4.8 | EPIA 11: Replacement of present inefficient DG set with new EE DG set..... | 48 |
| 4.9 | EPIA 12: Replacement of present inefficient burners with new EE burners | 49 |
| 5 | ANNEXURE | 51 |
| 6 | LIST OF VENDORS..... | 66 |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 6 of 71 | |

List of figures

| | |
|--|----|
| Figure 1: General methodology | 16 |
| Figure 2: Process flow diagram..... | 20 |
| Figure 3: Energy cost share..... | 23 |
| Figure 4: Energy use share..... | 24 |
| Figure 5: Share of electricity by source and cost | 25 |
| Figure 6: Month wise variation in electricity consumption from different sources | 28 |
| Figure 7: Month wise variation in electricity cost from different sources | 28 |
| Figure 8: Average cost of power (Rs./kWh) from different sources | 29 |
| Figure 9: Power factor and load profile | 31 |
| Figure 10: Current and Voltage Profile | 32 |
| Figure 11: Harmonics profile | 32 |
| Figure 12: Power factor and load profile of DG set 1-125 kVA..... | 33 |
| Figure 13: Voltage and current profile of DG Set 1-125 kVA..... | 34 |
| Figure 14: Energy and Harmonics profile of DG set 1- 125 KVA..... | 34 |
| Figure 15: Power factor and load profile of DG Set 2-125 KVA | 34 |
| Figure 16: Voltage and current profile of DG set 2- 125 kVA | 35 |
| Figure 17: Harmonics and Energy profile of DG set 2-125 KVA..... | 35 |
| Figure 18: Sankey diagram furnace 2 | 53 |
| Figure 19: Sankey diagram furnace 3 | 56 |
| Figure 20: Sankey diagram furnace 4 | 59 |
| Figure 21: Sankey diagram furnace 5 | 62 |
| Figure 22 Sankey: diagram of forging furnace 8..... | 65 |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 7 of 71 | |

List of Tables

| | |
|--|----|
| Table 1 Details of Unit | 11 |
| Table 2: Summary of EPIA..... | 13 |
| Table 3: List of 12 targeted MSME clusters covered under the project | 14 |
| Table 4 Energy audit instruments..... | 17 |
| Table 5: General particulars of the unit..... | 19 |
| Table 6: Energy cost distribution | 23 |
| Table 7: Baseline parameters | 24 |
| Table 8: Electricity share from grid and DG | 25 |
| Table 9: Tariff structure | 26 |
| Table 10: Electricity consumption & cost | 27 |
| Table 11: FO and wood used as fuel..... | 29 |
| Table 12: Overall specific energy consumption..... | 30 |
| Table 13: Diagnosis of electric supply..... | 32 |
| Table 14: Analysis of DG set | 35 |
| Table 15: Cost benefit analysis (EPIA 1) – Forging furnace 8..... | 40 |
| Table 16: Cost benefit analysis (EPIA 2) - Forging furnace-4 | 40 |
| Table 17: Cost benefit analysis (EPIA 3) – Forging furnace 5..... | 41 |
| Table 18: R & C losses | 42 |
| Table 19: Cost benefit analysis (EPIA 4)..... | 42 |
| Table 20: Cost benefit analysis (EPIA 5)..... | 43 |
| Table 21: Cost benefit analysis (EPIA 6)..... | 44 |
| Table 22: Cost benefit analysis (EPIA 7)..... | 45 |
| Table 23: Cost benefit analysis (EPIA 8)..... | 46 |
| Table 24: Cost benefit analysis (EPIA 9)..... | 47 |
| Table 25: Cost benefit analysis (EPIA 10)..... | 48 |
| Table 26: Cost benefit analysis (EPIA 11)..... | 49 |
| Table 27: Furnace specifications for the EE burners | 49 |
| Table 28: Cost benefit analysis (EPIA 12)..... | 50 |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 8 of 71 | |

| | | | | |
|-------------------|---|-------------|--------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 9 of 71 | |

ABBREVIATIONS

| Abbreviations | Expansions |
|------------------|--|
| APFC | Automatic Power Factor Correction |
| BEE | Bureau of Energy Efficiency |
| CEA | Comprehensive Energy Audit |
| CFL | Compact Fluorescent Lamp |
| CRV | Chromium Vanadium |
| DESL | Development Environenergy Services Limited |
| DG | Diesel Generator |
| EE | Energy Efficiency |
| EPIA | Energy Performance Improvement Action |
| FO | Furnace Oil |
| GEF | Global Environment Facility |
| HSD | High Speed Diesel |
| HVAC | Heating Ventilation and Air Conditioning |
| LED | Light Emitting Diode |
| LT | Low Tension |
| MD | Maximum Demand |
| MS | Mild Steel |
| MSME | Micro, Small and Medium Enterprises |
| MT | Metric Tons |
| MTOE | Million Tons of Oil Equivalent |
| MV | Mercury Vapour |
| No. | Number |
| PF | Power Factor |
| PID | Proportional-Integral-Derivative |
| PNG | Piped Natural Gas |
| PSPCL | Punjab State Power Corporation Limited |
| R & C | Radiation & Convection |
| RE | Renewable Energy |
| SEC | Specific Energy Consumption |
| SEGR | Specific Energy Generation Ratio |
| SLD | Single Line Diagram |
| SME | Small and Medium Enterprises |
| UNIDO | United Nations Industrial Development Organization |
| VFD | Variable Frequency Drives |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 10 of 71 | |

EXECUTIVE SUMMARY

Bureau of Energy Efficiency (BEE) in association with the United Nations Industrial Development Organization (UNIDO) and Global Environment Facility (GEF) is implementing a project titled “Promoting energy efficiency and renewable energy technology in selected MSME clusters in India”. The objective of the project is to provide impetus to energy efficiency initiatives in the micro, small and medium enterprises (MSMEs) sector in India.

As part of this project, DESL has been engaged to implement the project in the MSME hand tool cluster in Jalandhar, Punjab. There are about 400 units scattered over three industrial areas in Jalandhar, viz. focal point, old industrial area and basti area. The major products manufactured include spanners and wrenches, pliers, screw drivers, etc with an average annual production of 50,000 metric tons in the cluster.

The project awarded to DESL consists of six major tasks:

- Conducting pre – activity cluster workshop defining the agenda of this engagement.
- Comprehensive energy audit in 6 selected units.
- Development of cluster specific best operating practices document for the top 5 energy using equipments / processes in the industry.
- Identification of set of energy auditing instruments that should be used for carrying out periodic energy audits in the units.
- Enumeration of common regularly monitorable parameters at the process level, which have impact on energy performance and listing of appropriate instrumentation for the same.
- Conducting 3 post energy audit training workshops based on preceding outputs of this activity.

Brief Introduction of the Unit

Table 1 Details of Unit

| | |
|--------------------------------------|---|
| Name of the Unit | M/s Juneja Forgings |
| Constitution | Private Limited |
| MSME Classification | Small |
| No. of years in operation | NA |
| Address: Registered Office | 5 th -Milestone, Kapurthala Rd, Jalandhar, Punjab-144013 |
| Administrative Office | 5 th -Milestone, Kapurthala Rd, Jalandhar, Punjab-144013 |
| Factory | 5 th -Milestone, Kapurthala Rd, Jalandhar, Punjab-144013 |
| Industry-sector | Hand Tool |
| Products Manufactured | Combination Spanners, Double Open Ended Spanners, Ring Spanners etc |
| Name(s) of the Promoters / Directors | Mr. Sarabjit Singh |

Comprehensive Energy Audit

The study was conducted in 3 stages:

| | | | |
|-------------------|---|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 11 of 71 |

- **Stage 1:** Walk through energy audit of the plant to understand the process, energy drivers, assessment of the measurement system, assessment of scope, measurability, formulation of audit plan and obtaining required information
- **Stage 2:** Detailed energy audit data collection and field measurements for performance evaluation of equipments/ systems, estimation of savings potential, technology assessment and understanding of project constraints
- **Stage 3:** Data analysis, initial configuration of projects, savings quantification, vendor consultation, interaction with the unit and freezing of projects for implementation and preparation of energy audit report

The production process of the unit

The main process equipments in the unit include the following:

The production process includes blanking, heating, forging, trimming, broaching, grinding, barreling, heat treatment, shot blasting, calibration, polishing, electroplating and packing.

The raw materials used are mainly MS and CRV steel. The raw material is blanked and then sent to a forging furnace for heating. The heated material (work piece) is removed from the forging furnace and forged using hammers. The forged work piece is then cut and trimmed into desired shapes and the unnecessary burrs along the edges are removed in the trimming operation.

The trimmed work piece is then treated in the heat treatment furnace for hardening, quenching and tempering to attain desired metallurgical properties like strength, stability and durability.

Post heat treatment, in order to get the necessary surface finish and polish, the work pieces are shot blasted after which they are placed in vibrating glazing machines along with a measured quantity of ceramic material (in form of ceramic stones). Due to the vibration action of this machine, the work pieces and the ceramic materials rub against each other. In this process, the work piece gets further polished.

The polished work piece is then sent for electroplating, where it is dipped for a certain period of time inside hot nickel and chromium baths to attain the desired final glaze and finishing. From the electroplating section the finished products are packed and dispatched.

The main process equipments are furnace, hammer, broaching machines, blanking machines, heat treatment furnace, vibrators, shot blasting machine.

Identified Energy Performance Improvement Actions

The comprehensive energy audit covered all of the equipments which were operational during the field study. Thermal energy constitutes 68% (FO, HSD, Wood) and grid electricity constitutes 32% of total plant energy. The identified energy performance improvement actions are given in Table – 2.

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 12 of 71 | |

Table 2: Summary of EPIA

| Sl. No. | | Estimated energy savings | | | | | | Simple payback period y | |
|---------|--|--------------------------|-----------------|---------------|------------------|------------------|----------------------|----------------------------|------------|
| | | FO | Electricity | HSD | Material Savings | Monetary savings | Estimated investment | | |
| | | Litre/y | kWh/y | Litre/y | Rs./y | Rs. lakh/y | Rs. lakh | | |
| 1 | Installation of PID controller for excess air control on forging-8 | 11169.6 | 1969.4 | | | 3.7 | 8.3 | 7.00 | 0.8 |
| 2 | Installation of PID controller for excess air control on forging-4 | 10586 | 1969.4 | | | 3.9 | 9.1 | 7.00 | 0.8 |
| 3 | Installation of PID controller for excess air control on forging-5 | 4591 | 1969.4 | | | 2.3 | 4.3 | 7.00 | 1.6 |
| 4 | Skin loss reduction from furnace surface of forging 4 and 5 | 744.4 | | | | | 0.3 | 0.10 | 0.32 |
| 5 | VFD on broaching machine 11 | | 5251.7 | | | | 0.4 | 0.79 | 2.3 |
| 6 | Installation of energy efficient fan instead of conventional fan | | 36085.5 | | | | 2.4 | 4.05 | 1.7 |
| 7 | Retrofit of CFL 40 watt to led tube light of 16 watt | | 10692.0 | | | | 0.7 | 0.84 | 1.2 |
| 8 | Replacement of CFL 65W ,50W halogen watt,250W MV with LED light | | 39982.1 | | | | 2.69 | 5.06 | 1.9 |
| 9 | Leakage Arrest on Compressor 1 | | 13806 | | | | 0.9 | 0.10 | 0.1 |
| 10 | Replacement of reciprocating compressor with screw compressor | | 15303 | | | | 1.02 | 3.00 | 2.9 |
| 11 | DG Replacement - 125 kVA | | | 3232 | | | 1.62 | 7.61 | 4.7 |
| 12 | Replacement of present burner with energy efficient burner | 17820.0 | | | | | 7.13 | 1.21 | 0.2 |
| | Total | 44910.5 | 127028.2 | 3232.4 | | 9.9 | 38.8 | 43.8 | 1.1 |

The projects proposed will bring the energy savings of up to 6.62 % and upto 38.8 lakh of cost saving in the plant on implementation.

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 13 of 71 | |

1 INTRODUCTION

1.1 Background and Project objective

Bureau of Energy Efficiency (BEE) in association with the United Nations Industrial Development Organization (UNIDO) and Global Environment Facility (GEF) is implementing a project titled “Promoting energy efficiency and renewable energy technology in selected MSME clusters in India”. The objective of the project is to provide impetus to energy efficiency initiatives in the micro, small and medium enterprises (MSMEs) sector in India.

The targeted 12 MSME clusters under the project and the indicative information are given below:

Table 3: List of 12 targeted MSME clusters covered under the project

| Sl. No. | Sub – sector | Cluster |
|---------|--------------|-----------------------------|
| 1 | Brass | Jagadhri, Jamnagar |
| 2 | Ceramic | Khurja, Morbi, Thangarh |
| 3 | Dairy | Gujarat, Madhya Pradesh |
| 4 | Foundry | Belgaum, Coimbatore, Indore |
| 5 | Hand tools | Jalandhar, Nagaur |

The objectives of this project are as under:

- Increasing capacity of suppliers of energy efficiency (EE) and renewable energy (RE) based products, service providers and financing institutions;
- Increasing the levels of end-use demand and implementation of EE and RE technologies and practices by MSMEs;
- Scaling up of the project to the national level;
- Strengthening policy, institutional and decision making frameworks.

1.2 Scope of work for Comprehensive Energy Audit

The general scope of work for comprehensive energy audits is as follows:

- Data Collection
 - Current energy usage (month wise) for all forms of energy for the period April-2014 to March-2015 (quantity and cost)
 - Data on production for the corresponding period (quantity and cost)
 - Data on production cost and sales for the corresponding period (cost)
 - Mapping of process
 - Company profile including name of the company, constitution, promoters, years in operation and products manufactured
 - Existing manpower and levels of expertise
 - List of major equipments and specifications

| | | | |
|-------------------|---|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 14 of 71 |

- Analysis:
 - Energy cost and trend analysis
 - Energy quantities and trend analysis
 - Specific consumption and trend analysis
 - Performance evaluation of major energy consuming equipments / systems
 - Scope and potential for improvement in energy efficiency
- Correlate monthly production data with electricity and fuel consumption for a period of 12 months of normal operation for individual sections of the overall plant.
- Detailed process mapping to identify major areas of energy use.
- To identify all opportunities for energy savings in the following areas:
 - Electrical: Power Factor, transformer loading, power quality, motor load, compressed air systems, conditioned air systems, cooling water systems, lighting load, electrical metering, monitoring and control system.
 - Thermal: Furnaces, steam and hot water systems (including hot water lines tracing, pipe sizes, insulation), heat recovery systems, etc.
- Evaluate the energy consumption vis-à-vis the production levels and to identify the potential for energy savings / energy optimization (both short term requiring minor investments with attractive payback, and mid to long terms system improvement needing moderate investments and with payback period of 4.7 years).
- Classify parameters related to EE enhancements such as estimated quantum of energy savings, investment required, time-frame for implementation, payback period, re-skilling of existing manpower, etc. and to classify the same in order of priority.
- Design an “energy monitoring system” for effective monitoring and analysis of energy consumption, energy efficiency.

1.3 Methodology

1.3.1 Boundary parameters

Following boundary parameters were set for coverage of the audit.

- Audit covered all possible energy intensive areas & equipment which were operational during the field study
- All appropriate measuring systems including portable instruments were used
- The identified measures normally fall under short, medium and long-term measures

1.3.2 General methodology

Following flow chart illustrates the methodology followed for carrying out different tasks:

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 15 of 71 | |




Figure 1: General methodology

The study was conducted in 3 stages:

- **Stage 1:** Walk through energy audit of the plant to understand the process, energy drivers, assessment of the measurement system, assessment of scope, measurability, formulation of audit plan and obtaining required information
- **Stage 2:** Detailed energy audit-testing and measurement for identification of savings potential, technology assessment and understanding of project constraints
- **Stage 3:** Desk work for data analysis, initial configuration of projects, savings quantification, vendor consultation, interaction with unit and freezing of projects for implementation and preparation of energy audit report

1.3.3 Comprehensive energy audit – field assessment

A walk through was carried out on the before the audit with a view to:

- Understand the manufacturing process and collect historical energy consumption data
- Obtain cost and other operational data for understanding the impact of energy cost on the units financial performance
- Assess the energy conservation potential at macro level
- Finalize the schedule of equipments and systems for testing and measurement

The audit identified the following potential areas of study:

- Heating and Forging
- Electrical motors used in process
- Fans and lighting loads

The further activities carried out by the team after walk through study included:

- Preparation of the process and energy flow diagrams
- Study of the system and associated equipments

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 16 of 71 | |

- Conducting field testing and measurement
- Data analysis for preliminary estimation of savings potential at site
- Discussion with the unit on the summary of findings and energy efficiency measures identified

Audit methodology involved system study to identify the energy losses (thermal / electrical) and then finding solutions to minimize the same. This entailed data collection, measurements / testing of the system using calibrated, portable instruments, analyzing the data / test results and identifying the approach to improve the efficiency. The various instruments used for the energy audit are:

Table 4 Energy audit instruments

| Sl. No. | Instruments | Make | Model | Parameters Measured |
|---------|--|----------------------|-----------------------|--|
| 01 | Power Analyzer – 3 Phase (for un balanced Load) with 3 CT and 3 PT | Enercon and Circutor | AR-5 | AC Current, Voltage, Power Factor, Power, Energy, Frequency, Harmonics and data recording for minimum 1 sec interval |
| 02 | Power Analyzer – 3 Phase (for balance load) with 1 CT and 2 PT | Elcontrol Energy | Nanovip plus mem | AC Current, Voltage, Power Factor, Power, Energy, Frequency, Harmonics and data recording for minimum 2 sec interval |
| 03 | Digital Multi meter | Motwane | DM 352 | AC Amp, AC-DC Voltage, Resistance, Capacitance |
| 04 | Digital Clamp on Power Meter – 3 Phase and 1 Phase | Kusam - Meco | 2745 and 2709 | AC Amp, AC-DC Volt, Hz, Power Factor, Power |
| 05 | Flue Gas Analyzer | Kane-May | KM-900 | O2%, CO2%, CO in ppm and Flue gas temperature, Ambient temperature |
| 06 | Digital Temperature and Humidity Logger | Dickson | | Temperature and Humidity data logging |
| 07 | Digital Temp. & Humidity meter | Testo | 610 | Temp. & Humidity |
| 08 | Digital Anemometer | Lutron and Prova | AM 4201 And AVM-03 | Air velocity |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 17 of 71 | |

| Sl. No. | Instruments | Make | Model | Parameters Measured |
|---------|------------------------------------|-------------------------------------|----------|-----------------------------------|
| 09 | Vane Type Anemometer | Testo | 410 | Air velocity |
| 10 | Digital Infrared Temperature Gun | Raytek | Minitemp | Distant Surface Temperature |
| 11 | Contact Type Temperature Meter | Testo | 925 | Liquid and Surface temperature |
| 12 | High touch probe Temperature Meter | CIG | | Temperature upto 1300 deg C |
| 13 | Lux Meter | Kusum Mecro (KM-LUX-99) and Mastech | | Lumens |
| 14 | Manometer | Comark | C 9553 | Differential air pressure in duct |
| 15 | Pressure Gauge | Wika | | Water pressure 0 to 40 kg |

1.3.4 Comprehensive energy audit – desk work

Post audit off-site work carried out included:

- Re-validation of all the calculations for arriving at the savings potential
- Quick costing based on DESL's database or through vendor interactions as required
- Configuration of individual energy performance improvement actions
- Preparation of audit report

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 18 of 71 | |

2 ABOUT THE MSME UNIT

2.1 Particulars of the unit

Table 5: General particulars of the unit

| Sl. No. | Particulars | Details |
|---------|---|---|
| 1 | Name of the unit | M/s Juneja Forgings |
| 2 | Constitution | Private Limited |
| 3 | Date of incorporation / commencement of business | NA |
| 4 | Name of the contact person Mobile/Phone No. E-mail ID | Mr. Sarabjit Singh +91-181 – 2651200,300,400 sarabjit@junejaforgings.com |
| 5 | Address of the unit | 5 th -Milestone, Kapurthala Rd, Jalandhar, Punjab-144013 |
| 6 | Industry / sector | Hand Tools |
| 7 | Products manufactured | Combination Spanners, Double Open Ended Spanners, Ring Spanners, etc |
| 8 | No. of operational hours/day | 12 |
| 9 | No. of shifts / day | 1 |
| 10 | No. of days of operation / year | 330 |
| 11 | Whether the unit is exporting its products (yes / no) | Yes |
| 12 | No. of employees | 200-300 |

| | | | |
|-------------------|---|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 19 of 71 |

3 DETAILED TECHNICAL FEASIBILITY ASSESSMENT OF THE UNIT

3.1 Description of manufacturing process

3.1.1 Process & Energy flow diagram




Figure 2: Process flow diagram

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 20 of 71 | |

3.1.2 Process description

M/s Juneja Forgings manufacture Combination Spanners, Double Open Ended Spanners, Ring Spanners, etc.

The process description is as follows:

Raw Material

The main raw materials used are round and flat Mild Steel and Chromium Vanadium Steel.

Blanking

It is a process in which the work piece is removed from the primary metal strip and the piece removed is called blank metal scrap.

Heating

The unit has 5 oil fired forging furnaces for heating the work pieces. The temperature maintained is around 1000⁰C.

Forging

The red hot work pieces taken out from the forging furnace are placed on the lower fixed die above the anvil. A ram moves downwards with gravity action. Below the ram is placed the upper die which is fixed to it. After several strokes of the upper die on the work piece, the work piece takes the desired shape.

Trimming

In this machine, the forged material is pressed to give it a uniform shape by removing the unnecessary burrs along the edges. The speed of the press is controlled and it travels at a low speed when it comes down and exerts maximum pressure just before pressing.

Grinding

This is a process where-by a sand paper is used for side grinding of the “trimmed work-piece”.

Broaching

It is similar to trimming operation, whereby a toothed tool called broach is used to remove materials from the ground work piece. Two types of broaches are used, i.e. linear for open sections and rotary for circular sections.

Barreling

In this operation, ceramic stones are used to remove the scales from the work piece using a rubbing action.

Heat Treatment

Heat treatment is done to impart the required metallurgical properties to the work piece that will improve the working life of manufactured equipment (hand-tool). The main processes involved are hardening, quenching and tempering. Electrical heat treatment furnaces are used for this purpose.

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 21 of 71 | |

Shot Blasting

This is done to clean and polish the work piece.

Calibration and inspection

The finished product is calibrated to check the dimensions, size, shape, etc before the final finishing process.

Glazing

In this machine, the ceramic material and the work pieces are placed together on the vibrating glazing machine. Due to the vibrating action of this machine, the work piece and the ceramic materials (in the form of solid stones) rubs against each other and in this process the work piece gets polished.

Electro plating

The final shining and glazing of the product is done using electroplating, where-by, air is circulated using a blower inside a nickel tank. The final product is dipped inside this tank and kept in that condition for a certain period of time and then taken out and cleaned in a hot water tank.

3.2 Inventory of process machines / equipments and utilities

Major energy consuming equipments in the plant are:

- **Blanking Machine:** Here, the raw material is cut into required shape before it is heated in a furnace.
- **Forging furnace:** FO fired forging furnaces are used for heating the material for forging. The operating temperature of FO fired furnace is around 1000-1100⁰C oil fired furnaces are used in the plant.
- **Hammer:** Hammers are used in forging process, in which material is pressed against a die using a drop hammer. There are 5 hammers which are used in the plant, each adjacent to a forging furnace.
- **Broaching machine:** This machine is used to remove materials from edges of the work piece to give it a better edge finish. Large motors are employed in this machine for this purpose.
- **Heat treatment furnace:** The heat treatment furnace consists of electrical heaters for hardening and tempering. Hardening is done around a temperature of 750 – 800⁰C and tempering is done at around 300 -350⁰C.
- **Electroplating:** Electroplating is the process of plating one metal onto another by hydrolysis, most commonly for decorative purposes or to prevent corrosion of a metal. There are specific types of electroplating such as copper plating, silver plating, and chromium plating.

3.2.1 Types of energy used and description of usage pattern

Both electricity and thermal energy are used in different manufacturing processes. The overall energy use pattern in the unit is as follows:

- Electricity is sourced from two different sources:
 - From the Utility, Punjab State Power Corporation Limited (PSPCL)

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 22 of 71 | |

- Captive backup Diesel Generator sets for the whole plant
- Thermal energy is used for following applications :
 - Fuel Oil for forging furnace
 - Wood for boiler to generate steam for heating electroplating baths

Total energy consumption pattern for the period April-14 to March-15, from different sources are as follows:

Table 6: Energy cost distribution

| Particulars | Rs.(Lakhs) | % of Total | Consumption (MTOE) | Energy sharing (%) |
|-------------------|---------------|-------------|--------------------|--------------------|
| Grid –Electricity | 268.95 | 52% | 361.9 | 32% |
| Diesel –DG | 23.40 | 5% | 44.1 | 4% |
| FO | 192.78 | 37% | 472.5 | 41% |
| Wood | 30.00 | 6% | 262.5 | 23% |
| Total | 515.13 | 100% | 1141.05 | 100% |




Figure 3: Energy cost share

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 23 of 71 | |




Figure 4: Energy use share

Major observations are as under:

- The unit uses both thermal and electrical energy for manufacturing operations. Electricity is sourced from the grid as well as self generated through DG sets when the grid power is not available. Thermal energy consumption is in the form of FO which is used in forging furnace and wood which is used in boiler
- FO used in furnace account for 37% of the total energy cost and 41% of overall energy consumption.
- Electricity used in the process accounts for 52% of the energy cost and diesel used for captive electricity generation is 5% of the overall cost.

3.3 Analysis of electricity consumption by the unit

3.3.1 Baseline parameters

Following are the general base line parameters, which have been considered for the techno-economic evaluation of various identified energy cost reduction projects. The costs shown are the landed costs.

Table 7: Baseline parameters

| | | |
|--|--------------|--------------------------------------|
| Electricity Rate (Excluding Rs./kVA) | 6.14 | Rs. / KVAh inclusive of taxes |
| Weighted Average Electricity Cost | 6.54 | Rs. / kWh |
| Percentage of total DG based Generation | 2% | |
| Average Cost of HSD | 50.00 | Rs./Litre for April 2015 |
| Average Cost of FO | 40.00 | Rs./Litre for April 2015 |
| Annual Operating Days per year | 330 | Day/yr |
| Annual Operating Hours per day | 24 | Hr/day |
| Production | 5433 | MT |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 24 of 71 | |

Electricity load profile

Following observation has been made from the utility inventory:

- The plant total connected load is 1,577.7 kW

3.3.2 Sourcing of electricity

The unit is drawing electricity from two different sources:

- Utility (PSPCL) through regulated tariff
- Captive DG set which is used as a backup source and supplies electrical power in case of grid power failure

The share of utility power and DG power is shown in the table and figure below:

Table 8: Electricity share from grid and DG

| | Consumption (kWh) | % | Cost (Rs. lakh) | % |
|-------------------------|-------------------|-------------|-----------------|-------------|
| Grid Electricity | 4208490 | 98% | 269.0 | 92% |
| Self Generation | 85950 | 2% | 23.4 | 8% |
| Total | 4294440 | 100% | 292.4 | 100% |

This is graphically depicted as follows:




Figure 5: Share of electricity by source and cost

The share of electrical power as shown in the above chart indicates the condition of power supply from utility. The requirement of power from backup source, i.e. DG sets is about 3% of the total power which is not very high. Although the share of DG power in terms of kWh is just 3% of the total electrical power, however, it accounts for about 8% in terms of total cost of electrical power. For economical operation of the plant, the utilization of DG sets needs to be minimized, but it will depend upon the supply condition of the grid as well as the power requirement of the plant.

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 25 of 71 | |

3.3.3 Supply from utility

Electricity is supplied by PSPCL. The unit has one HT energy meter provided by the distribution company in the premise. Details of grid supply are as follows:

- a) Power Supply : 11 kV line
- b) Contract Demand : 1225 kVA
- c) Sanctioned Load : 1577.27 kW
- d) Nature of Industry : HT – G

The grid electricity tariff structure is as follows:

Table 9: Tariff structure

| Particulars | Tariff Structure | |
|------------------------------|------------------|----------|
| Present energy charge | 6.14 | Rs./kVAh |
| Fuel Surcharge | 0.05 | Rs./kVA |
| Octroi Charge | 0.10 | Rs./kVAh |
| Municipality tax | 0.00 | Rs./kVAh |
| Electricity duty | 0.00 | Rs./kVAh |

(As per bill of Feb 2015)

Note: Since only monthly consumption was given by operating person verbally and no records were maintained for EB, hence the average value is taken for the evaluation which is correspondingly computed annually too.

Power factor

The utility bills of the unit reflect the average monthly power factor of the plant. A study was conducted by logging the main incomer and recording all the electrical parameters. The average power factor recorded was found to be 0.99.

Maximum demand

The average maximum demand recorded from electricity bill analysis was 885 kVA.

3.3.4 Self - generation

The unit has 2 DG sets for captive electricity generation as a back-up for grid electricity. The unit does not have a system for monitoring energy consumption and fuel usage in the DG. The DG performance test was conducted on two 125 kVA DG sets during the audit and specific fuel consumption (SFC) was calculated as 1.60 kWh / litre and 2.06 kWh / litre respectively. Diesel consumption by DG sets is 45000 liters annually costing Rs. 23.4 lakh with a power generation of 85,950 kWh.

Note: Since only monthly consumption was given by operating person verbally, hence the average value is taken for the evaluation which is correspondingly computed annually too.

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 26 of 71 | |

3.3.5 Month wise electricity consumption

Month wise total electrical energy consumption from different source is shown as under:

Table 10: Electricity consumption & cost

| Months | Electricity Used (kWh) | | | Electricity Cost, Rs. | | |
|---------------|------------------------|---------------|------------------|-----------------------|------------------|-------------------|
| | Grid kWh | DG kWh | Total kWh | Grid Rs. | DG Rs. | Total Rs. |
| Apr-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| May-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Jun-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Jul-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Aug-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Sep-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Oct-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Nov-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Dec-14 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Jan-15 | 350,708 | 7,163 | 357,870 | 2,241,272 | 195,000 | 2,436,272 |
| Feb-15 | 363,135 | 7,163 | 370,298 | 2,241,272 | 195,000 | 2,436,272 |
| Mar-15 | 338,280 | 7,163 | 345,443 | 2,241,272 | 195,000 | 2,436,272 |
| Total | 4,208,490 | 85,950 | 4,294,440 | 26,895,264 | 2,340,000 | 29,235,264 |

The month wise variation which is taken as an average for all the months as the bills were not provided by the unit is shown graphically in the figure below:

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 27 of 71 | |




Figure 6: Month wise variation in electricity consumption from different sources

As shown in the figure above, the consumption of electrical energy was on the higher side during the month of Feb 2015. However, it was noticed that electricity consumption during the month of Mar 2015 was less, which indicates that production during that month might have been low. The corresponding month wise variation in electricity cost is shown graphically in the figure below:




Figure 7: Month wise variation in electricity cost from different sources

The annual variation of cost of energy from utility as well as DG sets is shown in the figure below:

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 28 of 71 | |




Figure 8: Average cost of power (Rs./kWh) from different sources

From the above graph, it can be seen that the cost of electrical energy from DG sets is very high, nearly 3 times the cost of utility power.

3.4 Analysis of thermal consumption by the unit

The fuel used in forging furnace is FO whose cost is Rs 40 per liter. There was no meter installed for the measurement of fuel consumption in forging furnace. In the electroplating section, wood is used as fuel in boiler for generation of hot water. Load cell for measurement of wood consumption in boiler was not present. The data of fuel consumption and cost is given below:

Table 11: FO and wood used as fuel

| Month | FO (litre/month) | Cost Rs. | Wood (kg/month) | Cost Rs. |
|--------------|-------------------|-------------------|-----------------|------------------|
| Apr-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| May-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Jun-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Jul-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Aug-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Sep-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Oct-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Nov-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Dec-14 | 40,163 | 1606512 | 62,500 | 250,000 |
| Jan-15 | 40,163 | 1606512 | 62,500 | 250,000 |
| Feb-15 | 40,163 | 1606512 | 62,500 | 250,000 |
| Mar-15 | 40,163 | 1606512 | 62,500 | 250,000 |
| Total | 481,954 | 19,278,141 | 750,000 | 3,000,000 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 29 of 71 | |

The fuel consumption in furnace and boiler is considered constant, as no data was recorded and it is based on average value given by the unit personnel.

3.5 Specific energy consumption

Production data was available from the unit in metric tons (MT). Based on the available information, various specific energy consumption parameters have been estimated as shown in the following table. *It is to be noted here that though annual production value was provided, the monthly data for the same was not provided by the unit.*

Table 12: Overall specific energy consumption

| Parameters | Value | UoM |
|---|-----------|----------|
| Annual Grid Electricity Consumption | 4,208,490 | kWh |
| Annual DG Generation Unit | 85,950 | kWh |
| Annual Total Electricity Consumption | 4,294,440 | kWh |
| Diesel Consumption for Electricity Generation | 45000 | Litres |
| Annual Thermal Energy Consumption (FO) | 481,954 | Litre |
| Annual Thermal Energy Consumption (Wood) | 750,000 | kg |
| Annual Energy Consumption; MTOE | 1141.05 | MTOE |
| Annual Energy Cost | 515.13 | Rs. lakh |
| Annual Production | 5433 | MT |
| SEC; Electricity from Grid | 790 | kWh/MT |
| SEC; Thermal | 89 | Litre/MT |
| SEC; Overall | 0.210 | MTOE/MT |
| SEC; Cost Based | 9481 | Rs./MT |

Basis for estimation of energy consumption in terms of tons of oil equivalent are as follows:

- Conversion Factors
 - Electricity from the Grid : 860 kCal/KWh
 - 1koe : 10,000 kCal
- GCV of Diesel : 11840 kCal/ kg
- Density of HSD : 0.8263 kg/litre
- GCV of FO : 10,500 kCal/kg
- Density of FO : 0.9337 kg/litre
- GCV OF wood : 3,500 kCal/kg
- CO₂ Conversion factor
 - Grid : 0.89 kg/kWh
 - Diesel : 3.07 tons/ton
 - FO : 3.1 tons/litre

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 30 of 71 | |

3.6 Identified energy conservation measures in the plant

Diagnostic Study

A detailed study was conducted during the CEA in the unit. Observations regarding energy performance of various processes / equipments were recorded and a few ideas of EPIAs were developed. Summary of key observations is as follows:

3.6.1 Electricity Supply from Grid

The electrical parameters at the main incomer from PSPCL of the unit were recorded for 5 hours using a portable power analyzer. Following observation has been made:




Figure 9: Power factor and load profile

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 31 of 71 | |




Figure 10: Current and Voltage Profile




Figure 11: Harmonics profile

Table 13: Diagnosis of electric supply

| Name of Area | Present Set-up | Observations during field Study & measurements | Ideas for energy performance improvement actions |
|---------------------------|---|--|--|
| Electricity Demand | Power is supplied to this unit from PSPCL through a transformer. The unit has a HT connection. The contract | The maximum kVA identified from the electricity bill was 885.3 kVA which is less than the contract demand. | No EPIAs were suggested. |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 32 of 71 | |

| | | | |
|--------------------------|---|---|---------------------------|
| | demand of the unit is 1,225 kVA and sanctioned load is 1,577.27 kW. | | |
| Power Factor | The unit has a HT connection and billing is in kVAh. The utility bills reflect the PF of the unit. The unit has an APFC panel installed to control the power factor. | The average PF found during the measurement was 0.99. | No EPIA's were suggested. |
| Voltage variation | The supply to the plant is taken from two transformers. | The voltage profile of the unit was satisfactory. | No EPIA's suggested. |

In order to monitor the overall energy performance, the installation of a basic energy monitoring system has been proposed for the unit.

3.6.2 DG Performance

The unit has 2 DG sets for captive generation. The unit does not have a system for monitoring the energy generation and fuel usage in DG. The DG performance was done on two 125 kVA DG sets during the audit and specific fuel consumption (SFC) was calculated as 1.60 kWh / litre and 2.06 kWh / litre for DG-1 and DG-2 respectively. Diesel purchase records are maintained by the unit. As part of the performance testing, measurements were conducted on the DG sets by keeping track of the diesel consumed (by measuring the top up to the diesel tank) and recording of kWh generated during the same period. The key performance indicators of the DG sets were evaluated and Specific Fuel Consumption of the DG are as follows:




Figure 12: Power factor and load profile of DG set 1-125 kVA

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 33 of 71 | |




Figure 13: Voltage and current profile of DG Set 1-125 kVA




Figure 14: Energy and Harmonics profile of DG set 1- 125 KVA




Figure 15: Power factor and load profile of DG Set 2-125 KVA

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 34 of 71 | |




Figure 16: Voltage and current profile of DG set 2- 125 kVA




Figure 17: Harmonics and Energy profile of DG set 2-125 KVA

Table 14: Analysis of DG set

| Particulars | DG -1 | DG-2 |
|--|-------|------|
| Rated KVA | 125 | 125 |
| Specific Energy Generation Ratio (kWh/Litre) | 1.60 | 2.06 |

The observations made are as under:

| Parameters | Unit | DG#1 | DG#2 |
|-----------------------------|-----------|------|------|
| Capacity | kVA | 125 | 125 |
| Average Load | kW | 32 | 19 |
| Average Demand | kVA | 37 | 26 |
| Operating average PF | PF | 0.86 | 0.76 |
| Diesel Consumption | Litres/Hr | 4 | 4 |
| Loading Percentage | % | 30 | 21 |
| SEG | kWh/L | 2 | 2 |
| Specific unit cost | Rs./kWh | 31.3 | 24.3 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 35 of 71 | |

3.6.3 Electrical consumption areas

The details of the observations, measurements conducted and ideas generated for energy conservation measures are as follows:

| Name of Area | Present Set-up | Observations during field Study & measurements | Proposed Energy performance improvement actions | | | | | | | | | |
|---------------------------------------|---|---|---|------------------|-----------------|----------------------------|-------|-------|---|-------|------|--|
| Forging hammers | There are 5 hammer motors for forging with rating of 60 HP each. | <p>Study was conducted on a hammer motor 4</p> <p>The results of the study are as below:</p> <table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. Current (A)</th> <th>Avg. Power (kW)</th> </tr> </thead> <tbody> <tr> <td>Hammer #4</td> <td>41.54</td> <td>7.591</td> </tr> </tbody> </table> | Machine | Avg. Current (A) | Avg. Power (kW) | Hammer #4 | 41.54 | 7.591 | No EPIAs were suggested for forging hammers. | | | |
| Machine | Avg. Current (A) | Avg. Power (kW) | | | | | | | | | | |
| Hammer #4 | 41.54 | 7.591 | | | | | | | | | | |
| Broaching | Rated power of broaching machines used in the plant varies from 20 HP to 30 HP and study was conducted on machine # 11. | <p>It was found that during the unloading time power is consumed by motor which contributes to the total energy consumed.</p> <p>The results of the study are as below:</p> <table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>Avg. PF</th> </tr> </thead> <tbody> <tr> <td>Broaching #11</td> <td>3.21</td> <td>0.51</td> </tr> </tbody> </table> | Machine | Avg. kW | Avg. PF | Broaching #11 | 3.21 | 0.51 | VFD is suggested in broaching machine to reduce the power during unloading. | | | |
| Machine | Avg. kW | Avg. PF | | | | | | | | | | |
| Broaching #11 | 3.21 | 0.51 | | | | | | | | | | |
| Compressor | 3 air compressors were installed in the plant, which were the major source of energy consumption. | <p>FAD test was conducted on all the 3 compressors. 2 compressors were of reciprocating type and one compressor was of screw type.</p> <p>The results of the study are as below:</p> <table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>SPC (kW/CFM)</th> </tr> </thead> <tbody> <tr> <td>Compressor 1 ELGI 22 kW</td> <td>17.02</td> <td>0.08</td> </tr> <tr> <td>Compressor 2 Ingersoll 11.19 kW</td> <td>10.16</td> <td>0.21</td> </tr> </tbody> </table> | Machine | Avg. kW | SPC (kW/CFM) | Compressor 1 ELGI 22 kW | 17.02 | 0.08 | Compressor 2 Ingersoll 11.19 kW | 10.16 | 0.21 | <p>Leakage arresting on compressor number 1.</p> <p>Replacing compressor number 2 with screw compressor.</p> |
| Machine | Avg. kW | SPC (kW/CFM) | | | | | | | | | | |
| Compressor 1 ELGI 22 kW | 17.02 | 0.08 | | | | | | | | | | |
| Compressor 2 Ingersoll 11.19 kW | 10.16 | 0.21 | | | | | | | | | | |

| | | | |
|-------------------|---|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 36 of 71 |

| Name of Area | Present Set-up | Observations during field Study & measurements | | | Proposed Energy performance improvement actions | | | | | | | | | | | | | | | |
|------------------------|--|--|------|------|---|---------|---------|------------------|------|------|--------------------|-------|------|--------------------|-------|------|--------------------|-------|------|--------------------------|
| | | Compressor 3 Ingersoll 7.5 kW | 6.87 | 0.16 | | | | | | | | | | | | | | | | |
| Heat treatment section | In heat treatment section, the study was conducted on both hardening and tempering sections which consist of hardening heaters, tempering heaters, conveyor and blower motors. | <p>All heaters, blowers and conveyors were studied.</p> <p>The results of the study are as below:</p> <table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>Avg. PF</th> </tr> </thead> <tbody> <tr> <td>Hardening heater</td> <td>8.77</td> <td>0.99</td> </tr> <tr> <td>Tempering heater 1</td> <td>29.11</td> <td>0.99</td> </tr> <tr> <td>Tempering heater 2</td> <td>24.58</td> <td>1.00</td> </tr> <tr> <td>Tempering heater 3</td> <td>20.57</td> <td>0.99</td> </tr> </tbody> </table> | | | Machine | Avg. kW | Avg. PF | Hardening heater | 8.77 | 0.99 | Tempering heater 1 | 29.11 | 0.99 | Tempering heater 2 | 24.58 | 1.00 | Tempering heater 3 | 20.57 | 0.99 | No EPIAs were suggested. |
| Machine | Avg. kW | Avg. PF | | | | | | | | | | | | | | | | | | |
| Hardening heater | 8.77 | 0.99 | | | | | | | | | | | | | | | | | | |
| Tempering heater 1 | 29.11 | 0.99 | | | | | | | | | | | | | | | | | | |
| Tempering heater 2 | 24.58 | 1.00 | | | | | | | | | | | | | | | | | | |
| Tempering heater 3 | 20.57 | 0.99 | | | | | | | | | | | | | | | | | | |

3.6.4 Thermal consumption areas

As discussed in the earlier section, about 18 % of energy cost and 30% of the energy was being used in the forging furnace. The details of present set-up, key observations made and potential areas for energy cost reduction have been mentioned in the table below:

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 37 of 71 | |

| Name of Area | Present Set-up | Observations during field Study & measurements | Proposed Energy performance improvement actions |
|----------------|---|--|--|
| Furnace | The fuel used for heating in furnace is FO. | There was no metering system available for measuring fuel consumption. | Installation of flow meters are recommended. |
| | The required air for burning of fuel is supplied by electrical driven blower fan. | The O ₂ level in flue gas at the outlet of furnace 2, 4 and 5 was above 10 %. | Installation of PID for excess air control. |
| | The insulation provided in furnace was poor. | The temperature of furnace surface walls was high which clearly indicates that insulation is poor. | Reduction of skin losses by using high refractory materials. |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 38 of 71 | |

4 EE TECHNOLOGY OPTIONS AND TECHNO – ECONOMIC FEASIBILITY

During CEA of the plant, all energy consuming equipments and processes were studied. The analysis of all major energy consuming equipment and appliances were carried out which has already been discussed in earlier section of this report.

Based on the analysis, Energy Performance Improvement Actions (EPIA) has been identified as below:

4.1 EPIA 1, 2 & 3: Excess air control using PID

Technology description

It is necessary to maintain optimum excess air levels in combustion air supplied for proper combustion of the fuel. The excess air levels are calculated based on oxygen content in the flue gases. The theoretical air required for combustion of any fuel can be known from the ultimate analysis of the fuel. All combustion processes require a certain amount of excess air in addition to the theoretical air supplied. Excess air supplied needs to be maintained at optimum levels, as too much of excess air results in excessive heat loss through the flue gases. On the other hand, too little excess air results in incomplete combustion of fuel and formation of black coloured smoke in flue gases.

Generally, in most of the furnaces, fuel is fired with too much of excess air. This results in formation of excess flue gases, taking away the heat produced from the combustion and increasing the fuel consumption. This also results in formation of excess GHG emissions. The excess air effects on the formation of ferrous oxide resulting in increase in the burning losses.

A PID controller, if installed, will measure the oxygen levels in the flue gases at the exit of the furnace, and based on that the combustion air flow from FD fan (blower) can be regulated. Subsequently, proper temperature and optimum excess air can be attained in the furnace.

Study and investigation

At the time of CEA, it was found that there was no proper automation and control system installed to maintain the optimum excess air levels. Fuel was fired from the existing burner and no air flow control mechanism was in place for maintaining proper combustion of the fuel. It was found that the oxygen level in furnace 1, furnace 2 and furnace 3 were 12.48 %, 11.60 % and 10.00 % respectively, which indicate very high excess air levels. This results in high heat loss due to dry flue gas from the furnace.

Recommended action

It is recommended to install PID control system to regulate the supply of excess air for maintaining optimum excess air levels and ensuring complete combustion. As a thumb rule, reduction in every

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 39 of 71 | |

10% of excess air will save 1% in specific fuel consumption. The cost benefit analysis of the energy conservation measure is given below:

Table 15: Cost benefit analysis (EPIA 1) – Forging furnace 8

| Parameters | UOM | Present | Proposed |
|--|--------------|---------|----------|
| Production of material | Tph | 0.22 | 0.22 |
| Oxygen level in flue gas | % | 12.48 | 4.00 |
| Excess air control | % | 146.48 | 23.53 |
| Dry flue gas loss | % | 53.58 | |
| Specific fuel consumption | kg/t | 57.89 | 50.77 |
| Savings in specific fuel consumption | kg/h | | 1.58 |
| Operating hours of forging furnace | hr/y | 6,600 | 6,600 |
| Saving in fuel consumption per year | kg/y | | 10429.04 |
| Savings in fuel cost | Rs. lakh/y | | 4.47 |
| Installed capacity of blower | kW | 3.73 | 3.73 |
| Running load of blower | kW | 2.98 | 2.69 |
| Operating hours | hr/y | 6,600 | 6,600 |
| Electrical energy consumed | kWh/y | 19,694 | 17,725 |
| Savings in terms of power consumption | kWh/y | | 1,969 |
| Savings in terms of cost of electrical energy | Rs. lakh / y | | 0.13 |
| Reduction in the burning loss inside the furnace | % | | 0.50 |
| Total material savings | tpy | | 7.33 |
| Cost of saved material | Rs. lakh / y | | 3.66 |
| Monetary savings | Rs. lakh/y | | 8.26 |
| Estimated investment | Rs. lakh | | 7.00 |
| Simple payback | Years | | 0.85 |

Table 16: Cost benefit analysis (EPIA 2) - Forging furnace-4

| Parameters | UOM | Present | Proposed |
|-------------------------------------|------------|---------|----------|
| Production of material | Tph | 0.15 | 0.15 |
| Oxygen level in flue gas | % | 11.60 | 4.00 |
| Excess air control | % | 123.40 | 23.53 |
| Dry flue gas loss | % | 45.71 | |
| Specific fuel consumption | kg/t | 101.13 | 91.91 |
| Saving in specific fuel consumption | kg/h | | 1.50 |
| Operating hrs of forging furnace | hr/y | 6,600 | 6,600 |
| Saving in fuel consumption per year | kg/y | | 9883.73 |
| Savings in fuel cost | Rs. lakh/y | | 4.23 |
| Installed capacity of blower | kW | 3.73 | 3.73 |
| Running load of blower | kW | 2.98 | 2.69 |
| Operating hours | hr/y | 6,600 | 6,600 |
| Electrical energy consumed | kWh/y | 19694 | 17724.96 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 40 of 71 | |

| | | |
|--|--------------|---------|
| Savings in terms of power consumption | kWh/y | 1969.44 |
| Savings in terms of cost of electrical energy | Rs. lakh/y | 0.99 |
| Reduction in the burning loss inside the furnace | % | 0.80 |
| Total material saving | TPY | 7.81 |
| Cost of saved material | Rs. lakh / y | 3.91 |
| Monetary savings | Rs. lakh / y | 9.13 |
| Estimated investment | Rs. lakh | 7.00 |
| Simple payback | Years | 0.77 |

Table 17: Cost benefit analysis (EPIA 3) – Forging furnace 5

| Parameters | UOM | Present | Proposed |
|--|------------|-----------|-----------|
| Production of material | tph | 0.09 | 0.09 |
| Oxygen level in flue gas | % | 10.00 | 4.00 |
| Excess air control | % | 90.91 | 23.53 |
| Dry flue gas loss | % | 53.60 | |
| Specific fuel consumption | kg/t | 109.53 | 102.15 |
| Saving in specific fuel consumption | kg/h | | 0.65 |
| Operating hrs of forging furnace | hr/y | 6,600 | 6,600 |
| Saving in fuel consumption per year | kg/y | | 4286.55 |
| Savings in fuel cost | Rs. lakh/y | | 1.84 |
| Installed capacity of blower | kW | 3.73 | 3.73 |
| Running load of blower | kW | 2.98 | 2.69 |
| Operating hours | hrs/y | 6,600 | 6,600 |
| Electrical energy consumed | kWh/y | 19,694.40 | 17,724.96 |
| Savings in terms of power consumption | kWh/y | | 1,969.44 |
| Savings in terms of cost of electrical energy | Rs. lakh/y | | 0.13 |
| Reduction in the burning loss inside the furnace | % | | 0.80 |
| Total material savings | tpy | | 4.65 |
| Cost of saved material | Rs. lakh/y | | 2.32 |
| Monetary savings | Rs. lakh/y | | 4.29 |
| Estimated investment | Rs. lakh | | 7.00 |
| Simple payback | Years | | 1.63 |

4.2 EPIA 4: Reduction in radiation and convection losses from surfaces of forging furnace 4 and 5

Technology description

A significant portion of the losses in a furnace occurs as radiation loss from the furnace walls and the roof. These losses are substantially higher in areas of openings or in case of infiltration of cold air in

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 41 of 71 | |

some of the furnaces. Ideally, optimum amount of refractory and insulation should be provided in the furnace walls and the roof to maintain the surface temperature of the furnace at around 50-60 °C to avoid heat loss due to radiation and convection. Refractories are heat-resistant materials that constitute the linings for high-temperature furnaces and other processing units. In addition to being resistant to thermal stress and other physical phenomena induced by heat, refractories must also withstand physical wear and corrosion by chemical agents.

Thermal insulations are used to get reduction of heat transfer between objects in thermal contact or in range of radiative influence.

The furnace walls are designed in combination of refractories and insulation layers, with the objective of retaining maximum heat inside the furnace and avoiding losses from the furnace walls.

Study and investigation

The average temperature of furnace surface has to be about 10°C above ambient temperature, i.e. about 45-50°C. During audit, the furnace surface temperature was 70.48°C in furnace 4 & 76.04°C in furnace 5, which implicates that both the furnaces need to be properly insulated to keep the surface temperature within the specified range.

Recommended action

Recommended furnace surface temperature has to be brought to within 45-50°C to reduce the heat loss through radiation and convection and utilize the useful heat.

In the below table, the amount of heat lost through radiation and convection in firing zone of furnace 4 and furnace 5 is given.

Table 18: R & C losses

| Parameters | UOM | Forging-4 | Forging-5 |
|---|---------------------------|-----------|-----------|
| Natural convection heat transfer rate from sidewall surfaces | kCal/m ² deg C | 1.5 | 1.5 |
| External temp. of hearth | deg C | 70 | 76 |
| Hearth surface area | m ² | 3.85 | 2.50 |
| Room temperature | deg C | 33 | 33 |
| Recommended temperature | deg C | 50 | 50 |
| Loss at current situation | kCal/hr | 1,018 | 783 |
| Loss after insulation | kCal/hr | 396 | 257 |
| Temperature at current condition | deg C | 70 | 76 |
| Operating hours | hr/y | 6,600 | 6,600 |

Table 19: Cost benefit analysis (EPIA 4)

| Parameters | UOM | Forging-4 | | Forging-5 | |
|------------------------------|-------|-----------|----------|-----------|----------|
| | | Present | Proposed | Present | Proposed |
| Temperature of hearth | deg C | 70.48 | 50.00 | 76.04 | 50.00 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 42 of 71 | |

| | | | | | |
|-----------------------------------|----------------|----------|--------|--------|--------|
| Total hearth area | m ² | 3.86 | 3.86 | 2.50 | 2.50 |
| Heat loss from surface | kCal/hr | 1,018.44 | 396.38 | 783.04 | 257.22 |
| Reduction in heat loss | kCal/hr | | 622.06 | | 525.82 |
| Savings in fuel | kg/hr | | 0.06 | | 0.05 |
| Operating hours of furnace | hr/y | 6,600 | 6,600 | 6,600 | 6,600 |
| Savings in fuel per year | kg/y | | 376.66 | | 318.39 |
| Monetary savings | Rs. lakh | | 0.16 | | 0.14 |
| Estimated investment | Rs. lakh | | 0.06 | | 0.04 |
| Simple payback period | Years | | 0.36 | | 0.28 |

4.3 EPIA 5: Installation of VFD on broaching machine

Technology description

For fluctuating loads it is always recommended to install a variable frequency drive (VFD) to control the speed of the motor. A VFD will reduce the power consumption accordingly to the load variation in the broaching machine. During loading periods, the current drawn by the broaching machine will be very high, as an external force is also applied for the process to take place. During no load / unloading periods, the motor of broaching machine will draw some current which is 1/3 or 1/4th of the total current. Hence, this drawn current can be reduced by installing VFD. The installation of a VFD will help in regulating the speed of the broaching machine's motor, thereby resulting in lower current drawn and reduction in power consumption.

Study and investigation

During measurements, it was found that the existing broaching machine No – 11 draws high current even during unloading periods.

Recommended action

It is recommended to install VFD with the broaching machine No. 11. This will ensure that the machine draws minimal current during unloading. The cost benefit analysis of the energy conservation measure is given below:

Table 20: Cost benefit analysis (EPIA 5)

| Sl. No. | VFD on broaching machine | | Broaching M/c-11 | |
|---------|---|------|------------------|-------|
| | Parameters | Unit | As Is | To Be |
| 1 | Installed capacity of motor | kW | 14.92 | 14.92 |
| 2 | Estimated energy saving by installing VFD on compressor | % | | 20.0 |
| 3 | Average power consumption | kW | 3.3 | 3 |
| 4 | Percentage load | % | 22.2 | 17.8 |
| 4 | No of operating hours per day | hr | 24.00 | 24 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 43 of 71 | |

| | | | | |
|----|--|----------|--------|-------|
| 5 | Operating days per Year | days | 300.00 | 300 |
| 6 | Average electricity consumption per year | kWh | 26259 | 21007 |
| 7 | Savings in terms of power consumption | kWh/y | | 5252 |
| 8 | Average weighted cost | Rs./kWh | 6.67 | 6.67 |
| 9 | Monetary savings | Rs. lakh | | 0.35 |
| 10 | Estimated investment | Rs. lakh | | 0.8 |
| 11 | Simple Payback | Years | | 2.3 |

4.4 EPIA 6: Replacing old conventional ceiling fans with EE fans

Technology description

Replacing old fans of conventional types installed in various sections of the plant with energy efficient fans will reduce power consumption by half. The energy efficient fans have a noiseless operation and are controlled by electronic drives which on speed reduction automatically sense the rpm and reduce power consumption.

Study and investigation

The unit is having about 135 fans which are very old and are recommended to be replaced with energy efficient fans.

Recommended action

It is recommended to replace the existing fans with energy efficient fans. The cost benefit analysis of the same is given in the table below:

Table 21: Cost benefit analysis (EPIA 6)

| Data & Assumptions | UOM | Ordinary fan | Super fan |
|---------------------------------------|------------|--------------|-----------|
| Number of fans in the facility | Nos. | 135 | 135 |
| Run hours per day | hr / day | 18 | 18 |
| Power consumption at maximum speed | Watts | 75 | 35 |
| Number of working days/year | Days | 330 | 330 |
| Average Weighted cost | Rs. / kWh | 6.67 | 6.67 |
| Fan unit price | Rs. / pc | 1,500 | 3,000 |
| Electricity consumption: | | | |
| Electricity demand | kW | 10.80 | 4.73 |
| Power consumption by fans in a year | kWh/y | 64,152 | 28,067 |
| Savings in terms of power consumption | kWh/y | | 36,086 |
| Monetary savings | Rs. Lakh/y | | 2.41 |
| Estimated investment | Rs. Lakh/y | | 4.05 |
| Payback period | Years | | 1.68 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 44 of 71 | |

4.5 EPIA 7 & 8: Replacing present conventional lights with Energy Efficient light fixtures

Technology description

Replacing conventional lights like T-12s, CFLs etc with LED lights helps reduce power consumption and also results in higher illumination (lux) levels for the same power consumption.

Study and investigation

The unit is having about 50 nos. T12 tube lights, 87 nos. 45W CFL, 20 nos. 23W CFL and 9 nos. 250W halogens lamp.

Recommended action

All light fixtures have to be replaced with energy saving LED lamps which can reduce energy consumption immensely, and for T12 tube lights, retrofit LED lights can be obtained.

The savings assessment has been given in the table below:

Table 22: Cost benefit analysis (EPIA 7)

| Particulars | Unit | Existing | Proposed |
|--------------------------------------|--------------|----------|------------------------|
| Fixture | UOM | T-12 | 16 Watt LED tube light |
| Power consumed of T-12 | W | 40 | 16 |
| Power consumed | W | 12 | 0 |
| Total power consumption | W | 52 | 16 |
| Operating hours/day | Hr | 18 | 18 |
| Annual days of operation | day | 330 | 330 |
| Energy Used per year/fixture | kWh | 309 | 95 |
| Average weighted cost | Rs./kWh | 6.67 | 6.67 |
| No. of Fixtures | Nos. | 50 | 50 |
| Power consumption per year | kWh/y | 15,444 | 4,752 |
| Operating cost per year | Rs. lakh / y | 1.03 | 0.32 |
| Saving in terms of power consumption | kWh/y | | 10,692 |
| Monetary savings | Rs. lakh/y | | 0.71 |
| Investment per fixture of LED | Rs. | | 1,675 |
| Investment of project | Rs. lakh | | 0.83 |
| Payback period | Years | | 1.17 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 45 of 71 | |

Table 23: Cost benefit analysis (EPIA 8)

| Particulars | Unit | Existing | Proposed | Existing | Proposed | Existing | Proposed |
|--------------------------------------|------------|----------|--------------------------------|----------|-----------------------|---------------|-----------------------|
| | | 45 W CFL | 18 Watt LED Square Round Panel | 23 W CFL | 10 Watt LED Star Bulb | 250 W MV lamp | 80 Watt LED Bay light |
| Power consumed | W | 65 | 25 | 50 | 18 | 250 | 80 |
| Operating hours/day | hr | 18 | 18 | 18 | 18 | 18 | 18 |
| Annual days of operation | day | 330 | 330 | 330 | 330 | 330 | 330 |
| Energy Used per year/fixture | kWh | 463 | 149 | 362 | 107 | 1,148 | 317 |
| Average weighted cost | Rs/kWh | 6.67 | 6.67 | 6.67 | 6.67 | 6.94 | 6.94 |
| No. of Fixtures | Nos. | 87 | 87 | 20 | 20 | 9 | 9 |
| Power consumption per year | kWh/y | 40309 | 12920 | 7247 | 2138 | 10336 | 2851 |
| Operating cost per year | Rs. lakh/y | 2.69 | 0.86 | 0.48 | 0.14 | 0.72 | 0.20 |
| Saving in terms of power consumption | kWh/y | 27389 | | 5108 | | 7484 | |
| Monetary savings | Rs. lakh/y | 1.83 | | 0.34 | | 0.52 | |
| Investment per fixture of LED | Rs. | 0.04 | | 0.0235 | | 0.123 | |
| Investment of project | Rs. lakh | 3.48 | | 0.47 | | 1.107 | |
| Payback period | Years | 1.90 | | 1.38 | | 2.13 | |

4.6 EPIA 9: Leakage arrest in compressor 1

Technology description

Leakage test was conducted on compressor by filling the receiver tank and closing all the valves at user end so that air from tank will reach the point of usage but will not be utilized. During this time, the loading and unloading time of compressor is noted. The entire amount of air that is used during this period will be due to leakage.

Study and investigation

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 46 of 71 | |

Leakage test was conducted on the air compressor and total leakage was established at about 24%.

Recommended action

It is recommended to check all the pipes and valves and arresting all leakages, if any. This activity needs to be conducted periodically as a planned maintenance schedule. The cost benefit analysis for installation of energy monitoring system in the unit is given below in the table:

Table 24: Cost benefit analysis (EPIA 9)

| Parameters | Unit | AS IS | TO BE |
|--|----------------------|--------|--------|
| Cut in Pressure | kg/cm ² | 6.5 | 6.5 |
| Cut out Pressure | kg/cm ² | 6.9 | 6.9 |
| Free Air Discharge | Nm ³ /Min | 5.70 | 5.70 |
| Average Load time (T) | Min | 2.32 | - |
| Average Unload time (t) | Min | 7.016 | - |
| Leakage Quantity | Nm ³ /min | 1.41 | 0.57 |
| Average Operating Power | kW | 16 | 16 |
| Specific Energy Consumption | kW/Nm ³ | 0.05 | 0.05 |
| Operating Requirements | hr/day | 20 | 20 |
| Operating Requirements | day/y | 300 | 300 |
| Annual Energy Consumption | kWh/y | 23,121 | 9,315 |
| Savings in terms of power consumption | kWh/y | - | 13,806 |
| Weighted Average Cost | Rs./kWh | | 7 |
| Monetary Savings | Rs. lakh/ y | | 0.92 |
| Estimated Investment | Rs. lakh | | 0.10 |
| Payback Period | Years | | 0.11 |

4.7 EPIA 10: Replacement of reciprocating compressor No. 2 with screw compressor

Technology description

Free air delivery test was conducted on compressor No. 2 by emptying the compressor receiver (of a known volume) and closing its outlet valve. The compressor was started and the receiver tank was filled from its initial pressure to final pressure and time taken to fill the tank was recorded. Power consumed by the compressor during this time was also recorded. Based on this test, the specific power consumption of compressor was estimated. For an efficient compressor, the SPC should be in the range of 0.17 – 0.18 kW/CFM.

Study and investigation

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 47 of 71 | |

The FAD test established that the SPC of this compressor was 0.21 kW / CFM and it was on the higher side.

Recommended action

It is recommended to replace the old reciprocating compressor with a new energy efficient screw compressor in order to reduce the SPC.

The cost benefit analysis of the energy conservation measure is given below:

Table 25: Cost benefit analysis (EPIA 10)

| Parameters | Unit | AS IS | TO BE |
|--|--------------------|--------|---------|
| Design Pressure | kg/cm ² | 12.3 | 12.30 |
| Average Receiver Pressure | kg/cm ² | 12.3 | 12.3 |
| Operating Pressure (Compressor Panel Reading) | kg/cm ² | 12.3 | 12.3 |
| Specific Power Consumption | kW/CFM | 0.21 | 0.17 |
| Average Air Required | CFM | 47.3 | 47.3 |
| Average Power Consumption | kW | 10 | 8.04 |
| Size of Compressor | CFM | 50 | 50 |
| Loading on Compressor | % | 95 | 95 |
| Running hours per day | hr/day | 24 | 24 |
| Annual operating days | days/y | 300 | 300 |
| Annual Energy Consumption | kWh/y | 73,174 | 57,871 |
| Savings in terms of power consumption | kWh/y | - | 15302.6 |
| Average weighted Cost | Rs./kWh | | 6.67 |
| Monetary Savings | Rs. lakh/y | | 1.0 |
| Investment | Rs. lakh | | 3 |
| Years | Years | | 2.9 |

4.8 EPIA 11: Replacement of present inefficient DG set with new EE DG set

Technology description

The replacement of DG with new DG helps in increasing the specific energy generation ratio, i.e. units of electricity generated from 1 litre of diesel. Normally, the standard specific fuel consumption (SFC) given for new DG is 3.5 kWh/litre.

Study and investigation

The SFC of 125 kVA DG was established to be 1.60 kWh / litre which is very low as per standards.

Recommended action

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 48 of 71 | |

It is recommended to replace the 125 kVA DG with new DG having SEGR of 3.5 kWh / litre. The cost benefit analysis of the DG replacement is given in the table below:

Table 26: Cost benefit analysis (EPIA 11)

| Parameters | UOM | AS IS | TO BE |
|-----------------------------|-----------|---------|---------|
| Rated kVA | kVA | 125 | 125 |
| Operating Hours | hr | 1500 | 1500 |
| No of Units generated | kWh/y | 9498.01 | 9498.01 |
| Annual Diesel Consumption | Litres | 5946.09 | 2713.72 |
| Specific Energy Consumption | kWh/litre | 1.60 | 3.5 |
| Annual Diesel saving | Liters/y | | 3232 |
| Diesel Cost | Rs./litre | | 50 |
| Investment | Rs. lakh | | 7.61 |
| Monetary Savings | Rs. lakh | | 1.62 |
| Simple Payback | Years | | 4.71 |

4.9 EPIA 12: Replacement of present inefficient burners with new EE burners

Technology description

The EE burners are decided on the basis of furnace temperature, dimensions and the production. They have a film technology, where each droplet of oil is surrounded by the air increasing the surface area exposed to air resulting in efficient burning. Hence, the fuel consumption is reduced.

Study and investigation

The present fuel firing for the given production was high. It was monitored during the CEA that production of most of the furnaces was much lower than their standard capacity.

Table 27: Furnace specifications for the EE burners

| Parameters | UoM | Forging furnace-2 | Forging furnace-3 | Forging furnace-4 | Forging furnace-5 | Forging furnace-8 |
|---------------------|-----------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Fuel Firing rate | Liters/hr | 69.116 | 77.522 | 100.872 | 52.304 | 207.348 |
| Production | kg/hr | 106.00 | 122.00 | 148.00 | 88.00 | 222.00 |
| Area of the furnace | m2 | 2.3484 | 2.2134 | 3.857 | 2.5029 | 3.6309 |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 49 of 71 | |

Recommended action

It is recommended to replace inefficient burners with new EE burners. The cost benefit analysis of burner replacement is given in the table below:

Table 28: Cost benefit analysis (EPIA 12)

| Replacing present burners with energy efficient burners | | Forging furnace-2 | | Forging furnace-3 | | Forging furnace-4 | | Forging furnace-5 | | Forging furnace-8 | |
|---|-------------|-------------------|-------|-------------------|-------|-------------------|-------|-------------------|-------|-------------------|-------|
| Parameters | Unit | As Is | To Be | As Is | To Be | As Is | To Be | As Is | To Be | As Is | To Be |
| Production rate of the forging furnace | kg/hr | 106 | 106 | 122 | 122 | 148 | 148 | 88 | 88 | 222 | 222 |
| Total numbers of burners | Nos. | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Total numbers of energy efficient burner required | Nos. | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Estimated saving by energy efficient burner | % | 5.0 | | 5.0 | | 5.0 | | 5.0 | | 5.0 | |
| Current fuel firing in forging furnace | kg/hr | 8 | 8 | 9 | 9 | 13 | 12 | 8 | 8 | 11 | 11 |
| Savings in fuel per hours | kg/hr | 0.42 | | 0.47 | | 0.65 | | 0.42 | | 0.56 | |
| Number of operating days | days | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 |
| Number of operating hours per day | hrs | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 |
| Total savings per year into fuel firing | kg/yr | 2773 | | 3081 | | 4314 | | 2773 | | 3697 | |
| Unit cost of fuel | Rs./kg | 42.84 | | 42.84 | | 42.84 | | 42.84 | | 42.84 | |
| Monetary savings | Lakh Rs./yr | 1.19 | | 1.32 | | 1.85 | | 1.19 | | 1.58 | |
| Estimated investment for all burners | Lakh Rs. | 0.2 | | 0.2 | | 0.2 | | 0.2 | | 0.2 | |
| Payback period | Yr | 0.2 | | 0.2 | | 0.1 | | 0.2 | | 0.2 | |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 50 of 71 | |

5 ANNEXURE

Furnace 2 efficiency calculations

Input parameters

| Input Data Sheet | | |
|---|--------------|---------------|
| Type of Fuel | | Furnace Oil |
| Source of fuel | Local vendor | |
| | Value | Units |
| Furnace Operating temperature (Heating Zone) | 1100 | Deg C |
| Final temperature of material (at outlet of Heating zone) | 1048 | Deg C |
| Initial temperature of material | 35 | Deg C |
| Average fuel Consumption | 9.6 | kg/hr |
| Flue Gas Details | | |
| Flue gas temperature | 562 | deg C |
| Preheated air temperature | 110 | deg C |
| O ₂ in flue gas | 6.2 | % |
| CO ₂ in flue gas | 12.36 | % |
| CO in flue gas | 19.4 | Ppm |
| Atmospheric Air | | |
| Ambient Temperature | 35 | Deg C |
| Relative Humidity | 45.6 | % |
| Humidity in ambient air | 0.03 | kg/kg dry air |
| Fuel Analysis | | |
| C | 84.00 | % |
| H | 12.00 | % |
| N | 0.00 | % |
| O | 1.00 | % |
| S | 3.00 | % |
| Moisture | 0.00 | % |
| Ash | 0.00 | % |
| Weighted Average GCV of Fuel | 10,500 | kcal/kg |
| Ash Analysis | | |
| Unburnt in bottom ash | 0.00 | % |
| Unburnt in fly ash | 0.00 | % |
| GCV of bottom ash | 0 | kCal/kg |
| GCV of fly ash | 0 | kCal/kg |
| Material and flue gas data | | |
| Weight of material (Raw material) being heated in furnace | 106 | Kg/Hr |
| Weight of Stock | 106 | kg/hr |
| Specific heat of material | 0.12 | Kcal/kgdegC |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 51 of 71 | |

| | | |
|---|--------|-------------|
| Avg. specific heat of fuel | 0.417 | Kcal/kgdegC |
| fuel temperature | 70 | deg C |
| Specific heat of flue gas | 0.26 | Kcal/kgdegC |
| Specific heat of superheated vapour | 0.45 | Kcal/kgdegC |
| Heat loss from surfaces of various zone | | |
| For Ceiling | | |
| Natural convection heat transfer rate from ceiling | 2.8 | Kcal/m2degC |
| External temp. of ceiling | 346 | deg K |
| Room Temperature | 308 | deg K |
| Ceiling surface area | 3.55 | m2 |
| Emissivity of furnace body surface | 0.75 | |
| For side walls | | |
| Natural convection heat transfer rate from sidewall surfaces | 2.2 | Kcal/m2degC |
| External temperature of side walls | 318 | deg K |
| Sidewall surface area | 7.8828 | m2 |
| For Hearth | | |
| Natural convection heat transfer rate from flue gas duct surfaces | 1.5 | Kcal/m2degC |
| External temperature. of side walls | 315.81 | deg K |
| External surface area | 2.3484 | m2 |
| Outside dia of flue gas duct | 0.15 | M |
| For radiation loss in furnace(through charging and discharging door) | | |
| Time duration for which the material enters through preheating zone and exits through Furnace | 1 | Hr |
| Area of opening in m2 | 0.3111 | m2 |
| Coefficient based on profile of furnace opening | 0.7 | |
| Maximum temperature of air at furnace door | 428 | deg K |

Efficiency calculations

| Calculations | Values | Unit |
|------------------------------------|---------|----------------------------|
| Theoretical Air Required | 14.01 | kg/kg of fuel |
| Excess Air supplied | 41.89 | % |
| Actual Mass of Supplied Air | 19.87 | kg/kg of fuel |
| Mass of dry flue gas | 19.79 | kg/kg of fuel |
| Amount of Wet flue gas | 20.87 | Kg of flue gas/kg of fuel |
| Amount of water vapour in flue gas | 1.08 | Kg of H2O/kg of fuel |
| Amount of dry flue gas | 19.79 | kg/kg of fuel |
| Specific Fuel consumption | 90.93 | kg of fuel/ton of material |
| Heat Input Calculations | | |
| Combustion heat of fuel | 954,814 | Kcal/ton of material |
| Sensible heat of fuel | 1,321 | Kcal/ton of material |
| Total heat input | 956,134 | Kcal/ton of material |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 52 of 71 | |

| Heat Output Calculation | | |
|---|--------------|----------------------|
| Heat carried away by 1 ton of material (useful heat) | 127,780 | Kcal/ton of material |
| Heat loss in dry flue gas per ton of material | 246,609 | Kcal/ton of material |
| Loss due to H ₂ in fuel | 80,642 | Kcal/ton of material |
| Loss due to moisture in combustion air | 141 | Kcal/ton of material |
| Loss due to partial conversion of C to CO | 68 | Kcal/ton of material |
| Loss due to convection and radiation (openings in furnace - inlet & outlet door of furnace) | 1,977 | Kcal/ton of material |
| Loss Due to Evaporation of Moisture Present in Fuel | - | Kcal/ton of material |
| Total heat loss from furnace body | 21,102 | Kcal/ton of material |
| Heat loss due to unburnts in Fly ash | - | Kcal/ton of material |
| Heat loss due to unburnts in bottom ash | - | Kcal/ton of material |
| Unaccounted heat lossess | 477,816 | Kcal/ton of material |
| Heat loss from furnace body and ceilings | | |
| Heat loss from furnace body ceiling surface | 1615 | Kcal/hr |
| Heat loss from furnace body side walls surfaces | 522 | Kcal/hr |
| Heat loss from hearth | 100 | Kcal/hr |
| Total heat loss from furnace body | 21102 | Kcal/tons |
| Furnace Efficiency | 13.38 | % |




Figure 18: Sankey diagram furnace 2

Furnace 3 efficiency calculations

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 53 of 71 | |

Input Data Sheet

| | | |
|---|--------------|---------------------|
| Type of Fuel | | Furnace Oil |
| Source of fuel | Local vendor | |
| | Value | Units |
| Furnace Operating temperature (Heating Zone) | 1150 | <i>Deg C</i> |
| Final temperature of material (at outlet of Heating zone) | 1150 | <i>Deg C</i> |
| Initial temperature of material | 37 | <i>Deg C</i> |
| Average fuel Consumption | 10.7 | <i>Kg/hr</i> |
| Flue Gas Details | | |
| Flue gas temperature | 672 | <i>deg C</i> |
| Preheated air temperature | 110 | <i>deg C</i> |
| O2 in flue gas | 8 | % |
| CO2 in flue gas | 10.3 | % |
| CO in flue gas | 12.4 | <i>ppm</i> |
| Atmospheric Air | | |
| Ambient Temperature | 37 | <i>Deg C</i> |
| Relative Humidity | 45.6 | % |
| Humidity in ambient air | 0.03 | <i>kg/kgdry air</i> |
| Fuel Analysis | | |
| C | 84.00 | % |
| H | 12.00 | % |
| N | 0.00 | % |
| O | 1.00 | % |
| S | 3.00 | % |
| Moisture | 0.00 | % |
| Ash | 0.00 | % |
| Weighted Average GCV of Fuel-mix | 10500 | kcal/kg |
| Ash Analysis | | |
| Unburnt in bottom ash | 0.00 | % |
| Unburnt in fly ash | 0.00 | % |
| GCV of bottom ash | 0 | kCal/kg |
| GCV of fly ash | 0 | kCal/kg |
| Material and flue gas data | | |
| Weight of material (Raw material) being heated in furnace | 122 | <i>Kg/Hr</i> |
| Weight of Stock | 122 | <i>kg/hr</i> |
| Specific heat of material | 0.12 | <i>Kcal/kgdegC</i> |
| Average specific heat of fuel | 0.417 | <i>Kcal/kgdegC</i> |
| fuel temp | 70 | <i>deg C</i> |
| Specific heat of flue gas | 0.26 | <i>Kcal/kgdegC</i> |
| Specific heat of superheated vapour | 0.45 | <i>Kcal/kgdegC</i> |
| Heat loss from surfaces of various zone | | |
| For Ceiling | | |
| Natural convection heat transfer rate from ceiling | 2.8 | <i>Kcal/m2degC</i> |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 54 of 71 | |

| | | |
|---|--------|--------------------------|
| External temp. of ceiling | 365 | deg K |
| Room Temperature | 310 | deg K |
| Ceiling surface area | 3.43 | m ² |
| Emissivity of furnace body surface | 0.75 | |
| For side walls | | |
| Natural convection heat transfer rate from sidewall surfaces | 2.2 | Kcal/m ² degC |
| External temperature of side walls | 329 | deg K |
| Sidewall surface area | 8.4419 | m ² |
| For Hearth | | |
| Natural convection heat transfer rate from flue gas duct surfaces | 1.5 | Kcal/m ² degC |
| External temperature of side walls | 335 | deg K |
| External surface area | 2.2134 | m ² |
| Outside dia of flue gas duct | 0.15 | m |
| For radiation loss in furnace(through charging and discharging door) | | |
| Time duration for which the material enters through preheating zone and exits through Furnace | 1 | Hr |
| Area of opening in m ² | 0.4392 | m ² |
| Coefficient based on profile of furnace opening | 0.7 | |
| Maximum temperature of air at furnace door | 464 | deg K |

Efficiency calculations

| Calculations | Values | Unit |
|--|---------|-----------------------------------|
| Theoretical Air Required | 14.01 | kg/kg of fuel |
| Excess Air supplied | 56.02 | % |
| Actual Mass of Supplied Air | 21.85 | kg/kg of fuel |
| Mass of dry flue gas | 21.77 | kg/kg of fuel |
| Amount of Wet flue gas | 22.85 | Kg of flue gas/kg of fuel |
| Amount of water vapour in flue gas | 1.08 | Kg of H ₂ O/kg of fuel |
| Amount of dry flue gas | 21.77 | kg/kg of fuel |
| Specific Fuel consumption | 87.79 | kg of fuel/ton of material |
| Heat Input Calculations | | |
| Combustion heat of fuel | 921,769 | Kcal/ton of material |
| Sensible heat of fuel | 1,225 | Kcal/ton of material |
| Total heat input | 922,994 | Kcal/ton of material |
| Heat Output Calculation | | |
| Heat carried away by 1 ton of material (useful heat) | 133,614 | Kcal/ton of material |
| Heat loss in dry flue gas per ton of material | 315,843 | Kcal/ton of material |
| Loss due to H ₂ in fuel | 82,484 | Kcal/ton of material |
| Loss due to moisture in combustion air | 187 | Kcal/ton of material |
| Loss due to partial conversion of C to CO | 50 | Kcal/ton of material |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 55 of 71 | |

| | | |
|---|--------------|----------------------|
| Loss due to convection and radiation (openings in furnace - inlet & outlet door of furnace) | 3,998 | Kcal/ton of material |
| Loss Due to Evaporation of Moisture Present in Fuel | - | Kcal/ton of material |
| Total heat loss from furnace body | 34,045 | Kcal/ton of material |
| Heat loss due to unburnts in Fly ash | - | Kcal/ton of material |
| Heat loss due to unburnts in bottom ash | - | Kcal/ton of material |
| Unaccounted heat losses | 352,772 | Kcal/ton of material |
| Heat loss from furnace body and ceilings | | |
| Heat loss from furnace body ceiling surface | 2550 | Kcal/hr |
| Heat loss from furnace body side walls surfaces | 1268 | Kcal/hr |
| Heat loss from hearth | 336 | Kcal/hr |
| Total heat loss from furnace body | 34045 | Kcal/tons |
| Furnace Efficiency | 14.50 | % |




Figure 19: Sankey diagram furnace 3

Furnace 4 efficiency calculations

| Input Data Sheet | |
|------------------|--------------|
| Type of Fuel | Furnace Oil |
| Source of fuel | Local vendor |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 56 of 71 | |

| | Value | Units |
|---|--------------|---------------------|
| Furnace Operating temperature (Heating Zone) | 1100 | <i>Deg C</i> |
| Final temperature of material (at outlet of Heating zone) | 1100 | <i>Deg C</i> |
| Initial temperature of material | 33 | <i>Deg C</i> |
| Average fuel Consumption | 15 | <i>Kg/hr</i> |
| Flue Gas Details | | |
| Flue gas temperature | 625 | <i>deg C</i> |
| Preheated air temperature | 110 | <i>deg C</i> |
| O2 in flue gas | 12 | <i>%</i> |
| CO2 in flue gas | 6.8 | <i>%</i> |
| CO in flue gas | 34.6 | <i>ppm</i> |
| Atmospheric Air | | |
| Ambient Temperature | 33 | <i>Deg C</i> |
| Relative Humidity | 45.6 | <i>%</i> |
| Humidity in ambient air | 0.03 | <i>kg/kgdry air</i> |
| Fuel Analysis | | |
| C | 84.00 | <i>%</i> |
| H | 12.00 | <i>%</i> |
| N | 0.00 | <i>%</i> |
| O | 1.00 | <i>%</i> |
| S | 3.00 | <i>%</i> |
| Moisture | 0.00 | <i>%</i> |
| Ash | 0.00 | <i>%</i> |
| Weighted Average GCV of Fuel-mix | 10500 | <i>kcal/kg</i> |
| Ash Analysis | | |
| Unburnt in bottom ash | 0.00 | <i>%</i> |
| Unburnt in fly ash | 0.00 | <i>%</i> |
| GCV of bottom ash | 0 | <i>kCal/kg</i> |
| GCV of fly ash | 0 | <i>kCal/kg</i> |
| Material and flue gas data | | |
| Weight of material (Raw material) being heated in furnace | 148 | <i>Kg/Hr</i> |
| Weight of Stock | 148 | <i>kg/hr</i> |
| Specific heat of material | 0.12 | <i>Kcal/kgdegC</i> |
| Average specific heat of fuel | 0.417 | <i>Kcal/kgdegC</i> |
| fuel temp | 70 | <i>deg C</i> |
| Specific heat of flue gas | 0.26 | <i>Kcal/kgdegC</i> |
| Specific heat of superheated vapour | 0.45 | <i>Kcal/kgdegC</i> |
| Heat loss from surfaces of various zone | | |
| For Ceiling | | |
| Natural convection heat transfer rate from ceiling | 2.8 | <i>Kcal/m2degC</i> |
| External temp. of ceiling | 375 | <i>deg K</i> |
| Room Temperature | 306 | <i>deg K</i> |
| Ceiling surface area | 5.29 | <i>m2</i> |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 57 of 71 | |

| | | |
|---|---------|-------------|
| Emissivity of furnace body surface | 0.75 | |
| For side walls | | |
| Natural convection heat transfer rate from sidewall surfaces | 2.2 | Kcal/m2degC |
| External temperature of side walls | 345 | deg K |
| Sidewall surface area | 12.3728 | m2 |
| For Hearth | | |
| Natural convection heat transfer rate from flue gas duct surfaces | 1.5 | Kcal/m2degC |
| External temp. of side walls | 343 | deg K |
| External surface area | 3.857 | m2 |
| Outside dia of flue gas duct | 0.15 | m |
| For radiation loss in furnace(through charging and discharging door) | | |
| Time duration for which the material enters through preheating zone and exits through Furnace | 1 | Hr |
| Area of opening in m2 | 1.17 | m2 |
| Coefficient based on profile of furnace opening | 0.7 | |
| Maximum temperature of air at furnace door | 474 | deg K |

Efficiency calculations

| Calculations | Values | Unit |
|---|-----------|----------------------------|
| Theoretical Air Required | 14.01 | kg/kg of fuel |
| Excess Air supplied | 123.40 | % |
| Actual Mass of Supplied Air | 31.29 | kg/kg of fuel |
| Mass of dry flue gas | 31.21 | kg/kg of fuel |
| Amount of Wet flue gas | 32.29 | Kg of flue gas/kg of fuel |
| Amount of water vapour in flue gas | 1.08 | Kg of H2O/kg of fuel |
| Amount of dry flue gas | 31.21 | kg/kg of fuel |
| Specific Fuel consumption | 101.31 | kg of fuel/ton of material |
| Heat Input Calculations | | |
| Combustion heat of fuel | 1,063,771 | Kcal/ton of material |
| Sensible heat of fuel | 1,559 | Kcal/ton of material |
| Total heat input | 1,065,330 | Kcal/ton of material |
| Heat Output Calculation | | |
| Heat carried away by 1 ton of material (useful heat) | 128,028 | Kcal/ton of material |
| Heat loss in dry flue gas per ton of material | 486,994 | Kcal/ton of material |
| Loss due to H2 in fuel | 93,064 | Kcal/ton of material |
| Loss due to moisture in combustion air | 250 | Kcal/ton of material |
| Loss due to partial conversion of C to CO | 243 | Kcal/ton of material |
| Loss due to convection and radiation (openings in furnace - inlet & outlet door of furnace) | 9,894 | Kcal/ton of material |
| Loss Due to Evaporation of Moisture Present in Fuel | - | Kcal/ton of material |
| Total heat loss from furnace body | 68,857 | Kcal/ton of material |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 58 of 71 | |

| | | |
|---|--------------|----------------------|
| Heat loss due to unburnts in Fly ash | - | Kcal/ton of material |
| Heat loss due to unburnts in bottom ash | - | Kcal/ton of material |
| Unaccounted heat losses | 278,000 | Kcal/ton of material |
| Heat loss from furnace body and ceilings | | |
| Heat loss from furnace body ceiling surface | 5026 | Kcal/hr |
| Heat loss from furnace body side walls surfaces | 4280 | Kcal/hr |
| Heat loss from hearth | 884 | Kcal/hr |
| Total heat loss from furnace body | 68857 | Kcal/tons |
| Furnace Efficiency | 12.04 | % |




Figure 20: Sankey diagram furnace 4

Furnace 5 efficiency calculations

| Input Data Sheet | | |
|--|--------------|--------------|
| Type of Fuel | Furnace Oil | |
| Source of fuel | Local vendor | |
| | Value | Units |
| Furnace Operating temperature (Heating Zone) | 1210 | Deg C |

| | | | | |
|-------------------|---|-------------|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | | Page 59 of 71 |

| | | |
|---|-------|---------------|
| Final temperature of material (at outlet of Heating zone) | 1210 | Deg C |
| Initial temperature of material | 38 | Deg C |
| Average fuel Consumption | 9.6 | Kg/hr |
| Flue Gas Details | | |
| Flue gas temperature | 851 | Deg C |
| Preheated air temperature | 110 | Deg C |
| O2 in flue gas | 10 | % |
| CO2 in flue gas | 8.3 | % |
| CO in flue gas | 88.7 | ppm |
| Atmospheric Air | | |
| Ambient Temperature | 38 | Deg C |
| Relative Humidity | 45.6 | % |
| Humidity in ambient air | 0.03 | kg/kg dry air |
| Fuel Analysis | | |
| C | 84.00 | % |
| H | 12.00 | % |
| N | 0.00 | % |
| O | 1.00 | % |
| S | 3.00 | % |
| Moisture | 0.00 | % |
| Ash | 0.00 | % |
| Weighted Average GCV of Fuel-mix | 10500 | kcal/kg |
| Ash Analysis | | |
| Unburnt in bottom ash | 0.00 | % |
| Unburnt in fly ash | 0.00 | % |
| GCV of bottom ash | 0 | kCal/kg |
| GCV of fly ash | 0 | kCal/kg |
| Material and flue gas data | | |
| Weight of material (Raw material) being heated in furnace | 88 | Kg/Hr |
| Weight of Stock | 88 | kg/hr |
| Specific heat of material | 0.12 | Kcal/kgdegC |
| Average specific heat of fuel | 0.417 | Kcal/kgdegC |
| fuel temp | 70 | deg C |
| Specific heat of flue gas | 0.26 | Kcal/kgdegC |
| Specific heat of superheated vapour | 0.45 | Kcal/kgdegC |
| Heat loss from surfaces of various zone | | |
| For Ceiling | | |
| Natural convection heat transfer rate from ceiling | 2.8 | Kcal/m2degC |
| External temperature of ceiling | 379 | deg K |
| Room Temperature | 311 | deg K |
| Ceiling surface area | 3.81 | m2 |
| Emissivity of furnace body surface | 0.75 | |
| For side walls | | |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 60 of 71 | |

| | | |
|---|--------|--------------------------|
| Natural convection heat transfer rate from sidewall surfaces | 2.2 | Kcal/m ² degC |
| External temp. of side walls | 338 | deg K |
| Sidewall surface area | 8.6008 | m ² |
| For Hearth | | |
| Natural convection heat transfer rate from flue gas duct surfaces | 1.5 | Kcal/m ² degC |
| External temp. of side walls | 349 | deg K |
| External surface area | 2.5029 | m ² |
| Outside dia of flue gas duct | 0.15 | m |
| For radiation loss in furnace(through charging and discharging door) | | |
| Time duration for which the material enters through preheating zone and exits through Furnace | 1 | Hr |
| Area of opening in m ² | 0.5084 | m ² |
| Coefficient based on profile of furnace opening | 0.7 | |
| Maximum temperature of air at furnace door | 474 | deg K |

Efficiency calculations

| Calculations | Values | Unit |
|---|-----------|-----------------------------------|
| Theoretical Air Required | 14.01 | kg/kg of fuel |
| Excess Air supplied | 90.91 | % |
| Actual Mass of Supplied Air | 26.74 | kg/kg of fuel |
| Mass of dry flue gas | 26.66 | kg/kg of fuel |
| Amount of Wet flue gas | 27.74 | Kg of flue gas/kg of fuel |
| Amount of water vapour in flue gas | 1.08 | Kg of H ₂ O/kg of fuel |
| Amount of dry flue gas | 26.66 | kg/kg of fuel |
| Specific Fuel consumption | 109.53 | kg of fuel/ton of material |
| Heat Input Calculations | | |
| Combustion heat of fuel | 1,150,116 | Kcal/ton of material |
| Sensible heat of fuel | 1,460 | Kcal/ton of material |
| Total heat input | 1,151,577 | Kcal/ton of material |
| Heat Output Calculation | | |
| Heat carried away by 1 ton of material (useful heat) | 140,637 | Kcal/ton of material |
| Heat loss in dry flue gas per ton of material | 617,192 | Kcal/ton of material |
| Loss due to H ₂ in fuel | 112,358 | Kcal/ton of material |
| Loss due to moisture in combustion air | 293 | Kcal/ton of material |
| Loss due to partial conversion of C to CO | 558 | Kcal/ton of material |
| Loss due to convection and radiation (openings in furnace - inlet & outlet door of furnace) | 7,231 | Kcal/ton of material |
| Loss Due to Evaporation of Moisture Present in Fuel | - | Kcal/ton of material |
| Total heat loss from furnace body | 70,469 | Kcal/ton of material |
| Heat loss due to unburnts in Fly ash | - | Kcal/ton of material |
| Heat loss due to unburnts in bottom ash | - | Kcal/ton of material |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 61 of 71 | |

| | | |
|---|--------------|----------------------|
| Unaccounted heat losses | 202,839 | Kcal/ton of material |
| Heat loss from furnace body and ceilings | | |
| Heat loss from furnace body ceiling surface | 3675 | Kcal/hr |
| Heat loss from furnace body side walls surfaces | 1919 | Kcal/hr |
| Heat loss from hearth | 607 | Kcal/hr |
| Total heat loss from furnace body | 70469 | Kcal/tons |
| Furnace Efficiency | 12.23 | % |




Figure 21: Sankey diagram furnace 5

Furnace 8 efficiency calculations

| Input Data Sheet | | |
|---|---------------------|--------------------|
| Type of Fuel | | Furnace Oil |
| Source of fuel | Local vendor | |
| | Value | Units |
| Furnace Operating temperature (Heating Zone) | 1170 | Deg C |
| Final temperature of material (at outlet of Heating zone) | 1170 | Deg C |
| Initial temperature of material | 33 | Deg C |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 62 of 71 | |

| | | |
|--|-------|----------------------|
| Average fuel Consumption | 12.9 | <i>Kg/hr</i> |
| Flue Gas Details | | |
| Flue gas temperature | 662 | <i>Deg C</i> |
| Preheated air temperature | 110 | <i>Deg C</i> |
| O2 in flue gas | 12 | <i>%</i> |
| CO2 in flue gas | 7.3 | <i>%</i> |
| CO in flue gas | 43.5 | <i>ppm</i> |
| Atmospheric Air | | |
| Ambient Temperature | 33 | <i>Deg C</i> |
| Relative Humidity | 45.6 | <i>%</i> |
| Humidity in ambient air | 0.03 | <i>kg/kg dry air</i> |
| Fuel Analysis | | |
| C | 84.00 | <i>%</i> |
| H | 12.00 | <i>%</i> |
| N | 0.00 | <i>%</i> |
| O | 1.00 | <i>%</i> |
| S | 3.00 | <i>%</i> |
| Moisture | 0.00 | <i>%</i> |
| Ash | 0.00 | <i>%</i> |
| Weighted Average GCV of Fuel-mix | 10500 | <i>kcal/kg</i> |
| Ash Analysis | | |
| Unburnt in bottom ash | 0.00 | <i>%</i> |
| Unburnt in fly ash | 0.00 | <i>%</i> |
| GCV of bottom ash | 0 | <i>kCal/kg</i> |
| GCV of fly ash | 0 | <i>kCal/kg</i> |
| Material and flue gas data | | |
| Weight of material (Raw material) being heated in furnace | 222 | <i>Kg/Hr</i> |
| Weight of Stock | 222 | <i>kg/hr</i> |
| Specific heat of material | 0.12 | <i>Kcal/kg degC</i> |
| Average specific heat of fuel | 0.417 | <i>Kcal/kg degC</i> |
| fuel temp | 70 | <i>deg C</i> |
| Specific heat of flue gas | 0.26 | <i>Kcal/kg degC</i> |
| Specific heat of superheated vapor | 0.45 | <i>Kcal/kg degC</i> |
| Heat loss from surfaces of various zone | | |
| For Ceiling | | |
| Natural convection heat transfer rate from ceiling | 2.8 | <i>Kcal/m2 degC</i> |
| External temp. of ceiling | 361 | <i>deg K</i> |
| Room Temperature | 306 | <i>deg K</i> |
| Ceiling surface area | 5.07 | <i>m2</i> |
| Emissivity of furnace body surface | 0.75 | |
| For side walls | | |
| Natural convection heat transfer rate from sidewall surfaces | 2.2 | <i>Kcal/m2degC</i> |
| External temp. of side walls | 325 | <i>deg K</i> |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 63 of 71 | |

| | | |
|---|--------|--------------------------|
| Sidewall surface area | 9.7224 | m ² |
| For Hearth | | |
| Natural convection heat transfer rate from flue gas duct surfaces | 1.5 | Kcal/m ² degC |
| External temperature of side walls | 333 | deg K |
| External surface area | 3.6309 | m ² |
| Outside dia of flue gas duct | 0.15 | m |
| For radiation loss in furnace(through charging and discharging door) | | |
| Time duration for which the material enters through preheating zone and exits through Furnace | 1 | Hr |
| Area of opening in m ² | 0.88 | m ² |
| Coefficient based on profile of furnace opening | 0.7 | |
| Maximum temperature of air at furnace door | 463 | deg K |

Efficiency calculations

| Calculations | Values | Unit |
|---|---------|-----------------------------------|
| Theoretical Air Required | 14.01 | kg/kg of fuel |
| Excess Air supplied | 146.48 | % |
| Actual Mass of Supplied Air | 34.52 | kg/kg of fuel |
| Mass of dry flue gas | 34.44 | kg/kg of fuel |
| Amount of Wet flue gas | 35.52 | Kg of flue gas/kg of fuel |
| Amount of water vapour in flue gas | 1.08 | Kg of H ₂ O/kg of fuel |
| Amount of dry flue gas | 34.44 | kg/kg of fuel |
| Specific Fuel consumption | 57.89 | kg of fuel/ton of material |
| Heat Input Calculations | | |
| Combustion heat of fuel | 607,869 | Kcal/ton of material |
| Sensible heat of fuel | 892 | Kcal/ton of material |
| Total heat input | 608,761 | Kcal/ton of material |
| Heat Output Calculation | | |
| Heat carried away by 1 ton of material (useful heat) | 136,434 | Kcal/ton of material |
| Heat loss in dry flue gas per ton of material | 326,186 | Kcal/ton of material |
| Loss due to H ₂ in fuel | 54,215 | Kcal/ton of material |
| Loss due to moisture in combustion air | 293 | Kcal/ton of material |
| Loss due to partial conversion of C to CO | 164 | Kcal/ton of material |
| Loss due to convection and radiation (openings in furnace - inlet & outlet door of furnace) | 4,348 | Kcal/ton of material |
| Loss Due to Evaporation of Moisture Present in Fuel | - | Kcal/ton of material |
| Total heat loss from furnace body | 25,423 | Kcal/ton of material |
| Heat loss due to unburnts in Fly ash | - | Kcal/ton of material |
| Heat loss due to unburnts in bottom ash | - | Kcal/ton of material |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 64 of 71 | |

| | | |
|---|--------------|----------------------|
| Unaccounted heat losses | 61,696 | Kcal/ton of material |
| Heat loss from furnace body and ceilings | | |
| Heat loss from furnace body ceiling surface | 3,674 | Kcal/hr |
| Heat loss from furnace body side walls surfaces | 1,397 | Kcal/hr |
| Heat loss from hearth | 573 | Kcal/hr |
| Total heat loss from furnace body | 25,423 | Kcal/tons |
| Furnace Efficiency | 22.44 | % |




Figure 22 Sankey: diagram of forging furnace 8

| | | | |
|-------------------|---|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 65 of 71 |

6 LIST OF VENDORS

The details of some of suppliers for energy equipments are given in the table below:

EPIA 1, 2 & 3: Excess Air Control

| Sl. No. | Name of Company | Address | Phone No | E-mail /Website |
|-------------------|--|---|--|--|
| Automation | | | | |
| 1 | Delta Energy Nature Contact Person Gurinder Jeet Singh, Director | F-187, Indl. Area, Phase-VIII-Bm Mohali- 160059 | Tel.: 0172-4004213/ 3097657/ 2268197 Mobile: 9316523651 9814014144 9316523651 | dengjss@yahoo.com den8353@yahoo.com |
| 2 | International Automation Inc Contact Person Sanjeev Sharma) | # 1698, First Floor, Canara Bank Building, Near Cheema Chowk, Link Road, Ludhiana | Office: +91-161- 4624392, Mobile: +91- 9815600392 | Email: interautoinc@ya hoo.com |
| 3 | Happy Instrument | Yogesh 20, Proffulit Society, Nr Navo Vas, Rakhial, Ahmedabad-380021 | 079-22771702 9879950702 | yogesh@happyinstrument .com |
| 4 | Wonder Automation | Kulwinder Singh E-192, Sector 74, Phase 8- B, Industrial Area, SAS nagar Mohali | 0172-4657597 98140 12597 | info@wonderplctr.com adm.watc@gmail.com hs@wonderplctr.com |

EPIA 4: Skin loss reduction

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|--|---|--|--|
| 1 | Morgan Advanced Materials - Thermal Ceramics | P.O. Box 1570, Dare House Complex, Old No. 234, New No. 2, NSC Bose Rd, Chennai - 600001, | T 91 44 2530 6888 F 91 44 2534 5985 M 919840334836 | munuswamy.kadhirvelu@morganplc.com mmtcl.india@morganplc.c |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 66 of 71 | |

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|--|---|---|--|
| | | INDIA | | om ramaswamy.pondian@morganplc.com |
| 2 | M/s LLOYD Insulations (India) Limited, | 2,Kalka ji Industrial Area, New Delhi-110019 | Phone: +91-11-30882874 / 75 Fax: +91-11-44-30882894 /95 Mr. Rajneesh Phone : 0161-2819388 Mobile : 9417004025 | Email: kk.mitra@lloydinsulation.com |

EPIA 5: VFD on broaching machines

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|--|---|---|---|
| 1 | Schneider Electric Contact Person: Mr. Amritanshu | A-29, Mohan Cooperative Industrial Estate, Mathura Road, New Delhi-110044, India. | 9871555277 (Rinki), Mr.Amritanshu (9582941330), 0124-3940400 | amit.chadha@schneider-electric.com |
| 2 | Larson & Toubro Contact Person: Mr. Rajesh Bhalla | Electrical business group,32,Shivaji Marg,Near Moti nagar,Delhi-15 | 011(41419500),9582 252422(Mr.Rajesh),7 838299559(Mr.Vikram-sales),(Prithvi power-technical)- 9818899637,981002 8865(Mr.Ajit),851099 9637(Mr.Avinash Vigh) | Email: bhallar@Intebg.com, vikram.garg@Intebg.com, prithvipowers@yahoo.com, rajesh.bhalla@Intebg.com ,ajeet.singh@Intebg.com |

EPIA 6: Installation of EE fans instead of conventional fans

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 67 of 71 | |

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|--|--|--|--|
| 1 | Super fans | 351B/2A, Uzhaipalar street, GN Mills PO, Coimbatore. INDIA 641029. | Mob: 9489078737 | Email: superfan@versadrives.com |
| 2 | Usha pumps Contact Person: Mr. KB Singh | J-1/162, Rajouri Garden, Rajouri Garden New Delhi, DL 110005 | 011(23318114),011 2510 4999,01123235861(Mr.Manish) | Email: kb_singh@ushainternational.com |

EPIA 7 & 8: Energy Efficient Lights

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|---|--|--|---|
| 1 | Osram Electricals Contact Person: Mr. Vinay Bharti | OSRAM India Private Limited,Signature Towers, 11th Floor,Tower B, South City - 1,122001 Gurgaon, Haryana | Phone: 011-30416390 Mob: 9560215888 | vinay.bharti@osram.com |
| 2 | Philips Electronics Contact Person: Mr. R. Nandakishore | 1st Floor Watika Atrium, DLF Golf Course Road, Sector 53, Sector 53 Gurgaon, Haryana 122002 | 9810997486, 9818712322(Yogesh-Area Manager), 9810495473(Sandeep-Faridabad) | r.nandakishore@phillips.com, sandeep.raina@phillips.com |
| 3 | Bajaj Electricals Contact Person: Mr. Kushgra Kishore | Bajaj Electricals Ltd,1/10, Asaf Ali Road, New Delhi 110 002 | 9717100273, 011-25804644 Fax : 011-23230214 ,011-23503700, 9811801341(Mr.Rahul Khare), (9899660832)Mr.Atul Baluja, | kushagra.kishore@bajajelectricals.com, kushagrakishore@gmail.com; sanjay.adlakha@bajajelectricals.com |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 68 of 71 | |

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|-----------------|---------|---|--------|
| | | | Garving Gaur(9717100273), 9810461907(Kapil) | |

EPIA 9 & 10: Replacement of reciprocating compressor with screw compressor

| Sl. No. | Name of Company | Address | Phone No. | E-mail |
|---------|---|--|--|--|
| 1 | Elgi Equipments-Supplier Contact Person: Mr. Ankur Saxena | 23, Near Karampura, Opposite to DCM, Shivaji Marg, Delhi, - 110015 | 9717294729(Gaurav Luthra) Mr.Anshul Malhotra-9811025837,011-49491900(Dealer-Elgi equipment) | gauravl@elgi.com,sales@serviceequipmentcompany.com |
| 2 | Kaeser compressors India Pvt. Ltd. Contact Person: Amit Rajpal | 811 A, D Mall,A-01, Netaji Subhash Place, Pitam Pura, Delhi - 110034 | 011-27353552,9818380792,Fax-27353552 | Email: amit.rajpall@kaeser.com |

EPIA 11: DG Replacement

| Sl. No. | Name of Company | Address | Phone No. | E-mail / Website |
|---------|--|--|---------------------------|-----------------------------|
| 1 | Mahindra Powerol Engines & DG set Contact Person: Mr.Pankaj Katiyar Marketing | Jeevan Tara Building,5,Parliament street,delhi-1 | Mobile: +91-9818494230 | katiyar.pankaj@mahindra.com |

| | | | | |
|-------------------|---|-------------|-------------|---------------|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | | Rev. 2 |
| Prepared by: DESL | Date: 06-07-2015 | | | Page 69 of 71 |

| Sl. No. | Name of Company | Address | Phone No. | E-mail / Website |
|---------|---|--|---|--|
| 2 | Cummins Power Generation Contact Person: Rishi Gulati Senior Manager- Power Electronics | Cummins India Limited Power Generation Business Unit 35/A/1/2, Erandawana, Pune 411 038, India | Phone: (91) 020- 3024 8600 , +91 124 3910908 Mobile: +91 9350191881 | cpgindia@cummins.com rishi.s.gulati@cummins.com |
| 3 | BNE Company Contact Person: Mr Bhavneet Singh, Marketing | 7B, Kiran Shankar Roy Road, 3rd Floor, Kolkata 700 001 | Mobile : +91- 9831048994 | bnecompany@gmail.com, bne_company@yahoo.com |

EPIA 12: Installation of EE Burners

| Sl. No. | Name of Company | Address | Phone No | E-mail /Website |
|-------------------|--|--|--|--|
| Automation | | | | |
| 1 | ENCON Thermal Engineers (P) Ltd Contact Person: Mr V B Mahendra, Managing Director Mr. Puneet Mahendra, Director | 297, Sector-21 B Faridabad – 121001 Haryana | Tel.: +91 129 4041185 Fax: +91 129 4044355 Mobile: +919810063702 +919971499079 | sales@encon.co.in kk@encon.co.in www.encon.co.in |
| 2 | TECHNOTHERMA FURNACES INDIA PVT. LTD. | 206, Hallmark Commercial Complex, Near Nirmal Lifestyles, L.B.S. Marg, Mulund West, Mumbai - 400 080. India. | T: 022-25695555 | Furnace@technotherma.net |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 70 of 71 | |

| Sl. No. | Name of Company | Address | Phone No | E-mail /Website |
|---------|-----------------|---|--|--|
| 3 | Therm process | Mr. Sanjay Parab B/1203-O2 Commercial Complex, Minerva Estate, Opp Asha Nagar, P.K.Cross Road, Mulund (W) Mumbai-400080 | T: 022-25917880/82/83 M: 9967515330 | thermprocess@yahoo.com sanjay@thermprocess.com |

| | | | | |
|-------------------|---|-------------|---------------|---|
| Client Name | Bureau of Energy Efficiency (BEE) | Project No. | 9A0000005611 | |
| Project Name | Promoting energy efficiency and renewable energy in selected MSME clusters in India | | Rev. | 2 |
| Prepared by: DESL | Date: 06-07-2015 | | Page 71 of 71 | |