



United Nations Industrial  
Development Organization



Global Environment  
Facility



Bureau Of Energy Efficiency

## *Detailed Energy Audit Report*

*M/s Rajasthan Tools  
Nagaur Handtools Cluster*

*Under GEF-UNIDO-BEE project*

*Promoting energy efficiency and renewable  
energy in selected MSME clusters in India*

January 2016



---

# ***Table of Contents***

---

Acknowledgement	4
Executive Summary	5
Project Background	6
1.1. Background of the project	6
1.2. Introduction to assignment	6
1.3. Scope of services	6
2. Energy Audit at Rajasthan Tools	7
2.1. Process flow	7
2.2. Baseline information of Rajasthan Tools	8
2.3. Monthly trend of production	8
2.4. Past electricity bill analysis	9
2.5. Load profile of Rajasthan Tools	10
2.6. Temperature profile of process and furnace	12
2.7. Thermal efficiency of furnace – direct method	13
2.8. Thermal efficiency of furnace – indirect method	14
2.9. Material loss during production	14
2.10. Specific energy consumption	15
3. Energy Conservation Measures	16
3.1. Measure 1: Installation of Automatic Power Factor Controller (APFC)	16
3.2. Measure 2: Installation of electric billet heater	17
3.3. Measure 3: Installation of cogged belt on load side and poly-V belt on common shaft drive side	18
3.4. Measure 4: Preheating arrangement for raw material	19
Annexure A: List of Energy Audit Instruments	20
Annexure B: Calculation sheet of furnace efficiency by indirect method	21

## List of Tables

Table 1: Baseline profile .....	8
Table 2: Tariff description.....	9
Table 3: Thermal efficiency of furnace – direct method .....	13
Table 4: Thermal efficiency of furnace – indirect method.....	14
Table 5: Material loss during production.....	14
Table 6: Specific energy consumption.....	15
Table 7: Power factor improvement - Assumptions and parameters considered for estimation of energy and financial savings .....	16
Table 8: Installation of electric billet heater - Assumptions and parameters considered for estimation of energy and financial savings .....	17
Table 9: Installation of cogged belt on load side and poly-V belt on common shaft drive side - Assumptions and parameters considered for estimation of energy and financial savings .....	18
Table 10: Installation of preheating arrangement for raw material - Assumptions and parameters considered for estimation of energy and financial savings .....	19

## List of Figures

Figure 1: Scope of services .....	6
Figure 2: Process flow .....	7
Figure 3: Monthly production data .....	8
Figure 4: Energy consumption pattern .....	9
Figure 5: Power factor profile and power factor surcharge.....	10
Figure 6: Active power (Load) and apparent power profile during audit .....	10
Figure 7: Electricity consumption (kWh) and (kVAh) profile during audit.....	11
Figure 8: Power factor profile during audit .....	11
Figure 9: Different loads and centre distances of pulleys on common shaft .....	12
Figure 10: Temperature profile from raw material to final product.....	12
Figure 11: Skin temperature of furnace .....	13

## List of abbreviations

APFC	Automatic Power Factor Controller
AVVNL	Ajmer Vidyut Vitran Nigam Limited
BEE	Bureau of Energy Efficiency
DISCOM	Distribution Company
GEF	Global Environment Facility
HP	Horsepower
kCal	Kilo Calories
kVA	Kilo Volt Ampere
kVAr	Kilo Volt Ampere reactive
kW	Kilo Watt
kWh	Kilo Watt Hour
MSME	Micro, Small and Medium Enterprises
MT	Metric Tonne
PMU	Project Management Unit
UNIDO	United Nations Industrial Development Organization

# ***Acknowledgement***

We sincerely thank GEF- UNIDO-BEE for associating PricewaterhouseCoopers Private Limited (PwC) in its prestigious project “Promoting energy efficiency and renewable energy in selected MSME clusters in India” which involves developing and promoting market environment for introducing energy efficiencies in process applications in 12 selected energy-intensive MSME clusters in India. Nagaur handtools cluster is one of them.

We express our sincere gratitude to all following officials of GEF-UNIDO-BEE PMU for their valuable support and guidance during the project:-

- Mr. Milind Deore, Energy Economist, BEE
- Mr. Abhishek Nath, National Project Manager, UNIDO
- Mr. Niranjana Rao Devela, National Technology Coordinator, UNIDO
- Mr. Ashish Sharma, Project Engineer, BEE

PwC is thankful to Nagaur Handtool Manufacturer’s Association for extending support for this assignment. We are also thankful to Mrs. Mumtaz Begum, Owner, Rajasthan Tools and his team for giving full support during the energy audit. We would like to thank Mr. Rajiv Singhal, Cluster Leader, GEF-UNIDO-BEE Project for providing on-field support during the energy audit.

## *Executive Summary*

Rajasthan Tools is located in Basni Industrial Area of Nagaur and is involved in manufacturing of pliers. It uses EN 8 as raw material which is sheared into appropriate size through a shearing machine. Thereafter, blanks are fed to reheating furnace for heating up to a temperature of around 1150 – 1200 °C. After which the heated blank is rolled and pressed to give the shape of plier. During the process, excess material is cut and finally end cutting is done so that the final product is of correct size.

During the energy audit, following energy efficiency opportunities were identified:

S.No.	Energy Efficiency measure	Investment (INR)	Savings (INR)	Payback period (months)
1	Installation of Automatic Power Factor Controller (APFC)	23,625	11,150	25
2	Installation of electric billet heater	11,27,000	3,76,385	36
3	Installation of cogged belt on load side and poly-V belt on common shaft drive side	12,723	9,450	16
4	Preheating arrangement for raw material	20,000	76,388	3
<b>Total</b>		<b>11,83,348</b>	<b>4,73,373</b>	<b>30</b>

The details about the unit, load profiles, efficiency of furnace and description of energy conservation measures are discussed in appropriate sections of the report.

# Project Background

## 1.1. Background of the project

GEF-UNIDO-BEE is developing and promoting market environment for introducing energy efficiencies in process applications in 12 selected energy-intensive MSME clusters in India which includes Nagaur handtools cluster also.

The overall motive of this assignment is to improve the productivity and competitiveness of units as well as to reduce overall carbon emissions and improve the local environment.


## 1.2. Introduction to assignment

Under GEF-UNIDO-BEE project ‘Promoting energy efficiency and renewable energy in selected MSME clusters in India’ India’, PwC has been appointed for conducting activities of energy audit and dissemination in the Nagaur Handtools Cluster.

## 1.3. Scope of services

The activities being conducted by PwC under this assignment are shown at **Error! Not a valid bookmark self-reference..**

**Figure 1: Scope of services**




This current report has been prepared under the task 2 of above scope of services i.e. conducting comprehensive energy audits in 6 units in the cluster.

## 2. Energy Audit at Rajasthan Tools

### 2.1. Process flow

The process flow at Rajasthan Tools is shown at Figure 2 below. The raw material (EN 8) is sheared into appropriate size through a shearing machine. Thereafter, blanks are fed to reheating furnace for heating up to a temperature of around 1150 – 1200 °C. After which the heated blank is rolled and pressed to give the shape of plier. During the process, excess material is cut and finally end cutting is done so that the final product is of correct size. This is depicted in the following figure.

**Figure 2: Process flow**



The specialized instruments that were used during the energy audit included:

- Non-contact Infrared Thermometer (Testo-845 and Extech)
- Flue Gas Analyzer (KANE 900+)
- 3-phase Power Analyzer (Krykard ALM 30)
- 1-phase Power Analyzer (Krykard ALM 10)
- Vane Anemometer (Testo-416)
- Digital Tachometer (Extech-461995)

Details about the make of energy audit instruments are provided at **Annexure A**.

This report presents the field measurements, design and operational data and data analysis.

## 2.2. Baseline information of Rajasthan Tools

In order to assess the present energy consumption levels and possible energy efficiency measures at 'Rajasthan Tools' basic and general information was collected during the audit conducted on 4<sup>th</sup> and 5<sup>th</sup> May 2015.

The detail of energy audit of unit is provided below.

### 2.2.1. About the Unit

This unit is located in Basni Industrial Area of Nagaur. The baseline profile of the unit is presented in Table 1.


**Table 1: Baseline profile**

Parameters	Details
Name of the unit	Rajasthan Tools
Name & contact number of contact person	Mrs. Mumtaz Begum Mobile - 9887786911
Date of audit	4th and 5th May 2015
Raw material	EN-8
Final product	Plier 6"
Furnace	Box type
Dimension of furnace	33" X 19" X 16"
Fuel used	Furnace oil
Press hammer weight	150 kg
Daily production	1300 pieces
Operating hours/day	7 hours
Sanction load	40 hp

## 2.3. Monthly trend of production

The audit team has collected monthly production data from the unit and the same has been depicted in the following figure.

**Figure 3: Monthly production data**





## 2.4. Past electricity bill analysis


The team has collected electricity bills from January 2014 to February 2015 for the purpose of analysis. The electricity bills from January 2014 to March 2014 were based on LT-5 category as specified by AVVNL with sanction load of 15 hp. However, from April 2014 onwards, the tariff category was changed to LT-6 due to increase in sanction load to 40 hp. The details of these tariff categories are tabulated below:

**Table 2: Tariff description**

Parameter	LT-5	LT-6
Category description	Sanction load above 5kW but not exceeding 25HP	Sanction load above 25 HP but not exceeding 150 HP
Fixed charges	INR 50/ kVA	INR 60/ kVA
Energy charges	INR 4.85/ kWh	INR 6.25/ kWh

A graph showing pattern of energy consumption is shown below.


**Figure 4: Energy consumption pattern**



It can be inferred from above figure that the energy consumption peaks during months of June, January and February after which the consumption decreases. Further, the average energy consumption, for the said period, is 969 kWh/month.

Similarly, the power factor profile as well as power factor surcharge paid by the unit are shown in following figure.

**Figure 5: Power factor profile and power factor surcharge**



It can be seen that the unit has paid around INR 5900 due to low power factor surcharge from January 2014 to February 2015.


## 2.5. Load profile of Rajasthan Tools

In order to derive the load profile of the unit, many electrical parameters were measured by using a sophisticated portable 3-phase power analyser (KRYKARD).

### 2.5.1. Load (kW) and apparent power (kVA) profile

Load profile and apparent power profile is a graph of the variation in the electrical load versus time. In any electrical system, the vector sum of the active power (kW) and reactive power (kVAr) make up the total (or apparent) power (kVA) used. This is the power generated by a generation station for the user to perform a given amount of work. Total power is measured in kVA (Kilo Volts-Amperes) and the load or active power is measured in kW (kilowatts) and they become equal as and when the power factor approaches unity. Total electricity charges (units and demand) are based on the load or active power (kW) and apparent power (kVA).

**Figure 6: Active power (Load) and apparent power profile during audit**



#### Observations made from the above graph:


- The maximum input power drawn by the unit is 7.63 kW. The graph shows that that the unit stopped operation around 6:30 PM and then began its operation from 6:20 AM onwards.

- Apparent power curve (kVA) line is significantly above the active power (kW) line indicating that power factor is on lower side.

### 2.5.2. Electricity consumption (kWh) profile

Electricity consumption profile is the pattern of the consumption of electricity in the unit during the energy audit. The following graph captures the electricity consumption (kWh) profile of the unit:

**Figure 7: Electricity consumption (kWh) and (kVAh) profile during audit**



**Observations made from the above graph:**


- The unit consumed nearly 27.69 kWh and around 34.02 kVAh during the recording period of almost 19 hours.

### 2.5.3. Power factor profile of the unit

Power factor is an important parameter for the unit since its billing is based on kVAh wherein power factor plays a major role. Also, DISCOM’s supplying power to the units impose power factor surcharge on the bills in case the power factor is below 0.90.

The following graph captures the power factor profile of the unit:

**Figure 8: Power factor profile during audit**




**Observations made from the above graph:**

- The power factor of the unit is on lower side with maximum power factor being at 0.88
- The unit may consider installing capacitor banks for improving the power factor so that they do not get charged with power factor surcharge.

A common shaft is used in the unit for transmission of power from drive motor to other loads. The layout and positioning of various loads and centre distances are depicted in following figure.

**Figure 9: Different loads and centre distances of pulleys on common shaft**




**2.6. Temperature profile of process and furnace**

**2.6.1.1. Temperature profile**

During the baseline energy audit, temperature was measured at various stages of the process such as raw material temperature, furnace discharge, rolling mill outlet, press outlet, cutting outlet and final product. The temperature profile is presented at following figure.

**Figure 10: Temperature profile from raw material to final product**



There is total temperature drop of around 145°C from furnace outlet till final product.

**2.6.1.2. Skin temperature**

The skin temperature of furnace was captured using infrared thermometer. The temperature profile is mentioned below:

**Figure 11: Skin temperature of furnace**

Discharge side			Back Side	
286	300	315	250	238
206	270	300	203	160
<b>280</b>			<b>213</b>	
Burner side				
266	250	235		
253	232	180		
<b>236</b>				

It can be observed that the skin temperature is very high indicating that refractory lining is not proper inside the furnace and it also indicates that surface insulation is not present.

## ***2.7. Thermal efficiency of furnace – direct method***

Furnace thermal efficiency calculation by direct method involves comparison of useful heat content in the stock with the total thermal energy input to the furnace. Thermal efficiency for the reheating furnace is calculated by direct method in table below.

**Table 3: Thermal efficiency of furnace – direct method**

<b>Parameter</b>	<b>Unit</b>	<b>Value</b>
Production on audit day	kg/day	629.20
Furnace throughput	kg/hr	89.89
Fuel consumption rate	kg/hr	9.39
Gross calorific value of fuel	kCal/kg	10,880.00
Specific heat of the material	kCal/kg °C	0.12
Material charging temperature	°C	40.00
Material discharge temperature	°C	1,090.00
<b>Furnace efficiency by direct method</b>	<b>%</b>	<b>11.08</b>

It can be seen from above table that furnace thermal efficiency is around 11% as calculated by direct method. However, using direct method, one cannot determine different heat losses associated with furnace operation. Hence, indirect method or heat loss method is employed to determine furnace thermal efficiency as well as heat losses due to various other factors. The same has been discussed in next.

## 2.8. Thermal efficiency of furnace – indirect method

Indirect Method helps to determine major heat loss from furnace which includes losses in flue gas and other heat loss parameters like surface radiation losses, CO formation loss, etc. All these losses are calculated in table below:

**Table 4: Thermal efficiency of furnace – indirect method**

<i>Parameter</i>	<i>Unit</i>	<i>Value</i>
Measured O <sub>2</sub> in flue gas	%	6.10
Measured CO in flue gas	ppm	9225
Excess air used for combustion	%	40.94
Corresponding CO <sub>2</sub>	%	12.37
Total air used for combustion	kg/kg of fuel	18.20
Sensible heat loss in flue gas	%	<b>60.35</b>
Heat loss due to moisture present in fuel	%	0.019
Heat loss due to evaporation of water formed due to hydrogen in fuel	%	<b>7.24</b>
Heat loss due to moisture present in air	%	1.67
Heat loss due to CO formation	%	3.23
Heat loss due to radiation and openings	%	<b>5.49</b>
Heat loss in scale generation	%	0.003
Heat content in the material	%	11.08
Unaccounted Heat Losses	%	10.92

The exit flue gas temperature of furnace is 1050 °C and it can be observed from above that heat loss due to flue gas is one of the major contributors to overall heat loss from the furnace followed by heat loss due to hydrogen in fuel and heat loss due to radiation & openings. Detailed calculation sheet is attached at Annexure B.

## 2.9. Material loss during production

As observed in the process flow, material loss happens in following forms:

- Burning loss
- Cuttings after pressing
- End cuttings after sizing of product

We have captured these parameters to assess the burning loss as well as other material loss during the production process.

The assessment is tabulated below:

**Table 5: Material loss during production**

<i>Parameter</i>	<i>Unit</i>	<i>Value</i>
Weight of raw material	kg/piece	0.242
Weight of final product	kg/piece	0.204

Weight of cuttings	kg/piece	0.025
Weight of end-cuttings	kg/piece	0.006
Material loss in cuttings & end-cuttings	kg/piece	0.031
Total material loss	kg/piece	0.037
Burning loss	kg/piece	0.005
Burning loss	%	<b>2.34%</b>
Total material loss	%	<b>15.39%</b>

## ***2.10. Specific energy consumption***

Specific Energy Consumption for the product is calculated by aggregating individual specific energy consumption of fuel and electricity, as shown in table next.

**Table 6: Specific energy consumption**

<b>Parameter</b>	<b>Unit</b>	<b>Value</b>
Production	kg/day	629.20
Furnace oil consumption	L/day	71.48
Electricity consumption	kWh/day	26.80
Specific fuel consumption	L/Tonne	<b>113.60</b>
Specific electricity consumption	kWh/Tonne	<b>42.60</b>

## 3. Energy Conservation Measures

During the energy audit, we have identified following energy conservation measures:

- Installation of Automatic Power Factor Controller (APFC)
- Installation of electric billet heater
- Installation of cogged belt on load side and poly-V belt on common shaft drive side
- Preheating arrangement for raw material

We have analysed each of above mentioned measures next.

### 3.1. Measure 1: Installation of Automatic Power Factor Controller (APFC)

#### *Recommendation*

The average monthly power factor of the unit based on the electricity bills of the unit is 0.76 and it could be improved to 0.99 for load reduction and I<sup>2</sup>R losses reduction. This will also help in reducing the maximum demand. By installing Automatic Power Factor Control (APFC) unit, the power factor can be improved to unity.

#### *Energy and financial savings*

The following parameters and assumptions have been considered to estimate the energy savings and financial viability of this option:

**Table 7: Power factor improvement - Assumptions and parameters considered for estimation of energy and financial savings**

Assumptions and Input parameters		
Cost parameters		
Particulars	Unit	Value
Tentative price of capacitor bank	INR/kVAr	900
Tentative price of capacitor bank of 25 kVAr	INR	22,500
Installation cost	% of capital cost	5
Energy and financial savings		
Average monthly power factor		0.76
Proposed power factor		0.99
Required capacitor bank capacity	kVAr	25
Total annual monetary savings through power factor incentives	INR	11,150
Total investment requirement (price of capacitor bank and installation cost)	INR	23,625
Simple payback period	Months	25

The implementation of this recommendation will help the Rajasthan Tools to save around INR 11,150 per year by installing capacitor bank of around 25 kVAr. The implementation cost required to install Automatic Power Factor Control (APFC) panel is approximately INR 23,625 and the simple payback period of this investment is around 25 months.



## 3.2. Measure 2: Installation of electric billet heater

### Recommendation

The efficiency of reheating furnace used in the unit is pretty low and it generates lot of smoke making the environment not suitable for the workers. So, we recommend installation of electric billet heater in place of existing furnace oil fired reheating furnace. This will result in higher efficiency of billet heater and also better working environment for the workers.

### Energy and financial savings

The following parameters and assumptions have been considered to estimate the energy savings and financial viability of this option:

**Table 8: Installation of electric billet heater - Assumptions and parameters considered for estimation of energy and financial savings**

Assumptions and Input parameters		
Present Scenario		
Particulars	Unit	Value
Existing burning loss	%	2.34
Specific fuel consumption	L/T	113.6
Hourly production	kg/h	89.89
Present Scenario		
Size of billet heater	kW	40
Proposed burning loss	%	0.35
Specific electricity consumption	kWh/T	436
Cost components		
Cost of electric billet heater	INR	8,00,000
Cost of new transformer	INR	1,50,000
Miscellaneous expenses	INR	50,000
Impact of increased sanction demand @ 40 kVA	INR	1,27,000
Total cost	INR	11,27,000
Electricity consumption	kWh/annum	82,303
Electricity charges (in kWh/annum X INR 6.25/kWh )	INR	5,14,396
Benefits		
Material savings	T/annum	3.76
Fuel savings	L/annum	21,444
Material savings (in T/annum X INR 43000/T )	INR	1,61,680
Fuel savings (in L/annum X INR 34/L )	INR	7,29,101
Total benefits (Material savings + Fuel savings - Electricity charges)	INR	3,76,385
Simple payback period	Months	36

The implementation of this recommendation will help the Rajasthan Tools to save around INR 3,76,385 per year by installing electric billet heater of around 40 kW capacity. This will not result in change in existing tariff category. The simple payback period of this investment is around 36 months.

### **3.3. Measure 3: Installation of cogged belt on load side and poly-V belt on common shaft drive side**

#### **Recommendation**

Since the drive system in the unit is based on common shaft and different belts give input to other loads in the unit. Presently, the unit is using V-belt in common shaft drive side and flat belts on load side. However, if we replace existing belts with V-belt on load side and poly-V belt on common shaft drive side then it will give significant savings in electricity consumption of common drive motor as well as lower slippage losses.

#### **Energy and financial savings**

The following parameters and assumptions have been considered to estimate the energy savings and financial viability of this option:

**Table 9: Installation of cogged belt on load side and poly-V belt on common shaft drive side - Assumptions and parameters considered for estimation of energy and financial savings**

<b>Assumptions and Input parameters</b>		
<b>Assumptions</b>		
<b>Particulars</b>	<b>Unit</b>	<b>Value</b>
Efficiency of V-belt	%	0.85
Efficiency of normal belt	%	0.8
Efficiency of poly V-belt	%	0.92
Efficiency of cogged belt	%	0.85
Hours of operation per day	Hours	7
Annual operation days	Days	300
Tariff	INR/kWh	6.25
<b>Present Scenario</b>		
kW consumed	kW	5.5
kW at drive shaft	kW	4.68
kW at load	kW	3.74
<b>Proposed scenario</b>		
kW consumed	kW	4.78
kW at drive shaft	kW	4.40
kW at load	kW	3.74
<b>Cost elements</b>		
Cost of 15 feet cogged belt type "C" (3 nos.)	INR	5386
Cost of 10 feet cogged belt type "C" (2 nos.)	INR	2404
Cost of 6 feet cogged belt type "C"	INR	595
Cost of 22 feet poly-V belt (2 nos.)	INR	2658
Installation of pulleys of appropriate size	INR	1680
Total cost	INR	12723
<b>Benefits</b>		
Power savings	kW	0.72
Annual electricity savings	kWh/annum	1512
Monetary electricity savings	INR	9450
Simple payback period	Months	16

The implementation of this recommendation will help the Rajasthan Tools to save around INR 9450 per year by installing cogged and poly-V belts with an investment of INR 12723. The simple payback period of this investment is around 16 months.

### **3.4. Measure 4: Preheating arrangement for raw material**

#### **Recommendation**

It was observed during the energy audit that exit flue gas temperature from furnace is as high as 1050 °C which is not being utilized. We have also observed that it takes approximately 90 minutes for processing a batch of 300 pieces. So, we propose installation of a preheating arrangement at exit of furnace wherein next batch of 300 pieces are kept. Thus, during that time next batch of 300 pieces can be preheated and then transferred into furnace for processing. This will result in significant savings in fuel without any changes in furnace efficiency.

#### **Energy and financial savings**

The following parameters and assumptions have been considered to estimate the energy savings and financial viability of this option:

**Table 10: Installation of preheating arrangement for raw material - Assumptions and parameters considered for estimation of energy and financial savings**

<b>Assumptions and Input parameters</b>		
<b>Assumptions</b>		
<b>Particulars</b>	<b>Unit</b>	<b>Value</b>
Furnace efficiency	%	11.08
Material discharge temperature	°C	1090
Production	kg/h	89.89
Gross calorific value	kCal/kg	10880
Hours of operation per day	Hours	7
Annual operation days	Days	300
Fuel cost	INR/L	34
<b>Present Scenario</b>		
Material charging temperature	°C	40
Fuel consumption	L/day	71.49
<b>Proposed scenario</b>		
Material charging temperature	°C	150
Fuel consumption	L/day	64
<b>Cost elements</b>		
Lump-sum cost for installation of preheating system	INR	20,000
<b>Benefits</b>		
Fuel savings	L/day	7.49
Annual fuel savings	L/annum	2,246.72
Monetary savings due to fuel savings	INR	76,388
Simple payback period	Months	3

The implementation of this recommendation will help the Rajasthan Tools to save around INR 76,388 per year by installing preheating system for raw material with an investment of INR 20,000. The simple payback period of this investment is around 3 months.

# Annexure A: List of Energy Audit Instruments

PwC has multiple energy audit instruments kits. All the instruments are of high quality, precision and are periodically calibrated. The instruments are capable to cover all electrical and thermal measurements required in the plants. A list of instruments used by PwC during the audit are shown below:

S. No.	Name of the Instrument	Make	Quantity Used
<b>Thermal Instruments</b>			
1	Non-contact Infrared Thermometer (Testo-845 and Extech)	Testo (USA), Extech (USA)	2
2	Flue Gas Analyzer (KANE 900+)	Kane (UK)	1
<b>Electrical Instruments</b>			
3	3-phase Power Analyzer	Krykard, Circutor and Extech	3
4	1-phase Power Analyzer		2
<b>Others</b>			
5	Vane Anemometer (Testo-416)	Testo (USA)	2
6	Digital Tachometer (Extech-461995)	Extech (USA)	1

# Annexure B: Calculation sheet of furnace efficiency by indirect method

General Details		Data Sheet	
Name of unit	Rajasthan Tools		
No. of Energy Audit	1		
Product type	Plier		
Product size	160 mm		
Raw material under process	EN8		
Production Capacity	0.6292	TPD	
Standard Temperature for operation	1090	°C	
Average scale loss	0.02342933	%	
Average plant operation	7	hrs./day	
Annual plant operation	300	days/annum	
<b>Fuel Details</b>			
Type of fuel	Furnace Oil		
Total carbon	88.9	% by mass	
Hydrogen content	8	% by mass	
Sulfur content	0.5	% by mass	
Oxygen content	1.4	% by mass	
Nitrogen content	0.5	% by mass	
Moisture content	0.35	% by mass	
Ash content	0.35	% by mass	
Gross calorific value	10880	kcal/kg.	
Bulk Density	920	kg/m <sup>3</sup>	
Fuel consumption per hour	9.394514286	kg/hr	
Fuel consumption per day	65.7616	kg/day	
Fuel consumption per annum	19.72848	TPA	
Cost of fuel	31	Rs./kg	
<b>Measured Data</b>			
Ambient air temperature : (DBT)	40	°C	
Ambient air temperature : (WBT)	38	°C	
Material Temperature at feeding	40	°C	
Temp. of supply air for combustion	40	°C	
Average Oxygen level	6.1	%	
Average CO level	9225	ppm	
Exit flue gas temperature	1050	°C	
Average surface temperature -main body	200	°C	
Average surface temperature -front & back	200	°C	
Average surface temperature - Top	200	°C	
Temperature at Discharge opening	1090	°C	
Temperature at Charge opening	40	°C	
Surface area - main body	0.80903064	m <sup>2</sup>	
Surface area - front & back	0.39225728	m <sup>2</sup>	
Surface Area - Top	0.37999924	m <sup>2</sup>	
Area - Discharge opening	0.02725801	m <sup>2</sup>	
Area - Charge opening	0.0225806	m <sup>2</sup>	
Material temperature at furnace exit	1090	°C	
Material Feeding Rate	89.88571429	kg/hr	
Material Feeding Rate	629.2	kg/day	
<b>Standard Data</b>			
Specific heat of water	1	kcal/kg °C	
Specific Heat of steel	0.12	kcal/kg °C	
Specific Heat of coal	0.25	kcal/kg °C	
Specific heat of air	0.24	kcal/kg °C	
specific heat of water vapour at flue gas tempe	0.52	kcal/kg °C	
Enthalpy of steam at flue gas temperature	639.9	kcal/kg	
Enthalpy of water at supply air temperature	40	kcal/kg	
Specific Heat of flue gas	0.331949568	kcal/kg °C	
Moisture content of supply air		0.019 kg/kg of air	

<b>Efficiency Calculation of Furnace</b>		<b>Results Sheet</b>
Name of unit	Rajasthan Tools	
No. of Furnaces	1	
Type of furnace	Plier	
Application of furnace	160 mm	
Raw material under process	EN8	
Production Capacity	0.6292	TPD
Material feeding rate	89.88571429	kg/hr
Fuel Consumption rate	9.39	kg/hr
Specific heat of the material	0.12	kcal/kg °C
Material temperature at furnace entry	40	°C
Material temperature at furnace exit	1090	°C
<b>Furnace efficiency by direct method</b>	<b>11.1</b>	<b>%</b>
<b>Furnace efficiency by heat loss method</b>		
Stoichiometric air required for combustion	12.913	kg/kg of fuel
Theoretical max. CO <sub>2</sub>	17.44	%
Measured O <sub>2</sub> in flue gas	6.1	%
Measured CO in flue gas	9225	ppm
Excess air used for combustion	40.94	%
Corresponding CO <sub>2</sub>	12.37	%
Total air used for combustion	18.20	kg/kg of fuel
Heat loss due to dry flue gas	60.35	%
Heat loss due to moisture in fuel	0.019	%
Heat loss due to Hydrogen in fuel	7.24	%
Heat loss due to moisture in air	1.67	%
Heat loss due to CO formation	3.23	%
Heat loss due to radiation & openings	5.49	%
Heat loss in scale generation	0.0	%
Heat content in the material	11.08	%
Unaccounted loss	10.92	%

**DISCLAIMER:**

This publication has been prepared for general guidance on matters of interest only, and does not constitute professional advice. You should not act upon the information contained in this publication without obtaining specific professional advice. No representation or warranty (express or implied) is given as to the accuracy or completeness of the information contained in this publication, and, to the extent permitted by law, PricewaterhouseCoopers India Private Ltd., its members, employees and agents do not accept or assume any liability, responsibility or duty of care for any consequences of you or anyone else acting, or refraining to act, in reliance on the information contained in this publication or for any decision based on it.

© 2016 Bureau of Energy Efficiency. All rights reserved.