

COMPREHENSIVE ENERGY AUDIT REPORT

“PROMOTING ENERGY EFFICIENCY AND RENEWABLE ENERGY TECHNOLOGY IN SELECTED MSME CLUSTERS IN INDIA”

Jay Refractories

Chotila Road, Thangadh-363530, Gujarat, India

Submitted to



BUREAU OF ENERGY EFFICIENCY

4th Floor, SewaBhawan, R K Puram, Sector-I, New Delhi -110066

Submitted by



DEVELOPMENT ENVIRONERGY SERVICES LTD

819, AnrikshBhawan, 22 Kasturba Gandhi Marg, New Delhi -110001
Tel.: +91 11 4079 1100 Fax : +91 11 4079 1101; www.deslenergy.com

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 1 of 49	

DISCLAIMER

This report (including any enclosures and attachments) has been prepared for the exclusive use and benefit of the addressee(s) and solely for the purpose for which it is provided. Unless we provide express prior written consent, no part of this report should be reproduced, distributed or communicated to any third party. We do not accept any liability if this report is used for an alternative purpose from which it is intended, nor to any third party in respect of this report

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 2 of 49	

ACKNOWLEDGEMENT

DESL places on record its sincere thanks to Global Environment Facility (GEF), United Nations Industrial Development Organization (UNIDO) and Bureau of Energy Efficiency (BEE) for vesting confidence in DESL to carry out the assignment “Conducting energy audit and dissemination programs in MSME clusters” under their national project “Promoting energy efficiency and renewable energy in selected MSME clusters in India”.

As a part of this assignment, work in Thangadh Ceramic cluster was awarded to DESL and DESL is grateful to GEF-UNIDO-BEE PMU for their full-fledged coordination and support throughout the study

The study team is indebted to Mr. Jay Jadvani and Mr. Abhishe kJadvani, Jay Refractories for showing keen interest in the energy audit and also thankful to the management of Jay Refractories for their wholehearted support and cooperation for the preparation of this comprehensive energy audit report, without which the study would not have steered to its successful completion. Special thanks to other members of the unit for their diligent involvement and cooperation.

It is well worthy to mention that the efforts being taken and the enthusiasm shown by all the plant personnel towards energy conservation and sustainable growth are really admirable.

Last but not the least, the interaction and deliberation with Mr. Kirti Maru, President, Panchal Ceramic Association Vikas Trust , technology providers and all those who were directly or indirectly involved throughout the study were exemplary. The entire exercise was thoroughly a rewarding experience for DESL.

DESL Team

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 3 of 49	

DESL Team

Project Head	Mr. R. Rajmohan Chief Executive Officer
Team leader and co-coordinator	Mr. Suparno R Majumdar Consultant
Team member(s)	Mr. Mithlesh Priya Analyst
	Mr. Oisik Mishra Project Associate
	Mr. Prabhat Sharma Project Associate
	Mr. Vishnu P Project Associate
	Mr. Dhvanit Joshi Assistant Consultant
	Mr. Chintan Shah Assistant Analyst

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 4 of 49	

CONTENTS

EXECUTIVE SUMMARY	10
1 INTRODUCTION	13
1.1 Background and Project objective	13
1.2 Scope of work for Comprehensive Energy Audit	13
1.3 Methodology.....	14
1.3.1 Boundary parameters	14
1.3.2 General methodology	14
1.3.3 Comprehensive energy audit – field assessment	15
1.3.4 Comprehensive energy audit – desk work.....	17
2 ABOUT THE MSME UNIT.....	18
2.1 Particulars of the unit.....	18
3 DETAILED TECHNICAL FEASIBILITY ASSESSMENT OF THE UNIT	19
3.1 Description of manufacturing process	19
3.1.1 Process description.....	20
3.2 Inventory of process machines/equipment and utilities	20
3.3 Types of energy used and description of usage pattern	20
3.4 Analysis of electricity consumption by the unit	22
3.4.1 Electricity load profile	22
3.4.2 Supply from utility	23
3.4.3 Mont wise electricity consumption	24
3.5 Analysis of thermal consumption by the unit	25
3.6 Specific energy consumption	25
3.7 Baseline parameters	26
3.8 Identified energy conservation measures in the plant	26
3.7.1 Electricity Supply from Grid	27
3.7.3 Electrical consumption areas	27
3.7.4 Thermal consumption areas	28

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 5 of 49	

4	EE TECHNOLOGY OPTIONS AND TECHNO – ECONOMIC FEASIBILITY	31
4.1	EPIA 1: Reduction in radiation and convection losses from surface of kiln	31
4.2	EPIA 2: Excess air control	33
4.3	EPIA 3: Replacing conventional ceiling fans with Energy efficient fans	34
4.4	EPIA 4: Energy efficient light fixture.....	35
4.5	EPIA 5: Energy monitoring system	36
4.6	EPIA 6: Power factor improvement.....	37
4.7	EPIA 7: Replacement of Kiln car material.....	39
5	Renewable Energy Utilization.....	41
	Solar Air Drying	41
6	ANNEXURE	43
7	LIST OF VENDORS.....	46

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 6 of 49	

List of figures

Figure 1 General methodology	15
Figure 2 Process Flow Diagram	19
Figure 3 Energy cost share (Rs. Lakh)	21
Figure 4 Energy use share (MTOE).....	21
Figure 5 Details of connected load	23
Figure 6 SLD of electrical load.....	24
Figure 7 Temperature curve	29
Figure 8 Surface Temperature in each zone	32
Figure 9 Solar air drying schematic diagram.....	41

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 7 of 49	

List of Tables

Table 1 Details of Unit	10
Table 2 Summary of EPIA.....	12
Table 3 List of 12 targeted MSME clusters covered under the project	13
Table 4 Energy audit instruments.....	16
Table 5 General particulars of the unit.....	18
Table 6 Energy cost distribution	21
Table 7 Equipment wise connected load	22
Table 8 Tariff structure	23
Table 9 Electricity consumption & cost	24
Table 10 PNG used as fuel	25
Table 11 Overall specific energy consumption.....	25
Table 12 Baseline parameters	26
Table 13 Diagnosis of electric supply.....	27
Table 14 Kiln and Kiln car details	29
Table 15 Kiln Dimensions.....	29
Table 16 Thermal energy conservation measures.....	30
Table 17 R & C losses	32
Table 18 Cost benefit analysis (EPIA 1).....	32
Table 19 Cost benefit analysis (EPIA 2).....	34
Table 20 Cost benefit analysis (EPIA 3).....	35
Table 21 Cost benefit analysis (EPIA 4).....	36
Table 22 Cost benefit analysis (EPIA 5).....	37
Table 23 Sizing of capacitor banks.....	38
Table 24 Cost benefit analysis (EPIA 6).....	38
Table 25 Cost benefit analysis (EPIA 7).....	39
Table 26 Increase in production rate due to solar air drying	41
Table 27 Solar air drying system installation cost	42

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 8 of 49	

ABBREVIATIONS

Abbreviations	Expansions
APFC	Automatic Power Factor Correction
BEE	Bureau of Energy Efficiency
CEA	Comprehensive Energy Audit
DESL	Development Environenergy Services Limited
DG	Diesel Generator
EE	Energy Efficiency
EPIA	Energy Performance Improvement Action
GEF	Global Environmental Facility
HSD	High Speed Diesel
HVAC	Heating Ventilation and Air Conditioning
PCAVT	Panchal Ceramic Association Vikas Trust
LED	Light Emitting Diode
LT	Low Tension
MD	Maximum Demand
MSME	Micro, Small and Medium Enterprises
MT	Metric Tonnes
MTOE	Million Tonnes of Oil Equivalent
PF	Power Factor
PNG	Piped Natural Gas
PGVCL	Paschim Gujarat Vij Company Limited
R & C	Radiation & Convection
RE	Renewable Energy
SEC	Specific Energy Consumption
SEGR	Specific Energy Generation Ratio
SLD	Single Line Diagram
SME	Small and Medium Enterprises
UNIDO	United Nations Industrial Development Organization
VFD	Variable Frequency Drives

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 9 of 49	

EXECUTIVE SUMMARY

Bureau of Energy Efficiency (BEE) in association with United Nations Industrial Development Organization (UNIDO) and Global Environmental Facility (GEF) is implementing a project titled “Promoting energy efficiency and renewable energy technology in selected MSME clusters in India”. The objective of the project is to give impetus to the energy efficiency initiatives in the small and medium enterprises (SMEs) sector in India.

As part of this project DESL have been engaged to implement the project in the MSME ceramic cluster in Thangadh, Gujarat. The ceramic cluster in Thangadh consists of three distinct types of units – pottery works, insulator works and sanitary wares. The production process of all these three types of units are mostly same with main difference being the amount of ceramic material ratios being mixed in ball mill and heating time required in kilns for the 3 different products. The main fuel used in the MSME ceramic units of Thangadh is Pressurized Natural Gas (PNG).

The project awarded to DESL consists of four major tasks:

- 1) Conducting pre-activity cluster level workshop
- 2) Conducting comprehensive energy audit (CEA) at 6 units selected by the cluster association – Panchal Ceramic Association Vikas Trust(PCAVT)
- 3) Submission of reports – comprehensive energy audit, cluster level best operating practices for 5 major energy consuming equipment / process, list of common regularly monitored parameters for measurement of major energy consuming parameters, list of energy audit equipment.
- 4) Conducting three cluster level post audit training workshops

Brief Introduction of the Unit

Table 1 Details of Unit

Name of the Unit	Jay Refractories
Constitution	Private Limited
MSME Classification	Small
No. of years in operation	NA
Address: Registered Office:	Chotila Road, Thangadh-363530, Gujarat, India
Administrative Office	Chotila Road, Thangadh-363530, Gujarat, India
Factory :	Chotila Road, Thangadh-363530, Gujarat, India
Industry-sector	Ceramics
Products Manufactured	Sanitary Ware
Name(s) of the Promoters / Directors	Mr. AbhishekJadvani, Mr. JayJadvani

Comprehensive Energy Audit

The study was conducted in 3 stages:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 10 of 49	

- **Stage 1:** Walk through energy audit of the plant to understand process, energy drivers, assessment of the measurement system, assessment of scope, measurability, formulation of audit plan and obtaining required information
- **Stage 2:** Detail energy audit-testing & measurement for identification of saving potential, technology assessment and understanding of project constraints
- **Stage 3:** Data analysis, initial configuration of projects, savings quantification, vendor consultation, interaction with unit and freezing of projects for implementation and preparation of energy audit report

Production process of the unit

The main process equipment in the unit includes the following:

- The main energy utilizing equipment is kiln in which the fuel used is Pressured Natural Gas. The temperature maintained in kiln is approx. 1150 – 1180 °C (in heating zone).
- There are other equipment viz. air compressor, ball mill, ceiling fans which also contribute to the production process and consumes electrical energy.
- The raw material used is a mixture of china clay, bole clay, than clay, feldspar and quartz which is mixed along with water to form a plastic mass. The water and air is removed from this plastic mass in various process machines and the material shaped as per requirement using dies and fired in kiln for hardening. Later the material is cooled and packed for dispatch.

Identified Energy Performance Improvement Actions (EPIA)

The comprehensive energy audit covered all equipment which was operational during the field study. The main energy consuming areas in the unit are kilns which accounts for more than 70% of the total energy used.

The identified energy performance improvement actions in the kilns were providing proper insulation on the kiln to reduce radiation and convection heat loss from kiln surface, excess air control and replacement of kiln car material. It is also proposed to implement energy efficient fans for cooling and drying of molds and energy efficient LED lights in place of conventional tube lights. Other EE measures proposed were power factor improvement. The details of energy improvement actions are given in Table – 2.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 11 of 49	

Table 2 Summary of EPIA

Sl. No.	Name of the project	Estimated energy saving		Monetary savings	Estimated investment	Simple payback period	Annual Emission reduction
		PNG	Electricity	Rs. lakh/y	Rs. lakh	y	tCO ₂ /y
		SCM/y	kWh/y				
1	Skin loss reduction from the kiln	762.7		0.3	0.70	2.4	1.4
2	Excess air control in kiln	8919.7	5921	3.8	7.00	1.8	21.1
3	Installation of energy efficient fan instead of conventional fan		80640	5.53	9.6	1.74	71.8
4	Installation of LED fixture instead of T12 tube light system		12834	0.9	0.75	0.9	11.4
5	Energy monitoring system	1349.5	9271	0.5	0.45	0.9	10.6
6	Power Factor Improvement		58090 (kVARh/y)	0.058	0.3	5.16	1.5
7	Replacement of kiln car	25059.6		9.8	4.80	0.5	44.5
8	Solar air Drying		112297	7.7	8.5	1.1	99.9
	Total	36091.5	217603	28.4	31.8	1.1	262.3

The projects proposed will result in energy savings of up to 11.56% in the plant on implementation.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 12 of 49	

1 INTRODUCTION

1.1 Background and Project objective

Bureau of Energy Efficiency (BEE) in association with United Nations Industrial Development Organization (UNIDO) and Global Environmental Facility (GEF) is implementing a project titled “Promoting energy efficiency and renewable energy technology in selected MSME clusters in India”. The objective of the project is to give impetus to the energy efficiency initiatives in the small and medium enterprises (SMEs) sector in India.

The targeted 12 MSME clusters under the project and the indicative information are given below:

Table 3 List of 12 targeted MSME clusters covered under the project

S.No	Sub – sector	Cluster
1	Brass	Jagadhri, Jamnagar
2	Ceramic	Khurja, Morbi, Thangarh
3	Dairy	Gujarat, Madya Pradesh
4	Foundry	Belgaum, Coimbatore, Indore
5	Hand tools	Jalandhar, Nagaur

The objectives of this project are as under:

- Increased capacity of suppliers of energy efficiency (EE) and renewable energy (RE) based products, service providers and financing institutions;
- Increasing the levels of end-use demand and implementation of EE and RE technologies and practices by MSMEs;
- Scaling up of the project to national level;
- Strengthening policy, institutional and decision making frameworks.

1.2 Scope of work for Comprehensive Energy Audit

The general scope of work for comprehensive energy audits is as follows:

- Data Collection
 - Present energy usage (month wise) for all forms of energy from June-2014 to May-2015 (quantity and cost).
 - Data on production for corresponding period (quantity and cost).
 - Data on production cost and sales for the corresponding period (cost)
 - Mapping of process
 - Company profile including name of company, constitution, promoters, years in operation and products manufactured.
 - Existing manpower and levels of expertise
 - List of major equipment and specifications
- Analysis :-
 - Energy cost and trend analysis

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 13 of 49	

- Energy quantities and trend analysis
- Specific consumption and Trend analysis
- Scope and potential for improvement in energy efficiency
- Detailed process mapping to identify major areas of energy use.
- To identify all areas for energy saving in the following areas
 - Electrical: Power factor improvement, transformer loading, power quality tests, motor load studies, compressed air systems (including output efficiency tests), conditioned air provisions, cooling water systems, lighting load, electrical metering, monitoring and control system.
 - Thermal: Assessment to ascertain direct and indirect kiln efficiencies with intent to optimize thermal operations, heat recovery systems etc.
- Evaluate the energy consumption vis-à-vis the production levels and to identify the potential for energy savings/energy optimization (both short term requiring minor investments with attractive payback, and mid-long terms requiring moderate investments and with payback ranging from 5 - 6 years).
- Classify parameters related to EE enhancements such as estimated quantum of energy saving, investment required, time frame for implementation, payback period, re-skilling of existing man power etc. and to classify the same in order of priority.
- Assess the scope of application of renewable energy.
- Identify and recommend proper “energy monitoring system” for effective monitoring and analysis of energy consumption, energy efficiency.

1.3 Methodology

1.3.1 Boundary parameters

Following boundary parameters were set on coverage of the audit.

- Audit covered all possible energy intensive areas & equipment which were working during the field study
- All appropriate measuring system including portable instruments were used
- The identified measures normally fall under short, medium and long-term measures

1.3.2 General methodology

The following flow chart illustrates the methodology followed for carrying out different tasks.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 14 of 49	




Figure 1 General methodology

The study was conducted in 3 stages:

- **Stage 1:** Walk through energy audit of the plant to understand process, energy drivers, assessment of the measurement system, assessment of scope, measurability, formulation of audit plan and obtaining required information
- **Stage 2:** Detail energy audit-testing & measurement for identification of saving potential, technology assessment and understanding of project constraints
- **Stage 3:** Desk work for data analysis, initial configuration of projects, savings quantification, vendor consultation, interaction with unit and freezing of projects for implementation and preparation of energy audit report

1.3.3 Comprehensive energy audit – field assessment

A walk through audit was carried out before the comprehensive energy audit with a view to:

- Understand the manufacturing process and collect historical energy consumption data
- Obtaining cost and other operational data with a view to understand the impact of energy cost on the financial performance of the unit
- Assess the energy conservation potential at a macro level
- Finalize the schedule of equipment's and systems for testing and measurement

The audit identified the following potential areas of study;

- PNG fired tunnel kiln
- Electrical motors used in process
- Fans and lighting loads

Further activities carried out by the team after walk through study included:

- Preparation of the process & energy flow diagrams
- Study of the system & associated equipment.
- Conducting field testing & measurement
- Data analysis for preliminary estimation of saving potential at site

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 15 of 49	

- Discussion with the unit on the summary of findings and measures identified

Audit methodology involved system study to identify the energy losses (thermal/ electrical) followed by finding solutions to minimize the same. This entailed data collection, measurements/ testing of the system using calibrated, portable instruments, analyzing the data/ test results and identifying the approach to improve the efficiency. The various instruments used during the energy audit is as below.

Table 4 Energy audit instruments

Sl. No.	Instruments	Make	Model	Parameters Measured
01	Power Analyzer – 3 Phase (for un balanced Load) with 3 CT and 3 PT	Enercon Circutor	and AR-5	AC Current, Voltage, Power Factor, Power, Energy, Frequency, Harmonics and data recording for minimum 1 sec interval
02	Power Analyzer – 3 Phase (for balance load) with 1 CT and 2 PT	Elcontrol Energy	Nanovip plus mem	AC Current, Voltage, Power Factor, Power, Energy, Frequency, Harmonics and data recording for minimum 2 sec interval
03	Digital Multi meter	Motwane	DM 352	AC Amp, AC-DC Voltage, Resistance, Capacitance
04	Digital Clamp on Power Meter – 3 Phase and 1 Phase	Kusam - Meco	2745 and 2709	AC Amp, AC-DC Volt, Hz, Power Factor, Power
05	Flue Gas Analyzer	Kane-May	KM-900	O2%, CO2%, CO in ppm and Flue gas temperature, Ambient temperature
06	Digital Temperature and Humidity Logger	Dickson		Temperature and Humidity data logging
07	Digital Temp. & Humidity meter	Testo	610	Temp. & Humidity
08	Digital Anemometer	Lutron Prova	and AM 4201 And AVM-03	Air velocity
09	Vane Type Anemometer	Testo	410	Air velocity
10	Digital Infrared Temperature Gun	Raytek	Minitemp	Distant Surface Temperature
11	Contact Type Temperature Meter	Testo	925	Liquid and Surface temperature
12	High touch probe Temperature Meter	CIG		Temperature upto 1300°C

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 16 of 49	

13	Lux Meter	KusumMeco (KM-LUX-99) and Mastech		Lumens
14	Manometer	Comark	C 9553	Differential air pressure in duct
15	Pressure Gauge	Wika		Water pressure 0 to 40 kg

1.3.4 Comprehensive energy audit – desk work

Post audit off-site work carried out included

- Revalidation of all the calculations for arriving at the savings potential
- Quick costing based on DESL database or through vendor interactions as required
- Configuration of individual energy performance improvement actions
- Preparation of audit report

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 17 of 49	

2 ABOUT THE MSME UNIT

2.1 Particulars of the unit

Table 5 General particulars of the unit

S. No	Particulars	Details
1	Name of the unit	Jay Refractories
2	Constitution	Private
3	Date of incorporation / commencement of business	NA
4	Name of the contact person Mobile/Ph.No. E-mail ID	Mr. Jay Jadvani (co-owner) +91-98245-11466 NA
5	Address of the unit	Chotila Road, Thangadh-363530, Gujarat, India
6	Industry / sector	Ceramic
7	Products manufactured	Sanitary Wares
8	No. of operational hours	24
9	No. of shifts / day	3
10	No. of days of operation / year	300
11	Whether the unit is exporting its products (yes / no)	NA
12	No. of employees	NA

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 18 of 49	

3 DETAILED TECHNICAL FEASIBILITY ASSESSMENT OF THE UNIT

3.1 Description of manufacturing process




Figure 2 Process Flow Diagram

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 19 of 49	

3.1.1 Process description

Jay Refractories is a sanitary ware ceramic manufacturer

The process description is as follows:

- The raw materials clay, feldspar and quartz are mixed together with water in the ball mill for a period of 5 to 7 hours.
- It is then transferred in to the agitator tank for thorough mixing. With the help of centrifugal mud pump, the mixture is transferred to the sieve filter to remove water.
- The slurry is allowed to dry after pouring it in to mold dies made of plaster of Paris. Pressing of slurry is done using pressurized air to ensure tight bonding in the mold and leaving no chance of cavities.
- The molds are allowed to dry under ceiling fans for about 1-2 days depending on atmospheric humidity.
- Then the materials are glazed, painted and stacked on the kiln cars for firing to obtain strength. The firing zone temperature in the kiln is maintained at 1150 – 1180°C.
- After firing, the products are quality checked, packed and dispatched.

3.2 Inventory of process machines/equipment and utilities

The major energy consuming equipment's in the plants are

- **Ball mill:** Here the raw materials like clay, feldspar and quartz are mixed in the ratio of 2:1:1 respectively along with water to form a plastic mass.
- **Glaze mill:** For producing glazing material used on sanitary product.
- **Air Compressor:** Pressurized air is used at several locations in a unit viz. pressing of slurry, air cleaning, glazing etc.
- **Agitator:** The plastic mass after mixing in ball mill is poured in to a sump where an agitator is fitted for thorough mixing of materials and preventing it to settle at the bottom.
- **Jigger jollies:** The required shapes of the final product are made by the jigger jollies along with molds and then dried for the complete removal of moisture.
- **Tunnel Kiln:** The shaped materials are glazed, painted and then stacked on the kiln car which is then sent for firing in the tunnel kiln with the help of pusher motor kept at a specified rpm. The tunnel is about 55 m long and the temperature gradually increases up to firing zone and then decreases (in the cooling zone) with the highest temperature being 1150°C. Once the kiln car comes out of the cooling zone the materials are further cooled, quality tested and packed for dispatch.

3.3 Types of energy used and description of usage pattern

Both electricity and thermal energy is used in different manufacturing processes. The overall energy use pattern in the unit is as follows:

- Electricity is supplied from two different sources:
 - From the Utility, Paschim Gujarat Vij Company Ltd. (PGVCL)

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 20 of 49	

- Captive backup DG sets for whole plant
- Thermal energy is used for following applications :
 - PNG for tunnel kiln

Total energy consumption pattern for the period April-14 to March-15, from different sources are as follows:

Table 6 Energy cost distribution

Particular	Energy cost distribution		Energy use distribution	
	Rs. In Lakhs	% of total	MTOE	% of total
Grid – Electricity	21.1	8.6	26.57	5.31
Diesel – DG	NA	0	0	0
Thermal – PNG	224.5	91.4	473.02	94.69
Total	245.65	100	499.59	100




Figure 3 Energy cost share (Rs. Lakh)




Figure 4 Energy use share (MTOE)

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 21 of 49	

The major observations are as under

- The unit uses both thermal and electrical energy for the manufacturing operations. Electricity is sourced from the grid as well as self-generated in DG sets when the grid power is not available. Source of thermal energy is from combustion of PNG, which is used for firing in the kiln.
- PNG used in kilns account for 91% of the total energy cost and 94% of overall energy consumption.
- Electricity used in the process accounts for the remaining 6% of the energy cost.

3.4 Analysis of electricity consumption by the unit

3.4.1 Electricity load profile

Following observation has been made from the utility inventory.

- The plant and machinery load is 104 kW
- The utility load (air compressor, fan and lighting) is about 36.3 kW including the single phase load
- The plant total connected load is 140kW

Table 7 Equipment wise connected load

Sr. No.	Equipment	Numbers	Capacity (kW)	Total capacity
1	Ball mill motor	2	30	60
2	Glazing Ball Bill	3	5.5	16.5
3	Compressor	1	15	15
4	Air blower	3	5+3+7.5	15.5
5	Disperser Motor	2	2	4
6	Slurry Pump	2	4	8
7	Lighting loads	60	0.035	2.1
8	Fan Load	320	0.06	19.2
Total		264		140.3

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 22 of 49	

A pie chart of the entire connected load is shown in the figure below:




Figure 5 Details of connected load

As shown in the pie chart of connected loads, the maximum share of connected electrical load is for the ball mill – 54%, followed by air compressor – 12%, Ceiling fan – 15%, Kiln air blowers – 9%, Other machinery including slurry mud pump and lighting load – 5% each and disperser motor (agitator) of 2%.

3.4.2 Supply from utility

Electricity is supplied by the Paschim Gujarat Vij Company Ltd. (PGVCL).

The tariff structure is as follows:

Table 8 Tariff structure

Particulars	Tariff structure	
Energy Charges	4.7	Rs./kWh
Reactive power charges	0.01	Rs./kVARh
Fuel Surcharge	1.60	Rs./kVAh
Electricity duty	0.1	Rs./kVAh
Meter charges	225	Rs.

(As per bill for February – 15)

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 23 of 49	

The single line diagram of electrical distribution system is shown in the figure below:




Figure 6 SLD of electrical load

Power factor

The utility bills of the unit reflect the power factor. A study was conducted by logging the electrical parameters of the main incomer using a power analyzer. The average power factor was found to be 0.82 with the minimum being 0.68 and the maximum being 0.93.

Maximum demand

Maximum demand as reflected in the utility bill is 84 kVA from the bill analysis.

3.4.3 Mont wise electricity consumption

Month wise total electrical energy consumption from different source is shown as under:

Table 9 Electricity consumption & cost

	Electricity Used (kWh)	Electricity Cost (Rs.)
Jun-14	25752	176045.1
Jul-14	25752	176045.1
Aug-14	25752	176045.1
Sep-14	25752	176045.1

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 24 of 49	

Oct-14	25752	176045.1
Nov-14	25752	176045.1
Dec-14	25752	176045.1
Jan-15	24175	167992.6
Feb-15	28550	207267.8
Mar-15	22540	152210
Apr-15	27287	181060.1
May-15	29660	197600
Total	334776.0	2288586.8

3.5 Analysis of thermal consumption by the unit

PNG is used as the fuel for firing in the kiln. PNG is available throughout Thangadh cluster with GSPC (Gujarat State Petroleum Company) as a common supplier. Based on the gas bill shared for the month of Mar-15 to May-15 annual fuel consumption has been extrapolated as under:

Table 10 PNG used as fuel

Month	PNG consumption (scm/month)	Amount
Jun-14	45834.96	1870999
Jul-14	45834.96	1870999
Aug-14	45834.96	1870999
Sep-14	45834.96	1870999
Oct-14	45834.96	1870999
Nov-14	45834.96	1870999
Dec-14	45834.96	1870999
Jan-15	45834.96	1870999
Feb-15	45834.96	1870999
Mar-15	47117.8	2074736
Apr-15	45404.5	1806669
May-15	44982.6	1731592
Total	550019.6	22451988

3.6 Specific energy consumption

Annual production data was available from the unit in metric tonnes (MT). Based on the available information, various specific energy consumption parameters have been estimated as shown in the following table:

Table 11 Overall specific energy consumption

Parameters	Value	UoM
Annual Grid Electricity Consumption	309024	kWh
Annual DG Generation Unit	NA	kWh

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 25 of 49	

Annual Total Electricity Consumption	309024	kWh
Annual Thermal Energy Consumption (PNG)	550019.6	SCM
Annual Energy Consumption; MTOE	499.59	MTOE
Annual Energy Cost	245.65	Lakh Rs
Annual Production	3240	MT
SEC; Electricity from Grid	95	kWh/MT
SEC; Thermal	170	SCM/MT
SEC; Overall	0.15	MTOE/MT
SEC; Cost Based	7580	Rs./MT

Basis for estimation of energy consumption in terms of tons of oil equivalent are as follows:

- Conversion Factors
 - Electricity from the Grid : 860 kCal/Kwh
- GCV of Diesel : 11,840 kCal/ kg
- Density of HSD : 0.8263 kg/litre
- GCV of PNG : 8600kCal/scm
- CO₂ Conversion factor
 - Grid : 0.89 kg/kWh
 - Diesel : 3.07 tons/ ton

3.7 Baseline parameters

The following are the general base line parameters, which have been considered for the techno-economic evaluation of various identified energy cost reduction projects as well as for the purpose of comparison post implementation of the projects. The costs shown are landed costs.

Table 12 Baseline parameters

Electricity cost (Excluding Rs/kVA)	NA	Rs./ KVAH inclusive of taxes
Weighted Average Electricity Cost	7.2	Rs./ kWh for 2013-14
Percentage of total DG based Generation	NA	
Average Cost of PNG	41	Rs./litre
Operating Days per year	300	Days / year
Operating Hours per day	24	Hours / day
Production	3240	MT

3.8 Identified energy conservation measures in the plant

Diagnostic Study

A detailed study was conducted during CEA in the unit and some observations were made and few ideas of EPIAs were developed. Summary of key observations are as follows:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 26 of 49	

3.7.1 Electricity Supply from Grid

The electrical parameters at the main electrical incomer feeder from PGVCL of the unit are recorded for 8 hours using portable power analyzer. Following observation has been made:

Table 13 Diagnosis of electric supply

Name of Area	Present Set-up	Observations during field Study & measurements	Ideas for energy performance improvement actions
Electricity Demand	Power is supplied to this unit from PGVCL through a common distribution feeder. The contract demand of the unit is 140 kVA	The maximum kVA recorded during study period was 74 kVA. As per utility bill; the MD is 90 KVA which is less than the contract demand.	No EPIAs were suggested.
Power Factor	Unit has an LT connection and billing is in kWh. The utility bills does not reflect the PF of the unit. The unit does not have an APFC panel installed to control the power factor.	The average PF found during the measurement was 0.81. It varies between 0.68 and 0.934 where the difference is very large.	Power factor improvement is suggested by installing inline static capacitor bank. Additionally APFC panel can be installed for control.
Voltage variation	The unit has no Servo stabilizers for voltage regulation.	The voltage profile of the unit is satisfactory and average voltage measured was 428 V. Maximum voltage was 456 V and minimum was 407 V.	A servo stabilizer can be installed to maintain voltage below 405 V.

In order to monitor the overall energy performance, the installation of a basic energy monitoring system has been proposed for the unit.

3.7.3 Electrical consumption areas

The section-wise consumption of electrical energy is shown in Table 6. Over 90% of the energy consumption is in the manufacturing operations and about 10% is in utilities.

The details of measurements conducted, observation made and ideas generated for energy conservation measures are as follows:

Name of Area	Present Set-up	Observations during field Study & measurements	Proposed Energy performance improvement actions
--------------	----------------	--	---

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015		Page 27 of 49

Ball mill	There are 5 ball mills in the unit out of which 2 are connected with 40 HP motors and 3 with a 5.5 HP motor respectively. Ball mills account for 54% of overall energy consumption.	Out of the 5 ball mills 2 of 1.5 T was on operation during CEA and its characteristics were studied. The results of the study are below:	No EPIAs were suggested for ball mill.												
		<table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>Avg. PF</th> </tr> </thead> <tbody> <tr> <td>Mill 1 (40 HP)</td> <td>17.85</td> <td>0.976</td> </tr> <tr> <td>Mill 2 (5.5 HP)</td> <td>2.68</td> <td>0.84</td> </tr> </tbody> </table>	Machine	Avg. kW	Avg. PF	Mill 1 (40 HP)	17.85	0.976	Mill 2 (5.5 HP)	2.68	0.84				
Machine	Avg. kW	Avg. PF													
Mill 1 (40 HP)	17.85	0.976													
Mill 2 (5.5 HP)	2.68	0.84													
Air Compressor	The unit has 1 air compressor. It is of reciprocating type. Rated load is about 16.5 KW and operating set point pressure is 80 psi	Many air leaks were found inside the unit. Loading power of compressor is as below:	Savings in compressed air power through attending leakages												
		<table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>Avg. PF</th> </tr> </thead> <tbody> <tr> <td>Air compressor</td> <td>15.83</td> <td>0.85</td> </tr> </tbody> </table>	Machine	Avg. kW	Avg. PF	Air compressor	15.83	0.85							
Machine	Avg. kW	Avg. PF													
Air compressor	15.83	0.85													
Kiln blower	The unit has kiln blowers which are used for supplying combustion and cooling air in the tunnel kiln. The blowers account for 9% of the total electricity consumption.	Data logging was carried out on the cooling zone blower to establish the power profile. The results of the study are below:	EPIA suggested for maintaining the draft pressure by adjusting Kiln blowers												
		<table border="1"> <thead> <tr> <th>Machine</th> <th>Avg. kW</th> <th>Avg. PF</th> </tr> </thead> <tbody> <tr> <td>Cooling Zone</td> <td>4.03</td> <td>0.99</td> </tr> <tr> <td>Fire Zone</td> <td>4.23</td> <td>0.99</td> </tr> <tr> <td>Preheating</td> <td>1.67</td> <td>1</td> </tr> </tbody> </table>	Machine	Avg. kW	Avg. PF	Cooling Zone	4.03	0.99	Fire Zone	4.23	0.99	Preheating	1.67	1	
Machine	Avg. kW	Avg. PF													
Cooling Zone	4.03	0.99													
Fire Zone	4.23	0.99													
Preheating	1.67	1													

3.7.4 Thermal consumption areas

As discussed in our earlier section Kiln accounts for about 90% of energy cost and 94% of the energy use. The details of present set-up, key observations made and potential areas for energy cost reduction have been mentioned in the table below:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 28 of 49	

Table 14 Kiln and Kiln car details

Sr. No	Parameter	Value	Unit
1	Kiln Operating time	24	hour
2	Number of burner to left	6	-
3	Number of burner to right	6	-
4	Kiln car residence time	18	hour
5	Kiln cars per day	33	-
6	Stock weight per kiln car	300-330	kg
7	Waste Heat recovery option	No	

Table 15 Kiln Dimensions

Zone	Height	Width	Length	UoM
Preheating	1.85	3.2	21	meter
Firing	2.35	4.8	13	meter
Cooling	1.85	3.2	21	meter




Figure 7 Temperature curve

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 29 of 49	

Table 16 Thermal energy conservation measures

Name of Area	Present Set-up	Observations during field Study & measurements	Proposed Energy performance improvement actions								
<p>Kiln</p>	<p>PNG is used as a fuel in the kiln to heat the ceramic material to the required temperature.</p> <p>The required air for fuel combustion is supplied by a blower (FD fan).</p> <p>The dead weight of kiln car was high.</p>	<p>The fuel consumption of kiln has been identified by dip stick method as no metering system was available.</p> <table border="1" data-bbox="483 600 1145 871"> <thead> <tr> <th data-bbox="483 600 660 804">Machine</th> <th data-bbox="660 600 804 804">Oxygen Level measured in Flue Gas</th> <th data-bbox="804 600 970 804">Ambient Air Temp</th> <th data-bbox="970 600 1145 804">Exhaust Temperature of Flue Gas</th> </tr> </thead> <tbody> <tr> <td data-bbox="483 804 660 871">Tunnel kiln</td> <td data-bbox="660 804 804 871">6.5%</td> <td data-bbox="804 804 970 871">37.4Deg C</td> <td data-bbox="970 804 1145 871">107Deg C</td> </tr> </tbody> </table> <p>From the above Table, it is clear that the oxygen level measured in flue gas was high.</p> <p>The inlet temperature of raw material in kiln was in the range of 35 – 42deg C which was the ambient air temperature.</p> <p>The kiln car is made up of fire clay bricks, pillars and tiles to stack the materials. All these materials have different specific heats. It is to be noted that the kiln car takes away lot of useful heat.</p>	Machine	Oxygen Level measured in Flue Gas	Ambient Air Temp	Exhaust Temperature of Flue Gas	Tunnel kiln	6.5%	37.4Deg C	107Deg C	<p>No waste heat recovery recommendation has been suggested as the exit flue gas temperature is low and cannot be used for waste heat recovery</p> <p>Reducing the radiation and convection losses from the kiln surface by improving insulation is recommended in firing zone of kiln.</p> <p>Reducing opening losses in kiln is recommended.</p> <p>It is recommended to change the kiln car material with other materials of lower specific heat values and that absorbs lesser heat.</p>
Machine	Oxygen Level measured in Flue Gas	Ambient Air Temp	Exhaust Temperature of Flue Gas								
Tunnel kiln	6.5%	37.4Deg C	107Deg C								

4 EE TECHNOLOGY OPTIONS AND TECHNO - ECONOMIC FEASIBILITY

During CEA of plant all energy consuming equipment and processes were studied. The analysis of all major energy consuming equipment and appliances were carried out and the same was discussed in earlier section of this report.

Based on the analysis, Energy Performance Improvement Actions (EPIA) has been identified; each of which are described below:

4.1 EPIA 1: Reduction in radiation and convection losses from surface of kiln

Technology description

A significant portion of the losses in a kiln occurs as radiation and convection loss from the kiln walls and roof. These losses are substantially higher on areas of openings or in case of infiltration of cold air. Ideally, optimum amount of refractory and insulation should be provided on the kiln walls and roof to maintain the skin temperature of the furnace at around 45-50DegC, so as to avoid heat loss due to radiation and convection. Refractories are heat-resistant materials that constitute the linings for high-temperature tunnel kilns. In addition to being resistant to thermal stress and other physical phenomena induced by heat, refractories must also withstand physical wear and corrosion by chemical agents.

Thermal insulations are used for reduction in heat transfer (the transfer of thermal energy between objects of differing temperature) between objects in thermal contact or in range of radiative influence.

A kiln wall is designed as a combination of refractory and insulation layers, with the objective of retaining maximum heat inside the kiln to avoid losses from kiln walls.

Study and investigation

There are three different zones in kiln i.e. pre- heating, firing and cooling zones. The surface temperature of each zones were measured. The average surface temperature of kiln body in the firing zone must be in the range of 45-50deg C and it was measured as 85°C, hence the kiln surface has to be properly insulated to keep the surface temperature within the specified range.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 31 of 49	




Figure 8 Surface Temperature in each zone

Recommended action

Recommended surface temperature of the firing zone has to be brought to within 50 deg. C to reduce the heat loss due to radiation and convection and utilize the useful heat. The amount of heat lost through radiation and convection in each zone is given in the table below.

Table 17 R & C losses

Total radiation and convection heat loss per hour	Units	Value
Pre-Heating Zone	kCal / hr	462
Heating Zone	kCal / hr	1,296
Cooling Zone	kCal / hr	627
Total R&C loss	kCal / hr	2,385

The cost benefit analysis of the energy conservation measure is given below:

Table 18 Cost benefit analysis (EPIA 1)

Parameters	UoM	Value
Present average skin temperature of Heating zone	deg. C	74.75
Recommended skin temperature of Heating Zone	deg. C	50.00
Present heat loss due to Radiation & Convection from Work side wall	kCal / hr	1,296
Recommended heat loss due to Radiation & Convection from Heating zone	W / m ²	101.71
	kCal / m ²	87.47

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 32 of 49	

Parameters	UoM	Value
	kCal / hr	411
Total reduction in heat loss due to Radiation & convection by limiting skin temperature at Heating zone	kCal / hr	885
Calorific value of Fuel	kCal / kg	12,652
Equivalent savings in Fuel	kg / hr	0.07
	Nm3 / hr	
Plant running time	days / year	300
	hrs / day	24
Annual savings in Fuel	kg/y	503
Cost of fuel	Rs / kg	58.485
Annual Monetary savings	Rs / Year	29,441
	Rs. Lacs / Year	0.29
Estimated investment	Rs. Lakh	0.7

4.2 EPIA 2: Excess air control

Technology description

It is necessary to maintain optimum excess air levels in combustion air supplied for complete combustion of fuel. The excess air levels are calculated based on oxygen content in the flue gases. The theoretical air required for combustion of any fuel can be known from the ultimate analysis of the fuel. All combustion process requires certain amount of excess air in addition to the theoretical air supplied. Excess air supplied needs to be maintained at optimum levels, as, too much excess air results in excessive heat loss through the flue gases whereas too little excess air results in incomplete combustion of fuel and formation of black colored smoke in flue gases.

In general, in most of the kilns, fuel is fired with too much excess air. This result in the formation of excess flue gases, taking away the heat produced from the combustion and increasing the fuel consumption. This also results in the formation of excess GHG emissions.

A PID controller if installed measures the oxygen levels in the flue gases at the exit of the kiln and based on that the combustion air flow from FD fan (blower) is regulated and subsequently proper temperature and optimum excess air for combustion is attained in the kiln.

Study and investigation

Presently there was no proper automation and control system installed in the kiln to monitor and maintain optimum excess air levels. Fuel was fired from the existing burner system and no air flow

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 33 of 49	

control mechanism was in place for maintaining proper combustion of the fuel. The combustion air and cooling air (through air curtains) were being supplied from the same FD fan. The pressures required for combustion and for cooling air were different and supplying both the air from one common FD fan was not a good practice.

Recommended action

Two separate blowers have been recommended for supplying combustion air and cooling air. It is proposed to install control system to regulate the supply of excess air for proper combustion. As a thumb rule, reduction in every 10 percent of excess air will save one percent in specific fuel consumption. The cost benefit analysis of the energy conservation measure is given below:

Table 19 Cost benefit analysis (EPIA 2)

Parameters	UOM	Present	Proposed
Oxygen level in flue gas	%	7.1	3.00
Excess air level	%	51.08	16.67
Dry flue gas loss	%	3.75	
Saving in fuel	With every 10% reduction in excess air leads to a saving in specific fuel consumption by 1%		
Specific fuel consumption	kg/t	52.8	50.98
Saving in specific fuel consumption	kg/h		0.82
Savings in fuel cost	Rs. Lakh/y		3.44
Installed capacity of blower	kW	5	4.18
Operating hours	hrs/y	7200	7200
Electrical energy consumed	kWh/y	36000	30078.72
Savings in electrical energy	kWh/y		5921.28
Cost of increased electrical energy	Rs. Lakh/y	2.47	2.06
Savings in terms of energy cost	Rs. Lakh/Y		3.85
Estimated investment	Rs. lakh		7.00
Simple payback	y		1.82

4.3 EPIA 3: Replacing conventional ceiling fans with Energy efficient fans

Technology description

Replacing the old fans of conventional type installed in various sections of the plant with energy efficient fans will reduce the power consumption by half. The energy efficient fans have a noiseless operation and it is controlled by electronic drives which on speed reduction will automatically sense the rpm and reduce the power consumption. Since large number of ceiling fans are used in the ceramic units for drying purposes these EE fans can be best suited for energy conservation.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015		Page 34 of 49

Study and investigation

The unit is having about 320 nos. of conventional ceiling fans which are very old and can be replaced with EE fans.

Recommended action

It is recommended to replace the present ceiling fans with energy efficient fans. The cost benefit analysis of the same is given in the table below:

Table 20 Cost benefit analysis (EPIA 3)

Data & Assumptions	UOM	Present	Proposed
Number of Ceiling fans in the plant	Nos	320	320
Running hours per day (avg.) - for fans	hrs / day	24	24
Power consumption at Maximum speed	kW	0.07	0.04
Number of working days/year	days / year	300	300
Tariff for unit of electricity	Rs / kWh	6.85	6.85
Fan unit price	Rs./piece	0	3000
Electricity consumption:			
Electricity demand	kW	22.40	11.2
Power consumption by fans in a year	kWh/y	161280	80640
Savings in terms of power consumption	kWh/y	80640	
Savings in terms of cost	Rs. Lakh/y		5.53
Estimated investment	Rs. Lakh/y		9.6
Payback period	y		1.74

4.4 EPIA 4: Energy efficient light fixture

Technology description

Replacing conventional lights like T-12s, T-8s, CFLs, incandescent lamps etc with LED lights helps reduce the power consumption and also result in higher illumination (lux) levels for the same power consumption.

Study and investigation

The unit is having 60 T-8 tubelight.

Recommended action

It is recommended to replace the above mentioned light fixtures with energy efficient LED lamps which shall help reduce present lighting energy consumption. The cost benefit analysis for the EPIA is given below:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 35 of 49	

Table 21 Cost benefit analysis (EPIA 4)

Particulars	Unit	Existing	Proposed
Fixture		T-8	16 Watt LED tube light
Power consumed by T8	W	35	16
Power consumed by Ballast	W	12	0
Total power consumption	W	47	16
Operating Hours/day	Hr	16	16
Annual days of operation	Day	300	300
Energy Used per year/fixture	kWh	226	77
Energy Rate	Rs/kWh	6.85	6.85
No. of Fixture	Unit	60	60
Power consumption per year	kWh/Year	19458	6624
Operating cost per year	Rs. Lakh/Year	1.33	0.45
Saving in terms of electrical energy	kWh/Year		12834
Savings in terms of cost	Rs. Lakh/Year		0.88
Investment per fixture of LED	Rs. Lakh		0.0125
Investment of project	Rs. Lakh		0.75
Payback period	Years		0.85

4.5 EPIA 5: Energy monitoring system

Technology description

Installation of energy monitoring system on a unit will monitor the energy consumed by various machines. From this we can set the benchmark energy consumption with respect to production for the machines. If an increase in energy consumption is noticed for any machine, then the reasons for the increased consumption can be diagnosed and proper remedial actions can be taken.

Study and investigation

It was observed during the audit that, online data measurement is not done on the main incomer as well as at various electrical panels for the energy consumption. It was also noticed that there were no proper fuel monitoring system installed in the DG sets and in kilns like on-line flow-meters.

Recommended action

It is recommended to install online electrical energy monitoring systems (smart energy meters) on the main incomer and on the various electricity distribution panels.. This measure will help in reduction in energy consumption by 3% approx. from its present levels. The cost benefit analysis for this project is given below:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015		Page 36 of 49

Table 22 Cost benefit analysis (EPIA 5)

Parameters	Unit	As Is	To Be
Energy monitoring saving	%		3.00
Energy consumption of major machines per year	kWh/Yr	309,024	299,753
Annual electricity saving per year	kWh/Yr		9,271
W. Average Electricity Tariff	Rs/kWh		6.85
Annual monetary savings	lakh Rs/yr		0.64
Estimate of Investment	Lakh Rs		0.25
Simple Payback	Months		4.72
Energy monitoring saving	%		3.00
Current fuel consumption	kg/y	29,689	28798
Annual fuel saving per year	kg/y		891
Unit Cost	Rs./kg		58.48
Annual monetary savings	Lakhs Rs/year		0.52
Estimate of Investment	Lakhs Rs		0.20
Simple Payback	years		0.38

4.6 EPIA 6: Power factor improvement

Technology description

Power factor plays an important role in electricity system of industries. If proper power factor is not maintained it leads to penalty in the electricity billing. Present system of billing in Rs / kVAh has the power factor component in-built in the tariff structure. Poor power factor will result in higher electricity bill for the unit, hence, it is necessary to maintain high power factor. To maintain high power factor, properly sized capacitors needs to be connected in the electricity line. The value of capacitors to be connected will vary with respect to load and the existing PF and can be controlled using APFC panels.

Study and investigation

An APFC panel is already installed in the unit and the power factor was found to be deviating beyond 0.98 due to unhealthy condition of few capacitors. It is recommended to replace the de-rated capacitors. The average power factor maintained in the unit was found to be 0.89 during the study.

Recommended action

A high power factor of 0.99 needs to be maintained to avoid higher electricity bills as the billing structure in kWh already factors the effect of power factor into the total amount billed. To maintain high power factor, proper sizing of capacitors needs to be made which is given in the table:

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015		Page 37 of 49

Table 23 Sizing of capacitor banks

Sizing of Capacitor Bank		
Parameters	Unit	Value
Present Minimum PF	Cos ϕ	0.68
Present Maximum PF	Cos ϕ	0.93
Present Average PF	Cos ϕ	0.82
Minimum Load	kW	15.0
Maximum Load	kW	50.3
Average Load	kW	31.8
Target Average Power Factor		1.00
Capacitor Bank Capacity at Average Load and Average PF	kVAr	22.3
Capacitor Bank Capacity at Maximum Load and Average PF	kVAr	35.2
Capacitor Bank Capacity at Maximum Load and Minimum PF	kVAr	54.4
Capacitor Bank Capacity at Minimum Load and Minimum PF	kVAr	16.2
Required capacitor bank for PF at Unity	kVAr	54.4
APFC Panel (Rating) for maintaining optimum PF	kVAr	54
Baseline Parameters		
Present Tariff of Electricity including Tax	Rs./kVAh	7
Reference Month of Bill		May-15

The cost benefit analysis for installation of APFC panels in the unit is given below in the table:

Table 24 Cost benefit analysis (EPIA 6)

Parameters	Unit	AS is	To be
Minimum PF	Cos ϕ	0.68	1.00
Maximum PF	Cos ϕ	0.93	1.00
Average PF	Cos ϕ	0.82	1.00
Maximum Load	kW	50.3	50.30
Average Load	kW	31.85	31.85
Capacitor Bank	kVAr	0.0	54.4
Annual Grid Electricity Consumption	kVAh/Year	321900.	263809.
		0	6
	kWh/Year	263809.	263809.
		6	6
Annual Grid Electricity Savings	kVAh/Year	-	58090.3
			9
Electricity Tariff	Rs./kVAh	0.1	0.1
Annual Monetary Saving	Lakh Rs./Year	-	0.05809
Investment	Lakh Rs	-	0.30
Payback Period	Year	-	5.16

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015		Page 38 of 49

4.7 EPIA 7: Replacement of Kiln car material

Technology description

The existing kiln car consists of refractory bricks and tiles which are very heavy and hence increases the dead weight of the car. The present kiln car also carries away much of the useful heat supplied to the kilns. This reduces the kiln efficiency. Instead of the present kiln car material, a new material called ultralite¹ can be used in the kiln car construction, which will help in reducing its dead weight. This will also help in reduction in kiln losses due to useful heat carried away by kiln car as this material has lesser specific heat.

Study and investigation

Presently kiln car used is made up of HFK bricks, quadrite tiles and pillars and these materials contribute to a dead weight (of kiln car) of 500 kg. The ceramic materials to be heated are placed on the kiln car on make-shift racks and this kiln car travels all along the length of the kiln from pre-heating zone to heating (or firing) zone to cooling zone. The kiln car also gains useful heat that is supplied by fuel to heat the ceramic materials and they carry the same with them out of the kiln. The heat gained by kiln car is wastage of useful heat supplied as the heat is being supplied to heat the ceramic material and not the kiln car, but this is a necessary wastage as the materials has to be placed on kiln cars to travel along the kiln. So, in order to reduce this necessary wastage, it is recommended to select kiln car material that shall absorb as minimum heat as possible, so that most of the heat supplied is gained by the ceramic material. This will also help in reduced fuel consumption in the kiln.

Recommended action

It is recommended to replace the present kiln car material with “ultralite” material with little modification in the arrangement of refractories which will help reduce the dead weight of the kiln car thereby reducing the heat gained by the same and also help in reduction in fuel consumption in the kiln by 30% approximately. The cost benefit analysis for the EPIA is given in the table below:

Table 25 Cost benefit analysis (EPIA 7)

Data	UOM	As is	To be
Production of the material	tph	0.37	0.37
Weight of existing kiln car	kg	500	500
Total number of kiln car inside kiln	Nos.	33	33
Initial temperature of kiln car	Deg c	33.5	33.5
Final temperature of kiln car	Deg c	1124.71429	1124.7143
Estimated percentage saving by new kiln car material	%	30	
Heat carried away by the kiln material	kcal/hr	101,086	70760
Reduction in the heat carried by the kiln	kcal/hr		30,326

¹ Kiln car material by Interkiln Industries, Ahmedabad, Gujarat.

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015		Page 39 of 49

Operating hrs of kiln	hrs	6900	6900
Savings in terms of fuel consumption	kg/y		16,539
Savings in terms of cost	Rs. Lakh/y		9.8
Estimated investment of kiln material	Rs. Lakh/y		4.80
Payback period	y		0.5

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015		Page 40 of 49

5 Renewable Energy Utilization

Solar Air Drying




Figure 9 Solar air drying schematic diagram

Wet Solid molds in ceramic industries are conventionally dried using ceiling fans with 1200 mm blade diameter circulating air in open space. This method is extremely dependent on atmospheric conditions such as relative humidity in atmosphere and atmospheric temperature. Also drying rate is lower because the contact air to surface drying area is irregular. To overcome this, a proposal of hot room is introduced. Hot room is conceptually similar to Green House. In Hot room dry air with temperature above atmospheric temperature is distributed uniformly. This hot air is generated by heat exchange between solar water heater and suction air from air blower. Solar water heaters are technically and commercially available source of heat pumps. In this way electricity cost of conventional ceiling fans is saved and drying time is reduced which greatly decreases the production time at constant tunnel kiln operation time. But this setup requires additional investment such as solar water heater system, heat exchangers, air circulating system and hot room. Also operating cost of circulating pump and air blowers add up. A techno-commercial benefit is to be obtained by comparing increase in production to the increase in electricity cost. A calculation regarding reduction in drying rate using solar air drying is shown in below table.

Table 26 Increase in production rate due to solar air drying

Parameter	As is	To be	Unit
Humidity in atmosphere	40	40	%
Moisture content in mold	30	30	%
Final Moisture content	10	10	%
Weight of Drying Solid	20	20	kg
Moisture to be removed	4.6	4.6	kg
Drying Surface Area	0.72	0.72	m ²

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 41 of 49	

Parameter	As is	To be	Unit
Drying Flux	0.003	0.01	kg/m ² s
Time Taken	11.83	3.55	hr
Drying Rate	0.233	0.777	kg/hr
Production Rate	10.8	11.9	tpd
Annual Production	3240	3564	ton
Power saving of drying fans	0	7.7	lakh/annum
Estimated Investment		8.5	Lakh
Payback (exclusive of profit in increase production rate & increase in power cost of air drying system)		1.1	year

Below table shows estimated investment on setting up solar air drying system for drying wet solid molds.

Table 27 Solar air drying system installation cost

System	Capacity	unit	Initial Cost (Rs.)	Annual Power cost (Rs./annum)
Solar water heater	500	Liter per day (lpd)	66000	48240
	1000	lpd	110000	72360
Heat exchanger (fan coil Unit)			40000	
FD blower	10	kW	25000	482400
Exhaust Fan	2	kW	3000	96480
Hot room Ducting	60	m ²	30000	
Total Cost		with 500 lpd	1.64 Lakh	6.27 lakh
		with 1000 lpd	2.08 Lakh	6.51 Lakh

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015		Page 42 of 49

6 ANNEXURE

Kiln efficiency calculations

Input parameters

Input Data Sheet		
Type of Fuel	PNG	
Source of fuel	GSPC	
	Value	Units
Tunnel Kiln Operating temperature (Heating Zone)	1125	Deg C
Initial temperature of kiln car	33.5	Deg C
Avg. fuel Consumption	23.8	kg/hr
Flue Gas Details		
Flue gas temp.	107	deg C
Preheated air temp./Ambient	33.5	deg C
O2 in flue gas	7.1	%
CO2 in flue gas	10.7	%
CO in flue gas	68	ppm
Atmospheric Air		
Ambient Temp.	33.5	Deg C
Relative Humidity	48.3	%
Humidity in ambient air	0.03	kg/kgdry air
Fuel Analysis		
C	74.57	%
H	24.70	%
N	0.72	%
O	0.00	%
S	0.01	%
Moisture	0.0	%
Ash	0.00	%
GCV of PNG	12652	kcal/kg
Ash Analysis		
Unburnt in bottom ash	0.00	%
Unburnt in fly ash	0.00	%
GCV of bottom ash	0	kcal/kg
GCV of fly ash	0	kcal/kg
Material and flue gas data		
Weight of Kiln car material	500	Kg/Hr
Weight of ceramic material being heated in Kiln	450	Kg/Hr
Weight of Stock	450	kg/hr
Specific heat of clay material	0.22	Kcal/kgdegC

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 43 of 49	

Specific heat of kiln car material	0.23	Kcal/kgdegC
Avg. specific heat of fuel	0.559	Kcal/kgdegC
fuel temp	33.5	deg C
Specific heat of flue gas	0.26	Kcal/kgdegC
Specific heat of superheated vapour	0.45	Kcal/kgdegC
Heat loss from surfaces of various zone		
Radiation and from preheating zone surface	462	kcal/hr
Radiation and from heating zone surface	1296	kcal/hr
Radiation and from firing zone surface	627	kcal/hr
Heat loss from all zones	2385	kcal/hr
For radiation loss in furnace(through entry and exit of kiln car)		
Time duration for which the Kiln car enters through preheating zone and exits through cooling zone of kiln	19	Hr
Area of opening in m2	4.42	m2
Co-efficient based on profile of kiln opening	0.7	
Max operating temp. at door	353	deg K


Efficiency calculations

Calculations	Values	Unit
Theoretical Air Required	17.25	kg/kg of fuel
Excess Air supplied	51.08	%
Actual Mass of Supplied Air	26.06	kg/kg of fuel
Mass of dry flue gas	24.83	kg/kg of fuel
Amount of Wet flue gas	27.06	Kg of flue gas/kg of fuel
Amount of water vapour in flue gas	2.22	Kg of H2O/kg of fuel
Amount of dry flue gas	24.83	kg/kg of fuel
Specific Fuel consumption	52.80	kg of fuel/ton of billet
Heat Input Calculations		
Combustion heat of fuel	668000	Kcal/ton of billet
Sensible heat of fuel	0	Kcal/ton of billet
Total heat input	668000	Kcal/ton of billet
Heat Output Calculation		
Heat carried away by 1 ton of ceramics (useful heat)	240067	Kcal/ton of billet
Heat loss in dry flue gas per ton of ceramics	25056	Kcal/ton of billet
Loss due to H2 in fuel	72429	Kcal/ton of billet
Loss due to moisture in combustion air	26	Kcal/ton of billet
Loss due to partial conversion of C to CO	141	Kcal/ton of billet
Loss due to convection and radiation (openings in kiln - inlet & outlet of kiln car)	42,727	Kcal/ton of billet
Loss Due to Evaporation of Moisture Present in Fuel	0.0	Kcal/ton of billet
Total heat loss from kiln (surface) body	5300	Kcal/ton of billet

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 44 of 49	

Heat loss due to unburnts in Fly ash	0	Kcal/ton of billet
Heat loss due to unburnts in bottom ash	0	Kcal/ton of billet
Heat loss due to kiln car	273527	Kcal/ton of billet
Unaccounted heat lossess	8728	Kcal/ton of billet
Heat loss from kiln body and other sections		
Total heat loss from kiln	5300	Kcal/tons
Kiln Efficiency	35.9	%

2. Heat Balance Diagram



Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India	Rev.	2
Prepared by: DESL	Date: 06-07-2015	Page 45 of 49	

7 LIST OF VENDORS

EPIA 1: Radiation and convection loss reduction from surface of kiln

S.No	Name of Company	Address	Phone No.	E-mail
1	Morgan Advanced Materials - Thermal Ceramics	P.O. Box 1570, Dare House Complex, Old No. 234, New No. 2, NSC Bose Rd, Chennai - 600001, INDIA	T 91 44 2530 6888 F 91 44 2534 5985 M 919840334836	munuswamy.kadhirvelu@morganplc.com mtcl.india@morganplc.com ramaswamy.pondian@morganplc.com
2	M/s LLOYD Insulations (India) Limited,	2,Kalka ji Industrial Area, New Delhi-110019	Phone: +91-11-30882874 / 75 Fax: +91-11-44-30882894 /95 Mr. Rajneesh Phone : 0161-2819388 Mobile : 9417004025	Email: kk.mitra@lloydinsulation.com

EPIA 2: Excess Air Control

Sl. No.	Name of Company	Address	Phone No	E-mail /Website
Automation				
1	Delta Energy Nature Contact Person GurinderJeet Singh, Director	F-187, Indl. Area, Phase-VIII-Bm Mohali-160059	Tel.: 0172-4004213/ 3097657/ 2268197 Mobile: 9316523651 9814014144 9316523651	dengjss@yahoo.com den8353@yahoo.com
2	International Automation Inc	# 1698, First Floor, Canara Bank Building,	Office: +91-161-4624392,	Email: interautoinc@yahoo.com

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A0000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 46 of 49	

Sl. No.	Name of Company	Address	Phone No	E-mail /Website
	Contact Person (Sanjeev Sharma)	Near CheemaChowk, Link Road, Ludhiana	Mobile: +91-9815600392	
3	Happy Instrument	Yogesh 20, Proffulit Society, Nr Navo Vas, Rakhial, Ahmedabad-380021	079-22771702 9879950702	yogesh@happyinstrument.com
4	Wonder Automation	Kulwinder Singh E-192, Sector 74, Phase 8-B, Industrial Area, SAS nagar Mohali	0172-4657597 98140 12597	info@wonderplctr.com admn.watc@gmail.com hs@wonderplctr.com

EPIA 3: Replacing conventional ceiling fans with energy efficient fans

S.No	Name of Company	Address	Phone No.	E-mail
1	Super fans	351B/2A, Uzhaipalar street, GN Mills PO, Coimbatore. INDIA 641029.	Mob: 9489078737	Email: superfan@versadrives.com
2	Usha pumps Contact Person: Mr. KB Singh	J-1/162, Rajouri Garden, Rajouri Garden New Delhi, DL 110005	011(23318114),011 2510 4999,01123235861(Mr.Manish)r	Email: kb_singh@ushainternational.com

EPIA 4: Energy efficient light

S.No	Name of Company	Address	Phone No.	E-mail
1	Osram Electricals Contact Person: Mr. VinayBharti	OSRAM India Private Limited,Signature Towers, 11th Floor,Tower B, South City - 1,122001 Gurgaon, Haryana	Phone: 011-30416390 Mob: 9560215888	vinay.bharti@osram.com

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 47 of 49	

S.No	Name of Company	Address	Phone No.	E-mail
2	Philips Electronics Contact Person: Mr. R. Nandakishore	1st Floor Watika Atrium, DLF Golf Course Road, Sector 53, Sector 53 Gurgaon, Haryana 122002	9810997486, 9818712322(Yogesh- Area Manager), 9810495473(Sandee p-Faridabad)	r.nandakishore@phillips.com, sandeep.raina@phillips.com
3	Bajaj Electricals Contact Person: Mr. Kushgra Kishore	Bajaj Electricals Ltd,1/10, Asaf Ali Road, New Delhi 110 002	9717100273, 011-25804644 Fax : 011-23230214 ,011-23503700, 9811801341(Mr.RahulKhare), (9899660832)Mr.Atul Baluja, Garving Gaur(9717100273),9 810461907(Kapil)	kushagra.kishore@bajajelectricals.com, kushagrakishore@gmail.com; sanjay.adlakha@bajajelectricals.com

EPIA 5: Energy Monitoring System

S.No	Name of Company	Address	Phone No.	E-mail
1	Iadept Marketing Contact Person: Mr. Brijesh Kumar Director	S- 7, 2nd Floor, Manish Global Mall, Sector 22 Dwarka, Shahabad Mohammadpur, New Delhi, DL 110075	Tel.: 011-65151223	iadept@vsnl.net ,info@iadeptmarketing.com
2	Aimil Limited Contact Person: Mr. ManjulPandey	Naimex House A-8, Mohan Cooperative Industrial Estate, Mathura Road, New Delhi - 110 044	Office: 011- 30810229, Mobile: +91- 981817181	manjulpandey@aimil.com
3	Panasonic India Contact Person: NeerajVashisht	Panasonic India Pvt Ltd Industrial Device Division	9650015288	neeraj.vashisht@in.panasonic.com

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 48 of 49	

S.No	Name of Company	Address	Phone No.	E-mail
		(INDD) ABW Tower,7th Floor, Sector 25, IFFCO Chowk, MG Road,Gurgaon - 122001, Haryana,		

EPIA 6: Power factor improvement

PF Improvement				
Sl. No.	Name of Company	Address	Phone No.	E-mail / Website
1	Cummins Power Generation Contact Person: Rishi Gulati Senior Manager- Power Electronics	Cummins India Limited Power Generation Business Unit 35/A/1/2, Erandawana, Pune 411 038, India	Phone: (91) 020- 3024 8600 , +91 124 3910908	cpgindia@cummins.com rishi.s.gulati@cummins.com
2	Krishna Automation System Contact Person: Vikram Singh Bhati	ESTERN CHAWLA COLONY, NEAR KAUSHIK VATIKA, GURGAON CANAL BALLBGARH FARIDABAD 121004	Mob: 9015877030, 9582325232	krishnaautomationsystems@gmail.com

EPIA 7: Replacement of kiln car material

.No	Name of Company	Address	Phone No.	E-mail
1	INTERKILN INDUSTRIES LTD.	Sanghavi Chambers, Beside Canara Bank, Navrangpura ,Ahmedabad	+91-79-30911069 079-6438180	ik@interkiln.com

Client Name	Bureau of Energy Efficiency (BEE)	Project No.	9A000005602
Project Name	Promoting energy efficiency and renewable energy in selected MSME clusters in India		Rev. 2
Prepared by: DESL	Date: 06-07-2015	Page 49 of 49	